

Recognized as an  
American National Standard (ANSI)

**IEEE Std 524™-2003**  
(Revision of  
IEEE Std 524-1992)

# IEEE Guide to the Installation of Overhead Transmission Line Conductors

Sponsor

**Transmission & Distribution Committee**  
of the  
**IEEE Power Engineering Society**

Approved 30 December 2003

**American National Standard Institute**

Approved 17 October 2003

**IEEE-SA Standards Board**

**Abstract:** General recommendations for the selection of methods, equipment, and tools that have been found to be practical for the stringing of overhead transmission line conductors and overhead groundwires are provided.

**Keywords:** overhead transmission line conductors, overhead groundwires

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2004 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 12 March 2004. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

Print: ISBN 0-7381-3814-2 SH95170  
PDF: ISBN 0-7381-3815-0 SS95170

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied **“AS IS.”**

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE. Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
P.O. Box 1331  
Piscataway, NJ 08855-1331USA

**NOTE**—Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

# Introduction

(This introduction is not part of IEEE Std 524-2003, IEEE Guide to the Installation of Overhead Transmission Line Conductors.)

This guide provides general recommendations for the selection of methods, equipment, and tools that have been found to be practical for the stringing and grounding of overhead transmission line conductors and overhead groundwires. The following revisions have been made and are intended to improve the usefulness of the document:

- a) The IEEE Std 524, Guide to the Installation of Overhead Transmission Line Conductors and the supplemental IEEE Std 524a, Guide to Grounding During the Installation of Overhead Transmission Line Conductors have been combined into one document.
- b) The stringing specification for fiber optic cables has been expanded
- c) A clause on All Dielectric Self-Supporting (ADSS) cable has been added
- d) SSAC conductor type designation has been changed to the current ACSS designation
- e) Helicopter installation methods have been expanded
- f) All units have been changed to conform with IEEE metric policy

## Participants

At the time this standard was revised, the membership of the Task Group of the Working Group on the Construction of Overhead Lines of the Towers, Poles, and Conductors Subcommittee, was as follows:

**Neil Schmidt, Chair**

Bill Caulkins  
Jim L. Clark  
Denise Frey

Philip Givens  
Ron Magnus

Douglas Proctor  
Larry Slavin  
Frank R. Thrash, Jr.

The following members of the balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

James Applequist  
Anthony Baker  
Robert Bratton  
Sales Casals  
James Christensen  
Michael Clodfelder  
F. Leonard Consalvo  
Tommy Cooper  
Nicholas DeSantis  
Frank A. Denbrock  
J. Frederick Doering  
Randall Dotson  
Dale Douglass  
Marcia Eblen  
Robert Emerson  
Lowell Fink  
Marcel Fortin  
Denise Frey  
George Gela  
Phillip Givens

Charles W. Grose  
Randall Groves  
Richard Hensel  
Edward Horgan Jr.  
Magdi Ishac  
Gael Kennedy  
Henry Kientz  
Robert Kluge  
Donald Koonce  
Stephen R. Lambert  
James Larkey  
Keith Lindsey  
Gregory Luri  
Otto Lynch  
Faramarz Maghsoodlou  
Thomas McCaffrey  
Thomas McCarthy  
Gary Michel  
Yakov Motlis  
Abdul Mousa

George Niles  
John Olenik  
Robert Oswald  
Paulette Payne  
Carlos Peixoto  
Robert Peters  
Craig Pon  
Douglas Proctor  
Patrick Quinn  
Jerry Reding  
Joseph Renowden  
Thomas Rozek  
James Ruggieri  
Lluís Ramon  
Bob Saint  
Neil Schmidt  
Frank R. Thrash, Jr.  
Cassio Vinhal  
Daniel Ward  
James Wilson  
Luis E. Zambrano S.

The final conditions for approval of this standard were met on 17 October 2003. When the IEEE-SA Standards Board conditionally approved this standard on 11 September 2003, it had the following membership:

**Don Wright, *Chair***  
**Howard M. Frazier, *Vice Chair***  
**Judith Gorman, *Secretary***

H. Stephen Berger  
Joe Bruder  
Bob Davis  
Richard DeBlasio  
Julian Forster\*  
Toshio Fukuda  
Arnold M. Greenspan  
Raymond Hapeman

Donald M. Heirman  
Laura Hitchcock  
Richard H. Hulett  
Anant Jain  
Lowell G. Johnson  
Joseph L. Koepfinger\*  
Tom McGean  
Steve Mills

Daleep C. Mohla  
William J. Moylan  
Paul Nikolich  
Gary Robinson  
Malcolm V. Thaden  
Geoffrey O. Thompson  
Doug Topping  
Howard L. Wolfman

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Alan Cookson, *NIST Representative*  
Satish K. Aggarwal, *NRC Representative*

Don Messina  
*IEEE Standards Project Editor*

# Contents

1.	Overview.....	1
	1.1 Scope.....	1
	1.2 Purpose.....	1
	1.3 Application.....	1
2.	References.....	2
3.	Definitions and cross reference of terminology.....	2
	3.1 Definitions and terminology for conductor stringing equipment .....	2
	3.2 Acronyms.....	21
4.	Conductor stringing methods.....	22
	4.1 Slack or layout method .....	22
	4.2 Tension method.....	22
5.	Grounding equipment and methods.....	23
	5.1 Protective grounding principles .....	23
	5.2 Protection of personnel .....	23
	5.3 Hazards and electrical concepts.....	24
	5.4 Grounding equipment, methods, and testing .....	24
	5.5 Transmission line construction grounding systems .....	34
6.	Communications .....	40
7.	Conductor reels .....	40
	7.1 Reel types.....	40
	7.2 Reel handling .....	40
8.	Special requirements for mobile equipment .....	40
	8.1 Reel stand.....	40
	8.2 Helicopter.....	41
	8.3 Tensioner bullwheel characteristics.....	41
	8.4 Puller and tensioner operating characteristics.....	43
	8.5 Pilot line winder operating characteristics.....	44
9.	Travelers .....	44
	9.1 Sheave diameter.....	44
	9.2 Configuration of groove.....	45
	9.3 Bearings .....	46
	9.4 Material and construction .....	46
	9.5 Lining.....	47
	9.6 Electrical characteristics .....	47
	9.7 Bundled configurations.....	47
	9.8 Helicopter travelers.....	48

9.9 Uplift rollers and hold-down blocks .....	48
9.10 Traveler suspension .....	49
10. Typical procedures for stringing operations .....	49
10.1 Pull, tension, anchor, and splicing sites .....	49
10.2 Section between snub structures .....	51
10.3 Conductor splicing .....	52
10.4 Stringing procedures .....	54
10.5 Sagging procedures .....	60
10.6 Deadending precautions .....	65
10.7 Clipping-in .....	65
10.8 Damper installation .....	66
10.9 Spacer and spacer damper installation .....	66
11. Special conductors .....	66
11.1 ACSS — steel supported aluminum conductor .....	67
11.2 T-2 Conductor — twisted bare conductors .....	67
11.3 Self-damping conductor (SDC) .....	69
11.4 Composite overhead groundwire with optical fibers (OPGW) .....	70
11.5 All-dielectric self supporting fiber cable (ADSS) .....	71
Annex A (informative) Bibliography .....	74
Annex B (informative) Electrical theory .....	76
Annex C (informative) Grounding electrical concepts .....	82
Annex D (informative) Travelers or snub structure load calculation .....	96
Annex E (informative) Basic analysis for clipping offsets and sagging .....	98
Annex F (informative) Efficiency of travelers during tension stringing .....	106
Annex G (informative) Recommended bearing pressure on sheave linings .....	108
Annex H (informative) All aluminum 1350 alloy conductor standard packages .....	109
Annex I (informative) ACSR conductor standard packages .....	111
Annex J (informative) Drum or reel winding .....	114
Annex K (informative) Drum or reel capacities .....	115
Annex L (normative) Electric and magnetic field induction computer program presentation with sample problems .....	118
Annex M (normative) Source code for the electric field induction program (EFINCUC.C) .....	124
Annex N (normative) Source code for magnetic field induction program (MFINDUC.C) .....	134

# IEEE Guide to the Installation of Overhead Transmission Line Conductors

## 1. Overview

### 1.1 Scope

This guide provides general recommendations for the selection of methods, equipment, and tools that have been found to be practical for the stringing of overhead transmission line conductors and overhead groundwires. The guide also includes a comprehensive list of definitions for equipment and tools used in stringing and for stringing terms commonly employed. This guide does not address special conductors such as those used for river and canyon crossing. These conductors may be custom designed and often may require special considerations.

### 1.2 Purpose

The purpose of this guide is to present in one document sufficient details of present day methods, materials, and equipment to outline the basic considerations necessary for maintaining safe and adequate control of conductors during stringing operations. References are given in Clause 2 and the bibliography in Annex A for those desiring more detailed information. Because the terminology used for many hardware items and for many stringing terms varies from place to place, a list of definitions is included to provide correlation and clarification of the terms most commonly employed.

### 1.3 Application

This guide is broad enough, yet specific enough, to be applicable to the stringing of conventional overhead transmission conductors and overhead groundwires (OHGW) of the following types: AAAC, AAC, AACSR, ACAR, ACSR, ACSR/TW, CU, aluminum-clad steel OHGW, and galvanized steel OHGW.<sup>1</sup> Since stringing practices for different projects will be strongly influenced by the magnitude and nature of each project and by local circumstances, alternate methods that have been successfully employed are presented. Information contained in this guide may not be sufficient for certain special cases, such as when stringing extremely long spans, severe line angles, high tensions, or special conductors. In these cases, the manufacturer should be consulted. The practices that are described in this guide provide for continuous control of the conductor from the initial setup to the ready-for-service condition. Any legal requirements of national, state, or local regulations must, of course, be observed.

---

<sup>1</sup>See 3.2 for definitions of all acronyms.