

IEEE
blue
BOOK™



1015™

IEEE Recommended Practice for

**Applying Low
Voltage Circuit
Breakers Used in
Industrial and
Commercial Power
Systems**

Published by the
Institute of Electrical and
Electronics Engineers, Inc.

IEEE Std 1015™-2006
(Revision of
IEEE Std 1015-1997)

*Recognized as an
American National Standard (ANSI)*

IEEE Std 1015™-2006
(Revision of
IEEE Std 1015-1997)

IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems

Sponsor

**Power Systems Protection Committee
of the
IEEE Industry Applications Society**

Approved 5 September 2006

American National Standards Institute

Approved 30 March 2006

IEEE-SA Standards Board

Abstract: Information is provided for selecting the proper circuit breaker for a particular application. This recommended practice helps the application engineer specify the type of circuit breaker, ratings, trip functions, accessories, acceptance tests, and maintenance requirements. It also discusses circuit breakers for special applications, e.g., instantaneous only and switches. In addition, it provides information for applying circuit breakers at different locations in the power system, and for protecting specific components. Guidelines are also given for coordinating combinations of line-side and load-side devices.

Keywords: circuit breakers, circuit breaker evaluation, insulated case, insulated-case circuit breakers, low-voltage circuit breaker, low-voltage power circuit breaker, low-voltage protection, low-voltage protection device, molded case, molded-case circuit breaker, overcurrent protection, power circuit breaker, rating, testing

Grateful acknowledgement is made to the following organizations for having granted permission to reprint material in this document as follows:

Siemens Energy & Automation, Inc., Switchgear & Motor Control, P.O. Box 29503, Raleigh, NC 27626-0503, for Figure 1-2 and Figure 6-1 (right photo).

Square D Company, Distribution Equipment Business, Box 3069, 3700 Sixth Street S.W., Cedar Rapids, IA 52406, for Figure 1-1, Figure 6-1 (left photo), and Figure 6-2.

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 29 September 2006. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Safety Code and NESC are registered trademarks and service marks in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are registered trademarks in the U.S. Patent & Trademark Office, owned by The National Fire Protection Association.

Print: ISBN 0-7381-4954-3 SH95531
PDF: ISBN 0-7381-4955-1 SS95531

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 1015-2006, IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems.

This introduction provides an engineer a comprehensive reference source to aid in deciding what type of low-voltage circuit breaker to use for a particular application, and how to apply the circuit breaker. This recommended practice includes a comparison between the standards of low-voltage power circuit breakers and molded-case circuit breakers so that an engineer can make better, more informed choices. Pertinent tables have been extracted from other standards to provide the basis for the selection and application guidelines. In addition, specific application examples are provided.

Notice to users

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

The Blue Book Working Group for the 2006 edition had the following membership:

Donald H. McCullough II, Chair

- Chapter 1: Overview—**Donald H. McCullough, II, Chair**
- Chapter 2: Definitions, acronyms, and abbreviations—
Donald H. McCullough, II, Chair
- Chapter 3: Rating and testing—**Raymond D. Valentine, Chair**
Ray M. Clark, Vincent Saporita, Clive Kimblin, George D. Gregory
- Chapter 4: Specific applications—**James W. Brosnahan, Co-Chair**
Shaun P. Slattery*, Co-Chair
Ray M. Clark, Donald Colaberardino, Keith Cooper, George D. Gregory, David Roybal, Vincent Saporita, M. Stansbury, Raymond D. Valentine, Ralph Young
- Chapter 5: Selective coordination of low-voltage circuit breakers with other protective devices—**Lorraine Padden, Chair**
Jay Fischer, Vincent Saporita
- Chapter 6: Fused and special-purpose circuit breakers—
George D. Gregory, Co-Chair
Ray M. Clark, Co-Chair
Bruce G. Bailey, Donald H. McCullough, II
- Chapter 7: Acceptance and maintenance requirements—
Donald H. McCullough, II, Chair
Dan Neeser, George D. Gregory

Grateful appreciation and thanks is made to the following individuals for their support in the preparation of this standard:

Ruth Whitaker

William J. Morgan, II

This recommended practice is dedicated in memory of Shaun Slattery. The Working Group especially acknowledges his contributions to the original development of this recommended practice and his valuable insight into the material contained within this revision.

Historical Participants

Since the initial publication, many IEEE standards have added functionality or provided updates to material included in this recommended practice. The following is a historical list of participants who have dedicated their valuable time, energy, and knowledge to the creation of this material:

Jack Alacchi	Jay Fischer	Alan C. Pierce
Joseph J. Andrews	George D. Gregory	Bill Reardon
David S. Baker	William M. Hall	Vincent Saporita
Bruce G. Bailey	Walter Huening	Dean Sigmon
James W. Broshnahan	L. Guy Jackson	Robert Simpson
Kenneth W. Carrick	Ed Larsen	Shaun P. Slattery
Rene d. Catenschiold	Daniel J. Love	Raymond D. Valentine
Ray M. Clark	Bill May	Raymond O. D. Whitt
Kieth R. Cooper	Donald H. McCullough, II	Ralph Young
	Russel Ohlson	

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

Bruce G. Bailey	Paul Hamer	James Michalec
R. W. Becker	Adrienne Hendrickson	Gary Michel
Enrique Betancourt	Douglas Hopkins	T. David Mills
Thomas Blair	Ronald Hotchkiss	James Mitchem
Michael Brimsek	Robert Ingham	Charles Morse
James W. Brosnahan	David Jackson	Dan Neeser
Thomas Blair	L. Guy Jackson	Arthur Neubauer
Donald Colaberardino	Joseph Jancauskas	T. W. Olsen
Stephen P Conrad	Clive Kimblin	Lorraine Padden
James M. Daley	Yuri Khersonsky	Prafulla Pillai
Stephen Dare	Royce King	Percy Pool
Byron Davenport	E. Kramer	Brian Rener
Guru Dutt Dhingra	Steven Larson	James Ruggieri
Amir El-Sheikh	Timothy Lensmire	Melvin Sanders
Dan Evans	Blane Leuschner	Vincent Saporita
Jay Fischer	Jason Lin	Robert Schuerger
H. Landis Floyd	Michael Lowenstein	Robert Seitz
Carl Fredericks	Allan Ludbrook	Shaun Slattery
Edgar Galyon	Gregory Luri	Robert Smith, Jr.
Donner Gary	Keith Malmedal	James Stoner
Randall Groves	Donald H. McCullough, II	Jane Ann Verner
Erich Gunther	John Merando	Donald W. Zipse

When the IEEE-SA Standards Board approved this recommended practice on 30 March 2006, it had the following membership:

Steve M. Mills, *Chair*
Richard H. Hulett, *Vice Chair*
Don Wright, *Past Chair*
Judith Gorman, *Secretary*

Mark D. Bowman
Dennis B. Brophy
William R. Goldbach
Arnold M. Greenspan
Robert M. Grow
Joanna N. Guenin
Julian Forster*
Mark S. Halpin

Kenneth S. Hanus
William B. Hopf
Joseph L. Koepfinger*
David J. Law
Daleep C. Mohla
T. W. Olsen
Glenn Parsons
Ronald C. Peterson
Tom A. Prevost

Greg Ratta
Robby Robson
Anne-Marie Sahazian
Virginia C. Sulzberger
Malcolm V. Thaden
Richard L. Townsend
Walter Weigel
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan H. Cookson, *NIST Representative*

Michelle D. Turner
IEEE Standards Program Manager, Document Development

Matthew Ceglia
IEEE Standards Program Manager, Technical Program Development

Patricia Gerdon
IEEE Standards Program Administrator Manager, Technical Program Development

CONTENTS

Chapter 1

Overview.....	1
1.1 Scope.....	1
1.2 Two classifications of breakers.....	1
1.3 Description of a molded-case circuit breaker	2
1.4 Description of a low-voltage power circuit breaker	3
1.5 Document organization.....	6
1.6 Summary.....	8
1.7 Normative references.....	8
1.8 Bibliography	9

Chapter 2

Definitions, acronyms, and abbreviations.....	11
2.1 Definitions	11
2.2 Acronyms and abbreviations	17
2.3 Normative references.....	18
2.4 Bibliography	18

Chapter 3

Rating and testing	19
3.1 Relevance of rating and testing.....	19
3.2 The ideal circuit breaker	19
3.3 The practical circuit breaker	19
3.4 Basic circuit-breaker selection criteria	20
3.5 The role of industry standards	20
3.6 The role of safety and industry codes	21
3.7 Comparison of testing requirements	21
3.8 Circuit-breaker classes and types.....	22
3.9 Generalized application considerations	23
3.10 References on rating and application.....	23
3.11 Endurance considerations	24
3.12 Circuit-breaker voltage rating considerations.....	28
3.13 Frequency rating and considerations	30
3.14 Temperature considerations.....	31
3.15 Enclosure considerations	32
3.16 Cable, wire, and conductor considerations	34
3.17 De-rating for ambient temperature	38
3.18 Circuit-breaker humidity limitations	39
3.19 Circuit-breaker altitude limitations.....	40
3.20 Circuit-breaker ampere rating.....	41
3.21 National Electrical Code considerations.....	41
3.22 Preferred current ratings	42
3.23 Load effects.....	49
3.24 The effect of nonlinear loads on circuit breakers	49
3.25 The effect of high inrush loads	50

3.26	Overload testing of circuit breakers	50
3.27	Forced-air cooling of LVPCBs	55
3.28	Short-circuit interrupting rating	55
3.29	Fault-current calculation considerations	57
3.30	Circuit-breaker interrupting ratings	57
3.31	Single-pole fault interruption testing	58
3.32	Circuit-breaker evaluation in standards for testing	58
3.33	Blow-open contact arms	65
3.34	Circuit breaker useful life	65
3.35	Considerations on interrupting duty and maintenance	66
3.36	Integrally fused devices	66
3.37	Series-connected rating	67
3.38	Cascade arrangement	68
3.39	Short-time rating	68
3.40	Circuit-breaker evaluation for X/R ratio or short-circuit power factor	69
3.41	Single-pole interrupting capability and power system design considerations	70
3.42	Applying ac thermal-magnetic molded-case circuit breakers using their UL 489 dc rating	73
3.43	Normative references	76
3.44	Bibliography	77
Chapter 4		
	Specific applications	79
4.1	Scope	79
4.2	Selection considerations	79
4.3	Selection approach for application requirements	80
4.4	Selection approach for electrical ratings	80
4.5	Modifications and accessories for specific applications	95
4.6	Normal versus abnormal conditions	98
4.7	Considerations for applying MCCBs, ICCBs, and LVPCBs	99
4.8	Service requirements and protection	100
4.9	Main circuit breakers	100
4.10	Tie circuit breakers	102
4.11	Feeder protection	103
4.12	Normative references	132
4.13	Bibliography	133
Chapter 5		
	Selective coordination of low-voltage circuit breakers with other protective devices	135
5.1	Introduction	135
5.2	Low-voltage power circuit breakers	135
5.3	Low-voltage MCCBs and ICCBs	139
5.4	Other coordinating devices	140
5.5	Coordination examples	142
5.6	Normative references	154
5.7	Bibliography	155

Chapter 6

Fused and special-purpose circuit breakers	157
6.1 Introduction.....	157
6.2 Instantaneous-trip circuit breakers.....	157
6.3 Mine-duty circuit breakers.....	160
6.4 Current-limiting circuit breakers	162
6.5 Molded-case switches	164
6.6 Fused circuit breakers	165
6.7 Circuit breaker and ground-fault circuit interrupter	166
6.8 Arc-fault circuit interrupter.....	167
6.9 Supplementary protectors	168
6.10 Normative references	169
6.11 Bibliography	170

Chapter 7

Acceptance and maintenance requirements	171
7.1 Scope.....	171
7.2 Maintenance program	171
7.3 Maintenance of MCCBs	173
7.4 Maintenance of LVPCBs	175
7.5 Maintenance and testing of ICCBs	176
7.6 Maintenance and testing of molded-case switches	176
7.7 Maintenance of ground-fault circuit interrupters (GFCIs)	176
7.8 Documenting maintenance results	177
7.9 Testing program.....	177
7.10 Failures detected	185
7.11 Normative references	185
7.12 Bibliography	187
Annex 7A (informative) MCCB data record	188
Annex 7B (informative) LVPCB data record	194

IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems

Chapter 1 Overview

1.1 Scope

This recommended practice provides information for selecting the proper circuit breaker for a particular application. This recommended practice helps the application engineer specify the type of circuit breaker, ratings, trip functions, accessories, acceptance tests, and maintenance requirements. It also discusses circuit breakers for special applications, e.g., instantaneous only and switches. In addition, it provides information for applying circuit breakers at different locations in the power system and for protecting specific components. Guidelines are given for coordinating combinations of line-side and load-side devices. Acceptance testing and maintenance guidelines are provided so that reliable operation can be verified and maintained.

This recommended practice does not cover the selection and application of circuit breakers such as marine circuit breakers and definite purpose circuit breakers.

1.2 Two classifications of breakers

There are two main classifications of low-voltage circuit breakers: molded-case circuit breakers and low-voltage power circuit breakers. Within the molded-case circuit breaker classification, there is another type of circuit breaker called the insulated-case circuit breaker. The construction and characteristics of these three types will be discussed. Throughout the balance of this recommended practice, these devices will be referred to as follows:

- MCCB: molded-case circuit breaker
- ICCB: insulated-case circuit breaker
- LVPCB: low-voltage power circuit breaker

Each one of these circuit breakers has different design characteristics and, in many cases, different application requirements.