

Drinking water treatment units — Health effects

**NSF International Standard/
American National Standard**



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

This Standard is subject to revision.
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units
c/o NSF International
789 North Dixboro Road, P. O. Box 130140
Ann Arbor, MI 48113-0140, USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
FAX: (734) 769-0109
E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF International Standard/
American National Standard
for Drinking Water Treatment Units —

**Drinking water treatment units –
Health effects**

Standard Developer
NSF International

Adopted July 10, 2007
NSF International Board of Directors

Designated as an ANSI Standard
July 10, 2007
American National Standards Institute

Prepared by
The NSF Joint Committee on Drinking Water Treatment Units

Recommended for adoption by
The NSF Council of Public Health Consultants

Adopted by
The NSF Board of Directors
December 1981

Revised June 1982	Revised November 2000
Revised June 1988	Revised January 2001
Revised May 1990	Revised January 2002
Revised November 1992	Addendum 1.0 – 2002, June 2002
Revised September 1993	Addendum 2.0 – 2002, October 2002
Revised March 1994	Editorial Revision – November 2003
Revised March 1996	Revised July 2004
Revised September 1996	Addendum 1.0 – 2002e, August 2004
Revised September 1997	Revised February 2005
Revised November 1998	Revised January 2006
Revised March 1999	Addendum 1.0 – 2006, March 2006
Revised September 1999	Revised February 2007
Revised May 2000	Revised July 2007

Published by

NSF International
P. O. Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation “NSF/ANSI 53 – 2007a.”

Copyright 2007 NSF International

Previous editions © 2006, 2005, 2004, 2002, 2001, 2000, 1998, 1997, 1996, 1994, 1993, 1992, 1990, 1988, 1982, 1981

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

Contents

1	General	1
1.1	Purpose	1
1.2	Scope	1
1.3	Minimum requirements	1
1.4	Chemical and mechanical reduction performance claims	2
1.5	Standard review	2
2	Normative references	2
3	Definitions	3
4	Materials	7
4.1	Materials in contact with drinking water	7
4.2	Materials evaluation	7
4.3	Gas chromatography/mass spectroscopy (GC/MS) analysis	8
	Table 1 – Extraction testing parameters	10
	Table 2 – Formulation dependent extraction testing parameters	12
	Table 3 – Materials listed in U. S. Code of Federal Regulations, Title 21, not requiring formulation review	14
	Table 4 – Non-specific extraction testing parameters	15
5	Structural performance	15
5.1	Structural integrity	15
	Table 5 – Structural integrity testing requirements	16
6	Minimum performance requirements	20
6.1	Performance indication of chemical reduction capacity	20
6.2	Elements	22
6.3	Flow control	22
6.4	Waste connections	22
6.5	Product water dispensing outlets	22
6.6	Hazards	23
6.7	Systems used in bottled water plants	23
6.8	Operation temperature	23
6.9	Point-of-entry rated pressure drop	23
6.10	Minimum service flow	23
	Table 6 – Minimum service flow	23
6.11	Rated service flow	24
6.12	Active agents and additives	24
6.13	Media	24
6.14	Filter media	26
7	Elective performance claims – test methods	26
7.1	General requirements	26
7.2	Chemical reduction claims	28
	Table 7 – Chemical reduction requirements	28
	Table 8 – Chemical reduction requirements	32
	Table 9 – Radon reduction requirements	36
	Table 10 – Organic chemicals included by surrogate testing	39
7.3	Mechanical filtration reduction claims	43
7.4	Metals reduction testing	58
	Table 11 – Chemical reduction requirements	59
	Table 12 – Arsenic reduction requirements (Trivalent challenge)	63
	Table 13 – General metals reduction requirements	68

Table 14 – Lead reduction requirements.....	71
Table 15 – Mercury reduction requirements.....	78
8 Instruction and information	79
8.1 Installation, operation, and maintenance instructions.....	79
8.2 Data plate.....	81
8.3 Replacement components	83
8.4 Performance data sheet.....	84
Table 16 – Performance data sheet reduction claims	84
Table 17 – Performance data sheet reduction claims for organic chemicals.....	87
Table 18 – Performance data sheet performance claims for percent reduction	88
Annex A	A1
A.1 Summary of method.....	A1
A.2 Equipment.....	A1
A.3 Reagents.....	A2
A.4 Safety.....	A2
A.5 Enumeration of stock oocyst suspension.....	A3
A.6 Procedure.....	A4
A.7 Quality control	A7
A.8 Analyst verification	A9
Table A1 – Ethanol/glycerol series.....	A10
Table A2 – Suggested sample volumes for 25 mm membrane filters.....	A10
Table A3 – Quality control acceptance criteria for performance tests.....	A10
Annex B	B1
B.1 Summary of method.....	B1
B.2 Equipment.....	B1
B.3 Reagents.....	B1
B.4 Enumeration of stock microspheres.....	B2
B.5 Procedure.....	B2
B.6 Quality control	B4
B.7 Analyst verification	B6
Table B1 – Suggested sample volumes for 25 mm membrane filters.....	B7
Table B2 – Quality control acceptance criteria for performance tests for microspheres.....	B7
Annex C	C1
C.1 Example fact section for pentavalent arsenic treatment systems.....	C1
C.2 Example fact section for arsenic treatment systems	C2
Annex D	D1
D.1 Marking the product	D1
D.2 Listing certified companies.....	D1
D.3 Annual audits	D1
D.4 Testing	D2
D.5 Toxicological evaluation of materials formulations	D2
D.6 Corrective action	D2
D.7 Enforcement.....	D2
D.8 Administrative review	D2
D.9 Appeals	D2
D.10 Complaints.....	D3
D.11 Advertising.....	D3
D.12 Records	D3
D.13 Public notice	D3
D.14 Confidentiality.....	D3

Foreword²

The purpose of this Standard is to establish minimum requirements for materials, design and construction, and performance of drinking water treatment systems that are designed to reduce specific health-related contaminants in public or private water supplies. NSF/ANSI 53 specifies minimum product literature requirements that manufacturers must provide to authorized representatives and owners.

This edition of the Standard contains the following revisions:

Issue 57

The revisions made in this issue enable point-of-entry drinking water treatment systems to be covered by NSF/ANSI 61 and to use this one materials safety standard as the only test protocol for point-of-entry (POE) drinking water treatment units. 6.9, Rated pressure drop, has been updated to apply to POE systems with and without built-in-flow control. The definitions for point-of-entry and point-of-use systems have also been updated.

Issue 58

This issue revises the requirements for filter media. The filter media requirement has been changed so that conformance is demonstrated by a lack of visible evidence of media migration in samples collected at the completion of a mechanical filtration test for products making mechanical reduction claims. For systems that do not make mechanical filtration claims, any evidence of visible media migration detected in the course of contaminant reduction testing constitutes a failure for filter media. Visible evidence of media migration consists of visible detection of particles, and then confirmation that the particles are sufficient to represent a failure by confirming retention on a 100-mesh sieve.

Issue 59

The revision made in this issue establishes sample sizes for mechanical reduction tests for 7.3.1, Asbestos reduction testing of 1 L, and 7.3.3, Turbidity reduction testing of 250 mL.

Issue 61

The revision made in this issue updates the pass/fail criteria levels in Tables 1 and 2 for cyclohexanone, methyl ethyl ketone, carbon disulfide, diethyl phthalate, di-n-butyl phthalate, butyl benzyl phthalate, naphthalene, acetone, and 1,4-dioxane to match the levels in NSF/ANSI 61.

Issue 64

The revision made in this issue clarifies that the active agent levels from two units will be evaluated against levels of toxicological significance in 6.12, Active agents and additives, and will not be evaluated during extraction testing.

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

Issue 67

The revision made in this issue adds USEPA method 524.2 to Table 1 for the analysis of volatile organic compounds and carbon disulfide and to Table 2 for the analysis of acetone, cyclohexanone, tetrahydrofuran, and methyl ethyl ketone. It also adds USEPA method 525.2 to Table 2 for the analysis of phthalates and polynuclear aromatic hydrocarbons. This proposed revision also includes language to ensure, when the GC/MS method (method 625) is used, that an adequate analytical library has been developed.

An editorial change has been made to 7.4.3 Lead reduction testing. Extraneous language has been removed from 7.4.3.8.

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units, c/o NSF International, Standards Department, P. O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

NSF/ANSI Standard for Drinking Water Treatment Units —

Drinking water treatment units — Health effects

1 General

1.1 Purpose

It is the purpose of this Standard to establish minimum requirements for materials, design and construction, and performance of point-of-use and point-of-entry drinking water treatment systems that are designed to reduce specific health-related contaminants in public or private water supplies. Such systems include point-of-entry drinking water treatment systems used to treat all or part of the water at the inlet to a residential facility or a bottled water production facility, and includes the material and components used in these systems. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners, as well as the minimum service-related obligations that the manufacturer shall extend to system owners.

1.2 Scope

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private). These substances are considered established or potential health hazards. They may be microbiological, chemical, or particulate (including filterable cysts) in nature. It is recognized that a system may be effective in controlling one or more of these contaminants, but systems are not required to control all. Activated carbon filter systems covered by this Standard are not intended to be used with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

1.3 Minimum requirements

A system as defined in this standard shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7.

A component as defined in this standard shall meet the requirements of 4 and 8. If the component is pressure-bearing, it shall also meet the applicable requirements of 5.

A commercial modular system as defined in this standard shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7. Manifolds of commercial modular systems shall meet the requirements of 4, 5 (if pressure bearing), and 8, and shall be evaluated as stand-alone components. Manifolds shall have a minimum internal diameter such that the water velocity in the manifold will not exceed 3 m (10 ft) per second (which can be calculated based upon the system flow rate and the manifold internal diameter). Individual modular elements evaluated as a manifold and modular element combination shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7.