IEEE Guide for Recommended Electrical Clearances and Insulation Levels in Air-Insulated Electrical Power Substations

IEEE Power Engineering Society

Sponsored by the
Substations Committee

1427™

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

4 May 2007

IEEE Std 1427™-2006

IEEE Guide for Recommended Electrical Clearances and Insulation Levels in Air-Insulated Electrical Power Substations

Sponsor
Substations Committee
of the
IEEE Power Engineering Society

Approved 6 December 2006
IEEE-SA Standards Board

Abstract: This guide, covering three-phase ac systems from 1 kV to 800 kV, provides recommended electrical operating and safety clearances and insulation levels in air-insulated electric supply substations; addresses insulation coordination procedures; provides design procedures for the selection and coordination of the insulation levels within the station as they relate to substation clearances; and addresses how reduced clearances in high-voltage ac substations will allow for compact bus arrangements and substation voltage uprating applications.

Keywords: basic lightning impulse insulation level (BIL), basic switching impulse insulation level (BSL), clearances, insulation coordination, insulation levels, substation

---

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Print: ISBN 0-7381-5310-9 SH95611
PDF: ISBN 0-7381-5311-7 SS95611

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied "**AS IS**."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Introduction

This introduction is not part of IEEE Std 1427-2006, IEEE Guide for Recommended Electrical Clearances and Insulation Levels in Air Insulated Electrical Power Substations.

This guide was revised by members of Working Group D1—Recommended Minimum Clearances in Substation and is under the sponsorship of the Transmission and Distribution Substations Subcommittee of the IEEE/PESCS, Substations Committee.

Notice to users

Errata

Errata, if any, for this and all other guides can be accessed at the following URL: http://standards.ieee.org/reading/ieee/updates/errata/index.html. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: http://standards.ieee.org/reading/ieee/interp/index.html.

Patents

Attention is called to the possibility that implementation of this guide may require use of subject matter covered by patent rights. By publication of this guide, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Participants

At the time this guide was completed, the Working Group D1—Recommended Minimum Clearances in Substation had the following membership:

Kenneth White, *Chair*

Hanna Abdallah
Abbas Abed
Ken Aldridge
Joseph Bell
Steven Brown
Alan R. Byrd
Alton Comans
Richard N. Crowdis
Gary Engmann
Dennis R. Falkenheim
William B. Kahanek
Charles Koenig
Debra Longtin
Jeffrey Merryman
Jeffrey Nelson
Robert Nowell
Edward J. O'Donnell
Janusz Polak
Mike Portale
John Randolph
Donald R. Rogers
Alan Rotz
Steve Rozinka
Anne-Marie Sahazizian
Hamid Sharifnia
Boris Shvartsberg
Garry Simms
Roland Youngberg

The following members of the balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
Roy Alexander
Marcos Andrade
Stan J. Arnot
Ali Al Awazi
Anthony Baker
Thomas Barnes
W. J. Bergman
Enrique Betancourt
Philip Bolin
Stuart Bouchey
Eldridge R. Byron
William Chisholm
R. Daubert
Byron Davenport
Matthew Davis
Frank Denbrock
Guru Dutt Dhingra
Randall Dotson
Gary Engmann
Rabiz Foda
Frank Gerleve
Josephe Greco
Erik Guillot
Ajit K. Gwal
Edwatd Horgan, Jr.
James Houston
David W. Jackson
Clark Jacobson
Joseph Jancauskas
Mark Kempker
Hermann Koch
Joseph Koepfinger
Alan Kollar
David Krause
Chandra Krishnayya
Luther Kurtz
Stephen R. Lambert
Gerald Lee
George N. Lester
Jason Lin
Peter Lips
Albert Livshitz
William Lowe
Gregory Luri
Keith Malmedal
Frank Mayle
Mark McGranaghan
Bryan Melville
Gary L. Michel
Daleep Mohla
Abdul Mousa
Jeffrey Nelson
Art Neubauer
Joe Nims
Robert Nowell
T. W. Olsen
Carlos Peixoto
Michael Pehosh
John Randolph
Anne-Marie Sahazizian
Carl Schneider
Michael Sharp
H. Jin Sim
Garry Simms
Harinderpal Singh
James Sosinski
Allan St. Peter
Brian Story
Malcolm Thaden
Eric Udren
Jane Ann Verner
Hemant Vora
Joe Watson
William Wessman
Kenneth D. White
James W. Wilson, Jr.
Roland Youngberg

When the IEEE-SA Standards Board approved this standard on 6 December 2006, it had the following membership:

Steve M. Mills, *Chair*
Richard H. Hulett, *Vice Chair*
Don Wright, *Past Chair*
Judith Gorman, *Secretary*

Mark D. Bowman
Dennis B. Brophy
Joseph Bruder
Richard Cox
Bob Davis
Julian Forster*
Joanna N. Guenin
Mark S. Halpin
Raymond Hapeman
William B. Hopf
Lowell G. Johnson
Herman Koch
Joseph L. Koepfinger*
David J. Law
Daleep C. Mohla
Paul Nikolich
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Gary S. Robinson
Frank Stone
Malcolm V. Thaden
Richard L. Townsend
Joe D. Watson
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Alan H. Cookson, *NIST Representative*

Don Messina
IEEE Standards Program Manager, Document Development

Matthew Ceglia
IEEE Standards Program Manager, Technical Program Development

Contents

IEEE Guide for Recommended Electrical Clearances and Insulation Levels in Air-Insulated Electrical Power Substations

1. Overview

1.1 Scope

This guide, covering three-phase ac systems from 1 kV to 800 kV, provides recommended electrical operating and safety clearances and insulation levels in air-insulated electric supply substations; addresses insulation coordination procedures; provides design procedures for the selection and coordination of the insulation levels within the station as they relate to substation clearances; and addresses how reduced clearances in high-voltage ac substations will allow for compact bus arrangements and substation voltage uprating applications.

This guide addresses insulation coordination procedures, including the choice of insulation levels and arrester specification, in limited detail and only as relevant to clearance requirements. Detailed and expanded coverage of insulation coordination procedures is provided in other ANSI and IEEE guides and standards (see Clause 2).

This guide focuses on open-air bus assemblies and configurations and excludes apparatus clearances (i.e., bushing clearances for transformers, and breakers). Detailed coverage of apparatus clearances is provided in other applicable guides and standards.

1.2 Purpose

Proper electrical clearances are necessary for the design, construction, and operation of electric supply substations. This document develops guidelines for the application of recommended electrical clearances and insulation levels in air-insulated substations. The recommended clearances incorporate both design/operating clearances and safety clearances.