



# IEEE Standard for Flame-Propagation Testing of Wire and Cable

---

**IEEE Power Engineering Society**

Sponsored by the  
Insulated Conductors Committee

1202<sup>TM</sup>

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997, USA  
14 September 2006

**IEEE Std 1202<sup>TM</sup>-2006**  
(Revision of  
IEEE Std 1202-1991)



**IEEE Std 1202™-2006**  
(Revision of  
IEEE Std 1202-1991)

# **IEEE Standard for Flame-Propagation Testing of Wire and Cable**

Sponsor  
**Insulated Conductors Committee**  
of the  
**IEEE Power Engineering Society**

Approved 8 June 2006  
**IEEE-SA Standards Board**

**Abstract:** Standardization of cable flame propagation testing is beneficial to cable manufacturers, distributors, and users. Uniform procedures; consistent, repeatable results; and measurable test acceptance criteria are required to allow comparisons among competing products and to allow selection of the correct product for the application.

**Keywords:** 20 kW, 20 min, 70 000 Btu/h, after burn, cable, char, charring, flame propagation, test protocol, vertical cable tray, wire

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 14 September 2006. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code and NEC are both registered trademarks, owned by the National Fire Protection Association, Inc.

Print: ISBN 0-7381-5000-2           SH95554  
PDF: ISBN 0-7381-5001-0        SS95554

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied **“AS IS.”**

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std 1202-2006, IEEE Standard for Flame-Propagation Testing of Wire and Cable.

This standard provides a test procedure for determining wire and cable flame propagation characteristics due to ignition sources either outside of or within the cable system. The purpose of this revision is to update the standard to current industry practices and to harmonize this document with similar vertical tray flame test standards, such as UL 1685 and CSA C22.2 No. 22.2 No. 0.3-01 (R2005), FT4. This standard is not meant to determine circuit integrity or fire stop capability of wire or cable systems. This standard is also not meant to determine the protection afforded to cables by tray covers, conduits, or fire barrier materials. These considerations are covered in other more appropriate standards. This standard may be used to satisfy wire and cable flame propagation requirements identified in National Electrical Code® (NEC®) (NFPA 70-2005); CSA Standard C22.1-06, Canadian Electrical Code (CEC), Part I; or Mexican NOM-001 (MEC), Aparatos Electronicos de Uso Domestico Alimentados por Diferentes Fuentes de Energia Electrica. This standard is referenced in other standards such as IEEE Std 383™-2003 and IEEE Std 1580™-2001.

This standard has been coordinated with Underwriters Laboratories (UL), the Canadian Standards Association (CSA), and Mexico's SDO Association of Standardization and Certification (ANCE) as part of the tri-national harmonization process. Even though the IEEE is not formally part of the harmonization group, the content of this standard has been reviewed to achieve common technical requirements.

## Notice to users

### Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

### Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

### Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

## Participants

The Wire and Cable Fire Propagation Working Group of the Maintenance, Operation & Safety Subcommittee of the Power Systems Engineering Committee of the Industrial and Commercial Power Systems Department of the IEEE Industrial Applications Society originally prepared this standard. The document was initially issued in 1991 and confirmed for use on a five-year period since. The standard was transferred to the Insulated Conductors Committee (ICC) of the Power Engineering Society in mid-2002 and revised by ICC working group D15W, which had the following membership:

**John E. Merando Jr., *Chair***  
**Timothy J. Clancy, *Vice Chair***

J. Richard Barker  
Kenneth E. Bow  
Kent W. Brown  
John R. Cancelosi  
James M. Daly  
Chris K. Durland  
Steven N. Graham

Thomas J. Guida  
Ajit K. Gwal  
Brian Haydon  
Ajit K. Hiranandani  
Robert L. Konnik  
Randall K. Laymon

Arturo Maldonado  
C. David Mercier  
Jan S. Pirrong  
Stephen J. Sandberg  
Albert H. Spear III  
Michael D. Sweat  
William D. Wilkens

The following members of the balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Butch Anton  
Ali Al Awazi  
Adam J. Bagby  
Michael G. Bayer  
Thomas H. Blair  
Kenneth E. Bow  
Kent W. Brown  
John R. Cancelosi  
John H. Cooper  
Tommy P. Cooper  
Luis M. Coronado  
James M. Daly  
Donald G. Dunn  
Surinder L. Dureja  
Gary R. Engmann  
Keith Flowers  
Marcel Fortin  
Carl J. Fredericks  
Waymon P. Goch  
Steven N. Graham

Randall C. Groves  
Ajit K. Gwal  
Lauri J. Hiiivala  
David A. Horvath  
Dennis Horwitz  
David W. Jackson  
Paul R. Johnson Jr.  
A. S. Jones  
James H. Jones  
J. L. Koepfinger  
Jim Kulchisky  
Thomas W. La Rose  
Donald N. Laird  
Solomon Lee  
William E. Lockley  
Lisardo Lourido  
Russell E. Lowe  
William Lumpkins  
G. L. Luri  
Glenn J. Luzzi

Eric P. Marsden  
William M. McDermid  
Nigel P. McQuin  
John E. Merando Jr.  
Gary L. Michel  
William A. Moncrief  
Jerry R. Murphy  
Shantanu Nandi  
Michael S. Newman  
T. W. Olsen  
Stephen J. Sandberg  
David Singleton  
Peter B. Stevens  
S. Thamilarasan  
John E. Turner  
Kenneth D. White  
William D. Wilkens  
James W. Wilson Jr.  
David J. Zaprazny  
Donald W. Zipse

When the IEEE-SA Standards Board approved this standard on 8 June 2006, it had the following membership:

**Steve M. Mills**, *Chair*  
**Richard H. Hulett**, *Vice Chair*  
**Don Wright**, *Past Chair*  
**Judith Gorman**, *Secretary*

Mark D. Bowman  
Dennis B. Brophy  
Joseph Bruder  
Richard Cox  
Bob Davis  
Julian Forster\*  
Joanna N. Guenin  
Mark S. Halpin  
Raymond Hapeman

William B. Hopf  
Lowell G. Johnson  
Herman Koch  
Joseph L. Koepfinger\*  
David J. Law  
Daleep C. Mohla  
Paul Nikolic

T. W. Olsen  
Glenn Parsons  
Ronald C. Petersen  
Gary S. Robinson  
Frank Stone  
Malcolm V. Thaden  
Richard L. Townsend  
Joe D. Watson  
Howard L. Wolfman

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*  
Richard DeBlasio, *DOE Representative*  
Alan H. Cookson, *NIST Representative*

Don Messina  
*IEEE Standards Project Editor*

Matthew Ceglia  
*IEEE Standards Program Manager, Technical Program Development*

# Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	1
1.3 Applications.....	1
1.4 Disclaimer.....	1
1.5 Test precautions.....	1
2. Normative references.....	1
3. Definitions.....	1
4. Flame test facility .....	1
4.1 Enclosure .....	1
4.2 Exhaust duct .....	4
4.3 Air movement within the enclosure.....	4
4.4 Cable tray.....	5
4.5 Burner and mixer .....	5
4.6 Flowmeters .....	6
4.7 Supply air.....	6
4.8 Propane .....	6
5. Test sample requirements .....	6
5.1 Cable samples .....	6
5.2 Tests required .....	7
6. Flame test procedure.....	7
6.1 Cable mounting.....	7
6.2 Test procedure .....	9
7. Test evaluation .....	10
7.1 Evaluation of damage .....	10
7.2 Performance criteria.....	11
7.3 Test report.....	11
Annex A (normative) Burner and mixer information.....	12
Annex B (informative) Bibliography.....	14



# IEEE Standard for Flame-Propagation Testing of Wire and Cable

## 1. Overview

### 1.1 Scope

This standard provides a protocol for exposing cable samples to a theoretical 20 kW (70 000 Btu/h) flaming ignition source for a 20-min test duration. The test determines the flame propagation tendency of single-conductor and multi-conductor cables intended for use in cable trays.

### 1.2 Purpose

The purpose of this standard is to establish a test protocol and performance criteria to determine the flame propagation tendency of cables in a vertical cable tray.

### 1.3 Applications

This standard shall apply to multi-conductor cables and single insulated conductors that are allowed to be installed in cable tray, or to other cables and conductors for which a flame rating to the requirements of this standard is desired.

### 1.4 Disclaimer

The results obtained using this test do not imply that cables of similar cable construction will necessarily perform the same way in other cable arrangements, other cable tray configurations, or other environments.

### 1.5 Test precautions

Fire testing of products and materials is inherently hazardous. Adequate safeguards for personnel and property shall be employed while conducting these tests.