

IEEE Recommended Practice for Interconnecting Distributed Resources with Electric Power Systems Distribution Secondary Networks

Sponsor

**IEEE Standards Coordinating Committee 21 on
Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage**

Approved 10 September 2011

IEEE-SA Standards Board

Abstract: Recommendations and guidance for distributed resources (DR) interconnected on the distribution secondary networks, including both spot networks and grid networks, are provided. This document gives an overview of distribution secondary network systems design, components, and operation; describes considerations for interconnecting DR with networks; and provides potential solutions for the interconnection of DR on network distribution systems. IEEE Std 1547.6-2011 is part of the IEEE 1547™ series of standards. IEEE Std 1547-2003 provides mandatory requirements for the interconnection of DR with EPSs and focuses primarily on radial distribution circuit interconnections. For DR interconnected on networks, all of IEEE Std 1547-2003 needs to be satisfied. IEEE Std 1547.6-2011 was specifically developed to provide additional information in regard to interconnecting DR with distribution secondary networks.

Keywords: distributed resources, distribution grid, distribution secondary networks, electric power systems, grid networks, IEEE 1547.6, interconnection, spot networks, utility grid

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 12 September 2011. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6823-4 STD97173
Print: ISBN 978-0-7381-6824-1 STDPD97173

IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854-4141
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 1547.6-2011, IEEE Recommended Practice for Interconnecting Distributed Resources with Electric Power Systems Distribution Secondary Networks.

The IEEE 1547 series of standards was created to develop a national consensus on using distributed resources (DR) in electric power systems (EPSs). IEEE Std 1547-2003 provides mandatory requirements for the interconnection of DR with EPSs.^a It focuses primarily on radial feeder interconnections. For DR interconnected on networks, all of IEEE Std 1547-2003 needs to be satisfied.

IEEE Std 1547.6-2011 is part of the IEEE 1547 series of standards. IEEE Std 1547.6 provides recommendations and guidance for DR interconnected on EPS distribution secondary networks, including both spot networks and grid networks. IEEE Std 1547.6 was specifically developed to provide additional information in regard to interconnecting DR with distribution secondary networks. This document contains several clauses that address various aspects of DR interconnection with distribution secondary networks. Clause 1 provides an overview including the scope, purpose, and limitations of the document. Clause 2 provides normative references that must be understood and used with IEEE Std 1547.6, and Clause 3 lists definitions, acronyms, and abbreviations used in the document. Clause 4 identifies that IEEE Std 1547-2003 provides mandatory requirements for the interconnection of DR with EPSs. Clause 5 gives an overview of distribution secondary network systems design, components, and operation. Clause 6 describes considerations for interconnecting DR with networks. And Clause 7 provides potential solutions for the interconnection of DR on network distribution systems.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

^a Information on references can be found in Clause 2.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this recommended practice may require use of subject matter covered by patent rights. By publication of this recommended practice, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this recommended practice are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this recommended practice was submitted to the IEEE-SA Standards Board for approval, Standards Coordinating Committee 21 on Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage had the following membership:

Richard DeBlasio, Chair
Thomas S. Basso, Vice Chair & Secretary

David Bassett
John Bzura
James Daley
Douglas C. Dawson
Frank Goodman
Kelvin Hecht

Yiming Hou
Gerald Johnson
Joseph L. Koepfinger
Benjamin Kroposki
Peter McNutt
Thomas Prevost

Mary Reidy
Charles Rogers
Robert Saint
M. N. Satyanarayan
Mark Siira
Timothy Zgonena

At the time this recommended practice was submitted to the IEEE-SA Standards Board for approval, the IEEE P1547.6 Working Group had the following membership:

Joseph L. Koepfinger, Chair
John Bzura, Vice Chair
Thomas S. Basso, Co-Secretary
Michael Coddington, Co-Secretary

Jay Anderson
David Bassett
David Beach
David Bosack
James Cleary
Paul Collins
Stephen Conrad
James Daley
Marv Dartagz
Jeffrey Duff
Brian Escott
Andris Garsils
Sigifredo Gonzalez

Tom Gordon
Keith Harley
Patrick Healey
Taylor Hollis
Gerald Johnson
David Kelley
Connie Komomua
John Kueck
Jim Lemke
Scott Malinowski
Paul Mattes
C. Michael Miller

B. Zinn Morton
George Moskos
Daniel Mungovan
Robert Pellegrini
Janos Rajda
Dan Sammon
Colin Schauder
Mark Siira
Chase Sun
Chris Thompson
Sylvester Toe
Mohammad Vaziri
Charles Williams

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman
Marcelo Algrain
Curtis Ashton
Adam Bagby
John Banting
Thomas Barnes
G. Bartok
Earle Bascom, III
David Bassett
Thomas S. Basso
David Beach
Gabriel Benmouyal
Martin Best
Wallace Binder

Kenneth Birt
Thomas Blackburn
Oscar Bolado
David Bosack
Steven Brockschink
Chris Brooks
William Brumsickle
Gustavo Brunello
Jeffrey Burnworth
William Byrd
John Bzura
Peter J. Calderon
Michael Champagne
Arvind K. Chaudhary

Hari Preet Cheema
Keith Chow
James Cleary
Kurt Clemente
Frances Cleveland
Michael Coddington
Stephen Conrad
Terry Conrad
Garth Corey
Jerry Corkran
Randall Crellin
Randall Cunico
Matthew Davis
Kevin Donahoe

Carlo Donati
Gary Donner
Michael Dood
Randall Dotson
Neal Dowling
Michael Doyle
Donald Dunn
Ahmed Elneweih
Gary Engmann
Trishan Efram
Charles Finin
Rostyslaw Fostiak
Carl Fredericks
Fredric Friend
Andris Garsils
Frank Gerleve
Manjinder Gill
Mietek Glinkowski
Edwin Goodwin
J. T. Gordon
James Graham
Thomas Grebe
Stephen Grier
Randall Groves
Ajit Gwal
Jack Haggemiller
Donald Hall
Dennis Hansen
Edward Hare
Keith Harley
J. Harlow
David Harris
Jeffrey Hauber
John Hawkins
Steven Hensley
Lee Herron
Gary Heuston
Robert Hoerauf
Jerry Hohn
Philip Hopkinson
E. Horgan
David Horvath
R. Jackson
Gerald Johnson
Andrew Jones
Innocent Kamwa
Chad Kennedy
Gael Kennedy
John Kennedy
Yuri Khersonsky
Chad Kiger
Stanley Klein
Joseph L. Koepfinger
Boris Kogan

Jim Kulchisky
Saumen Kundu
Chung-Yiu Lam
Raluca Lascu
John Leach
Aleksandr Levin
Paul Lindemulder
Albert Livshitz
Linda Maepa
O. Malik
Wayne W. Manges
Omar Mazzoni
William McBride
Walter McCannon
John McDaniel
John McDonald
David McGinn
Hank McGlynn
Peter McNutt
Nigel McQuin
C. Michael Miller
Avygdor Moise
William Moncrief
George Moskos
Kimberly Mosley
David Mueller
Daniel Mulkey
Daniel Mungovan
Jerry Murphy
R. Murphy
Bruce Muschlitz
Anthony Napikoski
Dennis Neitzel
Michael S. Newman
David Nichols
Ted Olsen
Gregory Olson
Lorraine Padden
Donald Parker
Bansi Patel
M. Pehosh
Allan St. Peter
Dean Philips
Bruce Pickett
Alvaro Portillo
Lewis Powell
Robert Rallo
Michael Roberts
Robert Robinson
Charles Rogers
John Rossetti
Joseph R. Rostron
Marnie Roussel

Thomas Rozek
D. Daniel Sabin
Steven Sano
Bartien Sayogo
Colin Schauder
Robert Schuerger
Kenneth Sedziol
Douglas Seely
Robert Seitz
Gil Shultz
Tarlochan Sidhu
Cheong Siew
Mark Siira
Herbert Sinnock
James Smith
Jerry Smith
Aaron Snyder
Kwok Sum So
John Spare
David Stankes
Gary Stoedter
David Stone
Charles Sufana
Chase Sun
Peter Sutherland
Michael Swearingen
Richard Taylor
William Taylor
David Tepen
S. Thamilarasan
James Thompson
Kevin Thundiyil
Elisabeth Tobin
Sylvester Toe
Joe Uchiyama
Eric Udren
Timothy Unruh
Luis Vargas
Raul Velazquez
John Vergis
Marek Waclawiak
Carl Wall
Simon Wall
Reigh Walling
John Wang
Daniel Ward
Lee Welch
Kenneth White
Thomas Wiedman
John Wiles
Matthew Wilkowsky
James Wilson
John Wilson
Phil Winston

When the IEEE-SA Standards Board approved this recommended practice on 10 September 2011, it had the following membership:

Richard H. Hulett, *Chair*
John Kulick, *Vice Chair*
Robert M. Grow, *Past Chair*
Judith Gorman, *Secretary*

Masayuki Ariyoshi
William Bartley
Ted Burse
Clint Chaplin
Wael Diab
Jean-Philippe Faure
Alexander Gelman
Paul Houzé

Jim Hughes
Joseph L. Koepfinger*
David J. Law
Thomas Lee
Hung Ling
Oleg Logvinov
Ted Olsen

Gary Robinson
Jon Walter Rosdahl
Sam Sciacca
Mike Seavey
Curtis Siller
Phil Winston
Howard L. Wolfman
Don Wright

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Don Messina
IEEE Standards Program Manager, Document Development

Soo H. Kim
IEEE Standards Project Manager

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
1.3 Limitations	2
2. Normative references	2
3. Definitions, acronyms, and abbreviations	3
3.1 Definitions	3
3.2 Acronyms and abbreviations	4
4. Existing requirements for the interconnection of distributed resources with networks	5
5. Overview of distribution secondary network systems: design, components, and operation	5
5.1 Background	5
5.2 Network transformers	6
5.3 Spot networks	6
5.4 Secondary grid networks	8
5.5 Operation	10
6. Considerations for interconnecting DR with networks	11
6.1 Introduction	11
6.2 Network protectors	11
6.3 Protection and controls	12
6.4 System planning and reliability considerations	14
6.5 Work practices	16
6.6 Maintenance	16
7. Potential solutions for the interconnection of DR on network distribution systems	16
7.1 Overview of distributed resource characteristics	16
7.2 The <i>de minimus</i> interconnection concept: definition and examples	18
7.3 A concept of limiting DR output relative to facility load	20
7.4 Implementation of reverse-power control measures	21
7.5 Interconnection via combinations of control measures	22
Annex A (informative) Bibliography	25
Annex B (informative) Glossary	26

IEEE Recommended Practice for Interconnecting Distributed Resources with Electric Power Systems Distribution Secondary Networks

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This standard builds upon IEEE Std 1547TM-2003 for the interconnection of distributed resources (DR) to distribution secondary network systems.¹ This standard establishes recommended criteria, requirements, and tests, and provides guidance for interconnection of distribution secondary network system types of area electric power systems (area EPS) with DR providing electric power generation in local electric power systems (local EPS).

1.2 Purpose

This recommended practice focuses on the technical issues associated with the interconnection of area EPS distribution secondary networks with a local EPS having DR generation. The document provides

¹ Information on references can be found in Clause 2.

recommendations relevant to the performance, operation, testing, safety considerations, and maintenance of the interconnection. In this recommended practice consideration is given to the needs of the local EPS to be able to provide enhanced service to the DR owner loads as well as to other loads served by the network. Equally, the recommended practice addresses the technical concerns and issues of the area EPS. Further, this document identifies communication and control recommendations and provides guidance on considerations that will have to be addressed for such DR interconnections.

1.3 Limitations

The recommendations in this document are not mandatory requirements. Further, the recommendations are intended to be compatible with other IEEE-related guides and recommended practices to the extent possible. These recommended practices also may not cover all locations or all operating conditions. Therefore, following the recommended practices herein does not assure that any specific DR interconnection is feasible at any specific location.

- This document applies to the interconnection of DR with an area EPS secondary network on the load side of the network protector (NP). This recommended practice presents interconnection concepts that are not binding to any area EPS operator to accept or implement.
- This recommended practice does not presume that an area EPS operator will permit DR interconnection on the local EPS side of the point of common coupling (PCC).
- This recommended practice does not presume that an area EPS operator will make any adjustments to the operation of its NPs to facilitate the operation of DR within the network.
- This recommended practice does not address protection of the customer's interconnected DR.
- A delta-wye network transformer is the basis for this document. Some of the statements may not be suitable for a wye-wye transformation.
- This recommended practice applies to distribution secondary network systems with operating voltage 1000 V and less, between any two conductors, or between a conductor and ground.
- The topics not specifically covered in this issue of the recommended practice are deferred for discussion and development in future revisions of this document.

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

IEEE Std 1547TM-2003 (Reaff 2008), IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.^{2, 3}

IEEE Std 1547.1TM-2005, IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.

IEEE Std 1547.2TM-2008, IEEE Application Guide for IEEE Std 1547TM, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.

² IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854-4141, USA (<http://standards.ieee.org>).

³ The IEEE standards or products referred to in Clause 2 are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.