

IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems

IEEE Standards Coordinating Committee 21

Sponsored by the

**IEEE Standards Coordinating Committee 21 on
Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage**

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std 1547.4™-2011

20 July 2011

IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems

Sponsor

**IEEE Standards Coordinating Committee 21 on
Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage**

Approved 16 June 2011

IEEE-SA Standards Board

Abstract: Alternative approaches and good practices for the design, operation, and integration of distributed resource (DR) island systems with electric power systems (EPS) are provided. This includes the ability to separate from and reconnect to part of the area EPS while providing power to the islanded EPSs. This guide includes the DRs, interconnection systems, and participating EPSs.

Keywords: circuit island, distributed resources, DR island systems, electric power systems, IEEE 1547.4, intentional island, interconnection, lateral island, microgrid, secondary island, substation bus island

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2011 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 20 July 2011. Printed in the United States of America.
2nd Printing 29 July 2011. SCC 21 Participants added on page vi of the Frontmatter.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code, NEC, and NFPA 70 are registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association.

PDF: ISBN 978-0-7381-6688-9 STD97119
Print: ISBN 978-0-7381-6670-4 STDPD97119

IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854-4141
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std 1547.4-2011, IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems.

IEEE Std 1547.4 is part of the IEEE 1547™ series of standards. The IEEE 1547 series of standards was created to develop a national consensus on using distributed resources (DR) in electric power systems (EPSs). IEEE Std 1547.4 was specifically developed to address the lack of information included in IEEE Std 1547-2003 regarding intentional islands.^a This document covers intentional islands in electric power systems (EPSs) that contain DRs. IEEE created a new term *DR island systems* to generically refer to all intentional island systems that could include local and/or area EPS. The term DR island systems, sometimes referred to as *microgrids*, is used for these intentional islands. DR island systems are EPSs that: (1) have DR and load, (2) have the ability to disconnect from and parallel with the area EPS, (3) include the local EPS and may include portions of the area EPS, and (4) are intentionally planned. DR island systems can be either local EPS islands or area EPS islands.

DR island systems offer many potential benefits. They can:

- Improve reliability by providing the islanded portion of the EPS power during an area EPS outage or disturbance.
- Relieve area EPS overload problems by allowing a part of the EPS to intentionally island and removing load from the rest of the area EPS. The benefit is for both island and normal parallel operation.
- Isolate from area EPS power quality issues (voltage distortion, voltage sag, flicker, lightning transients, etc.) while in island mode operation.
- Resolve power-quality issues by reducing total harmonic distortion (THD) at the loads.
- Allow for maintenance on the area EPS while allowing intentionally islanded customers to remain powered.

This document contains several clauses that address various aspects of DR island systems. Clause 3 gives a list of definitions and acronyms used in the document. Clause 4 gives an overview of the general considerations for design and operation of DR island systems and describes the various types of DR island systems. This clause also discusses the modes of operation of the DR island systems, including normal parallel mode, transition-to-island mode, island mode, and reconnection mode. Clause 5 explains the planning and engineering of DR island systems with detailed discussions about the considerations and solutions. Clause 6 describes the operations of the DR island system.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this guide does not imply compliance to any applicable regulatory requirements. Implementers of the guide are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

^a Information on references can be found in Clause 2.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this guide may require use of subject matter covered by patent rights. By publication of this guide, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this guide are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this guide was submitted to the IEEE-SA Standards Board for approval, Standards Coordinating Committee 21 on Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage had the following membership:

Richard DeBlasio, *Chair*
Thomas S. Basso, *Vice Chair & Secretary*

David Bassett	Yiming Hou	Mary Reidy
John Bzura	Gerald Johnson	Charles Rogers
James Daley	Joseph L. Koepfinger	Robert Saint
Douglas C. Dawson	Benjamin Kroposki	M. N. Satyanarayan
Frank Goodman	Peter McNutt	Mark Siira
Kelvin Hecht	Thomas Prevost	Timothy Zgonena

At the time this guide was submitted to the IEEE-SA Standards Board for approval, the IEEE P1547.4 Working Group had the following membership:

Benjamin Kroposki, *Chair*
Thomas S. Basso, *Vice Chair*

Chad Abbey	Sigifredo Gonzalez	Daniel Sammon
Narang Arun	Joshua Hambrick	Colin Schauder
David Bassett	Keith Harley	Paul Sheaffer
David Beach	Gerald Johnson	Mark Siira
Robin Blanton	Travis Johnson	Glenn Skutt
David Bosack	Joseph L. Koepfinger	Mischa Steurer
Michael Coddington	Keith Malmedal	Chase Sun
Terry Conrad	Anthony Mazy	Siddharth Suryanarayanan
James Daley	David Nichols	Sylvester Toe
Jeff Duff	Gregory Obenchain	Mohammad Vaziri
Steve Fredette	Gary Olson	Simon Wall
John Gajda	Charles Rogers	Charles Watson
Andris Garsils	Michael Ropp	Charles Williams
	Robert Saint	

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman	William Bush	Matthew Davis
Satish K. Aggarwal	William Byrd	Kevin Donahoe
Marcelo Algrain	John Bzura	Carlo Donati
Ali Al Awazi	Shawn Catoe	Gary Donner
John Banting	Suresh Channarasappa	Michael Dood
David Bassett	Arvind K. Chaudhary	Neal Dowling
Thomas S. Basso	Keith Chow	Michael Doyle
David Beach	James Cleary	Richard Doyle
Kenneth Behrendt	Kurt Clemente	Dana Duffield
Greg Bernstein	Frances Cleveland	Gearold O. H. Eidhin
Wallace Binder	Michael Coddington	Ahmed Elneweih
Kenneth Birt	Stephen Conrad	Gary Engmann
Sara Biyabani	Terry Conrad	Rostyslaw Fostiak
Robin Blanton	Charles Cook	M. Freeman
Mark Bowman	Michael Coop	Fredric Friend
Steven Brockschink	Garth Corey	James Frysinger
Chris Brooks	Luis Coronado	Andris Garsils
Gustavo Brunello	Randall Crellin	William R. Godwin
Jeffrey Burnworth	Alireza Daneshpooy	Luz Carmen Manzano Gomez

Edwin Goodwin
J. T. Gordon
James Graham
Stephen Grier
Randall Groves
Donald Hall
Joshua Hambrick
Dennis Hansen
John Harauz
Edward Hare
Keith Harley
J. Harlow
David Harris
David Haynes
Roger Hedding
Michael Henry
Steven Hensley
Lee Herron
Gary Heuston
Robert Hoerauf
Jerry Hohn
David Horvath
John Houdek
Hakan Inan
R. Jackson
Junghoon Jee
Charles Jensen
Liang Ji
Gerald Johnson
Innocent Kamwa
Gael Kennedy
John Kennedy
Yuri Khersonsky
Morteza Khodaie
James Kinney
Stanley Klein
Joseph L. Koepfinger
Boris Kogan
Benjamin Kroposki
John Kueck
Jim Kulchisky
Saumen Kundu
Chung-Yiu Lam
Paul Lambert
Raluca Lascu
John Leach
Albert Livshitz
Greg Luri

O. Malik
Wayne W. Manges
Omar Mazzoni
John McDonald
Hank McGlynn
Peter McNutt
C. Michael Miller
Jeffery Mizener
Daleep Mohla
Avygdor Moise
William Moncrief
Jose Morales
Anne Morgan
Kimberly Mosley
Daniel Mulkey
Daniel Mungovan
Jerry Murphy
Bruce Muschlitz
Anthony Napikoski
Paul Nauert
Bradley Nelson
Rhonda Netzel
Michael S. Newman
David Nichols
Joe Nims
Chukwuemeka Okafor
T. Olsen
Gregory Olson
Lorraine Padden
Marty Page
Bansi Patel
M. Pehosh
Christopher Petrola
Robert Pettigrew
Louis Pinto
Alvaro Portillo
Iulian Profir
Robert Rallo
John Roach
Michael Roberts
George Robinson
Charles Rogers
Ken Romano
Michael Ropp
William Rose
D. Daniel Sabin
Sukhbir Sachdev
Robert Saint
Steven Sano

Bartien Sayogo
Colin Schauder
Robert Schuenger
Tony Seegers
Douglas Seely
Robert Seitz
Gil Shultz
Cheong Siew
Mark Siira
Hyeong Sim
Herbert Sinnock
James Smith
Jerry Smith
Aaron Snyder
John Spare
Gary Stoedter
David Stone
Charles Sufana
Chase Sun
Richard Taylor
William Taylor
John Tengdin
David Tepen
Tod Tesch
S. Thamilarasan
Elisabeth Tobin
Sylvester Toe
John Toth
Demetrios Tziouvaras
Joe Uchiyama
Eric Udren
Luis Vargas
John Vergis
Jane Verner
Carl Wall
Simon Wall
Reigh Walling
Joseph Weiss
Lee Welch
Randall West
Kenneth White
Thomas Wier
Matthew Wilkowski
Charles Williams
James Wilson
Paul Work
John Yale
Richard Young

When the IEEE-SA Standards Board approved this guide on 16 June 2011, it had the following membership:

Richard H. Hulett, *Chair*
John Kulick, *Vice Chair*
Robert M. Grow, *Past Chair*
Judith Gorman, *Secretary*

Masayuki Ariyoshi
William Bartley
Ted Burse
Clint Chaplin
Wael Diab
Jean-Philippe Faure
Alexander Gelman
Paul Houz 

Jim Hughes
Joseph L. Koepfinger*
David J. Law
Thomas Lee
Hung Ling
Oleg Logvinov
Ted Olsen

Gary Robinson
Jon Walter Rosdahl
Sam Sciacca
Mike Seavey
Curtis Siller
Phil Winston
Howard L. Wolfman
Don Wright

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Don Messina
IEEE Standards Program Manager, Document Development

Soo Kim
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	2
1.3 Limitations	2
2. Normative references	2
3. Definitions, acronyms, and abbreviations	3
3.1 Definitions	3
3.2 Acronyms and abbreviations	4
4. DR island systems overview	5
4.1 General DR island system considerations	5
4.2 Specific considerations for DR island systems that include a portion of the area EPS	6
4.3 DR island system configurations	6
4.4 Functionality of the DR island system	13
5. Planning and engineering of DR island systems	15
5.1 Load requirements and planning	16
5.2 EPS requirements and planning	19
5.3 DR requirements and planning	26
5.4 System studies	30
5.5 Motor starting studies	36
5.6 Additional planning considerations	36
5.7 Testing and commissioning	36
6. Operation of DR island systems	36
6.1 DR island system management	36
6.2 DR island system transitions	37
6.3 Control strategies of DR island systems	38
6.4 Restoration after disturbances	38
6.5 Safety considerations	38
6.6 Periodic review, maintenance, and testing	38
6.7 Protection consideration	39
6.8 Monitoring, information exchange, and control	39
6.9 Power quality	39
Annex A (informative) Bibliography	40
Annex B (informative) Contractual and regulatory considerations that need to be addressed for DR island systems	41
Annex C (informative) Glossary	42

IEEE Guide for Design, Operation, and Integration of Distributed Resource Island Systems with Electric Power Systems

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

This document covers intentional islands in electric power systems (EPSs) that contain distributed resources (DRs). The term *DR island systems*, sometimes referred to as *microgrids*, is used for these intentional islands. DR island systems are EPSs that: (1) have DR and load, (2) have the ability to disconnect from and parallel with the area EPS, (3) include the local EPS and may include portions of the area EPS, and (4) are intentionally planned. DR island systems can be either local EPS islands or area EPS islands. This document addresses issues associated with DR island systems on both local and area islanded EPSs. It provides an introduction and overview and addresses engineering concerns related to DR island systems.

1.1 Scope

This document provides alternative approaches and good practices for the design, operation, and integration of DR island systems with EPS. This includes the ability to separate from and reconnect to part of the area EPS while providing power to the islanded EPSs. This guide includes the DRs, interconnection systems, and participating EPSs.

1.2 Purpose

This guide is intended to be used by EPS designers, operators, system integrators, and equipment manufacturers. The document is intended to provide an introductory overview and address engineering concerns of DR island systems. It is relevant to the design, operation, and integration of DR island systems. Implementation of this guide will expand the benefits of using DR by targeting improved reliability and build upon the interconnection requirements of IEEE Std 1547TM-2008.¹

1.3 Limitations

This document also has the following limitation to its use:

- This guide does not establish DR reserve levels for a specific planned island.
- This guide does not address DR island systems on distribution secondary networks.
- The aggregate generating capacity within the DR island system is not restricted by this document.
- Each individual point of common coupling (PCC) is limited to 10 MVA of generation (per IEEE Std 1547-2003).
- This guide does not presume that an area EPS operator desires to establish planned islands on any portion of the area EPS that is normally connected to the balance of the area EPS.
- This guide does not presume that all DR located within an area EPS operator's planned island are participating.
- This guide does not presume that all load located within an area EPS operator's planned island are participating.
- This guide does not provide operational procedures for establishing and operating a planned island.
- This guide does not cover all possible contingencies (e.g., loss of control communications back to the area EPS) that may result in the cessation of planned island operations.
- This guide does not address physical security or cybersecurity.
- This guide does not cover contractual or regulatory considerations.
- This guide does not cover metering, which may be a contractual or regulatory consideration.

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

ANSI/NEMA C84.1-2006, American National Standard for Electric Power Systems and Equipment—Voltage Ratings (60 Hertz).^{2, 3}

ANSI/NEMA MG 1-2006, Motors and Generators.

¹ Information on references can be found in Clause 2.

² ANSI publications are available from the Customer Service Department, American National Standards Institute, 25 W. 43rd Street, 4th Floor, New York, NY 10036, USA (<http://www.ansi.org/>).

³ NEMA publications are available from Global Engineering Documents, 15 Inverness Way East, Englewood, Colorado 80112, USA (<http://global.ihs.com/>).

IEEE Std 399™-1997, IEEE Recommended Practice for Industrial and Commercial Power Systems Analysis (*IEEE Brown Book™*).^{4, 5}

IEEE Std 446™, IEEE Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications (*IEEE Orange Book™*).

IEEE Std 519™, IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems.

IEEE Std 1100™, IEEE Recommended Practice for Powering and Grounding Electronic Equipment (*IEEE Emerald Book™*).

IEEE Std 1547™-2003 (Reaff 2008), IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.

IEEE Std 1547.2™, IEEE Application Guide for IEEE Std 1547™ Interconnecting Distributed Resources with Electric Power Systems.

IEEE Std 1547.3™-2007, IEEE Guide for Monitoring, Information Exchange, and Control of Distributed Resources Interconnected with Electric Power Systems.

3. Definitions, acronyms, and abbreviations

3.1 Definitions

For the purposes of this document, the following terms and definitions apply. *The IEEE Standards Dictionary: Glossary of Terms & Definitions* should be referenced for terms not defined in this clause.⁶

black start: The ability to start local generation with no external source of power.

distributed resources (DR): Sources of electric power that are not directly connected to a bulk power transmission system. DR includes both generators and energy storage technologies.

distributed resources (DR) island system: DR island systems are parts of electric power systems (EPSs) that have DR and load, have the ability to disconnect from and parallel with the EPS, include the local EPS and may include portions of the area EPS, and are intentional and planned.

NOTE—Types of DR island systems include: local EPS island (facility island); circuit lateral island; distribution circuit island; substation bus island; substation island; adjacent circuit island.⁷

distribution system: That portion of an electric system that delivers electric energy from transformation points on the transmission or bulk power system to consumers.

⁴ IEEE publications are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854-4141, USA (<http://standards.ieee.org>).

⁵ The IEEE standards or products referred to in Clause 2 are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.

⁶ *The IEEE Standards Dictionary: Glossary of Terms & Definitions* is available at <http://shop.ieee.org/>.

⁷ Notes in text, tables, and figures of a standard are given for information only and do not contain requirements needed to implement this standard.