



*NSF International Standard /
American National Standard*

NSF/ANSI 42 - 2010

Drinking Water Treatment Units -
Aesthetic Effects



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

This Standard is subject to revision.
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units
c/o NSF International
789 North Dixboro Road, P. O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
FAX: (734) 769-0109
E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF International Standard/
American National Standard
for Drinking Water Treatment Units –

**Drinking water treatment units –
Aesthetic effects**

Standard Developer

NSF International

NSF International

Designated as an ANSI Standard

February 19, 2011

American National Standards Institute

Prepared by
The NSF Joint Committee on Drinking Water Treatment Units

Recommended for adoption by
The NSF Council of Public Health Consultants

Adopted by
The NSF Board of Directors
March 1973

Revised June 1982
Revised June 1988
Revised September 1996
Revised September 1997
Revised November 1998
Revised September 1999
Revised July 2000
Revised November 2000
Revised January 2001
Revised January 2002
 Addendum 1.0 – June 2002
 Addendum 2.0 – October 2002
 Editorial revision, November 2003
 Addendum 1.0 – August 2004

Revised April 2005
 Editorial revision, June 2005
Revised July 2007
Revised October 2007
 Addendum – March 2008
Revised August 2009
Revised February 2011

Published by

NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation “NSF/ANSI 42 – 2010.”

Copyright 2011 NSF International
Previous editions © 2009, 2008, 2007, 2005, 2004, 2002, 2001, 2000, 1999, 1998, 1997, 1996, 1988, 1982, 1973

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

Contents

1	General	1
1.1	Purpose	1
1.2	Scope	1
1.3	Alternate materials, designs, and construction	1
1.4	Chemical and mechanical reduction performance claims	1
1.5	Minimum requirements	2
2	Normative references	2
3	Definitions	3
4	Materials	6
4.1	Materials in contact with drinking water	6
4.2	Materials evaluation	7
4.3	Gas chromatography/mass spectroscopy (GC/MS) analysis	8
	Table 1 – Extraction testing parameters	9
	Table 2 – Formulation dependent extraction testing parameters	11
	Table 3 – Materials listed in U. S. Code of Federal Regulations, Table 4 – Non-specific extraction testing parameters	14
5	Structural performance	14
5.1	Structural integrity	14
5.2	Acceptance	14
5.3	Working pressure	15
5.4	Structural integrity test methods	15
	Table 5 – Structural integrity testing requirements	19
6	Minimum performance requirements	20
6.1	Elements	20
6.2	Waste connections	20
6.3	Product water dispensing outlets	20
6.4	Hazards	21
6.5	Operation temperature	21
6.6	Electrical safety and operation	21
6.7	Rated service flow	21
6.8	POE rated pressure drop	21
6.9	Minimum service flow	21
	Table 6 – Minimum service flow	22
6.10	Active agents and additives	22
6.11	Media	23
7	Elective performance claims – test methods	24
7.1	General requirements	24
7.2	Bacteriological performance	26
7.3	Chemical reduction testing	27
	Table 7 – Chemical reduction requirements	28
	Table 8 – Chloramine reduction requirements	30
	Table 9 – Chlorine reduction	34
	Table 10 – Hydrogen sulfide and phenol reduction requirements	36
	Table 11 – Iron and manganese reduction requirements	38
	Table 12 – pH adjustment requirements	40
	Table 13 – Zinc reduction requirements	42
7.4	Mechanical reduction testing	44
	Table 14 – Nominal particulate reduction (85%) classes	44

Table 15 – Test dust specifications for nominal particulate reduction (85%)	45
7.5 Scale control testing.....	46
Table 16 – Additives intended for scale control	47
8 Instruction and information	48
8.1 Installation, operation, and maintenance instruction.....	48
8.2 Data plate.....	49
8.3 Replacement components	50
8.4 Performance data sheet.....	51
Table 17 – Performance data sheet reduction claims	53
Table 18 – Performance data sheet reduction claims	53
Annex A	A1
A.1 Marking the product	A1
A.2 Listing certified companies.....	A1
A.3 Annual audits	A1
A.4 Testing	A2
A.5 Toxicological evaluation of materials formulations	A2
A.6 Corrective action	A2
A.7 Enforcement.....	A2
A.8 Administrative review	A2
A.9 Appeals	A2
A.10 Complaints.....	A3
A.11 Advertising.....	A3
A.12 Records	A3
A.13 Public notice	A3
A.14 Confidentiality.....	A3
Annex B	B1
B.1 Summary of method.....	B1
B.2 Equipment and materials	B1
B.3 Reagents and consumable materials.....	B1
B.4 Safety	B3
B.5 Procedure.....	B4
B.6 Data analysis.....	B4
B.7 Quality control	B4
B.8 References.....	B6

Foreword²

The purpose of this Standard is to establish minimum requirements for materials, design, construction, and performance of drinking water treatment units that are designed to reduce specific aesthetic-related contaminants in public or private water supplies. This Standard specifies the minimum product literature and labeling information that a manufacturer must supply to authorized representatives and system owners. Lastly, the Standard provides minimum service-related obligations that the manufacturer must extend to system owners.

This edition of the Standard contains the following revisions:

Issue 67

This revision corrected an error that occurred during the reformatting of NSF/ANSI 42. The following note was deleted from tables 7.3.1.5.1, 7.3.6.6.1, & 7.3.4.6.1:

NOTE – If precipitation of heavy metals occurs, deionized water shall be substituted for the public water supply, magnesium or calcium salts shall be added to provide the desired TDS, the TOC requirements shall be waived, and the pH requirement shall be modified accordingly.

Issue 68

This revision clarified the rated service flow requirement in 6.7 by not allowing a rated service flow to be greater than the required minimum service flow.

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units, c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

NSF/ANSI Standard for Drinking Water Treatment Units –

Drinking water treatment units – Aesthetic effects

1 General

1.1 Purpose

It is the purpose of this Standard to establish minimum requirements for materials, design and construction, and performance of drinking water treatment systems that are designed to reduce specific aesthetic-related (non-health effects) contaminants in public or private water supplies. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners as well as the minimum service-related obligations that the manufacturer shall extend to system owners.

1.2 Scope

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private) considered to be microbiologically safe and of known quality. Systems covered under this Standard are intended to reduce substances affecting the aesthetic quality of the water or to add chemicals for scale control, or both. Substances may be soluble or particulate in nature at concentrations influencing public acceptance of the drinking water. It is recognized that a system may be effective in controlling one or more of these substances but is not required to control all. Systems with components or functions covered under other NSF or NSF/ANSI standards or criteria shall conform to the applicable requirements therein.

1.3 Alternate materials, designs, and construction

While specific materials, designs, and construction may be stipulated in this Standard, systems that incorporate alternate materials, designs, and construction may be acceptable when it is verified that such systems meet the applicable requirements stated herein.

1.4 Chemical and mechanical reduction performance claims

1.4.1 All NSF/ANSI 42 performance claims shall be verified and substantiated by test data generated under the requirements of NSF/ANSI 42.

1.4.2 When performance claims are made for substances not specifically addressed in the scope of this Standard or for substances not specifically addressed but falling under the scope of NSF/ANSI 42, such claims shall be identified as not specifically addressed in the Standard.