



*NSF International Standard /
American National Standard*

NSF/ANSI 350 - 2011

Onsite Residential and Commercial
Water Reuse Treatment Systems



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

*This Standard is subject to revision.
Contact NSF to confirm this revision is current.*

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Wastewater Technology
c/o NSF International
789 North Dixboro Road, P.O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010
Telex: 753215 NSF INTL
FAX: (734) 769-0109
E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF International Standard/
American National Standard
for Wastewater Technology —

Onsite residential and commercial Water reuse treatment systems

Standard Developer

NSF International

Designated as an ANSI Standard

July 18, 2011

American National Standards Institute

Prepared by
The NSF Joint Committee on Wastewater Technology

Recommended for Adoption by
The NSF Council of Public Health Consultants

Adopted
July 2011

Published by

NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation “NSF/ANSI 350 – 2011.”

Copyright 2011 NSF International

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirement.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally blank.

Contents

1	General	1
1.1	Purpose	1
1.2	Scope	1
1.3	Alternate materials, design, and construction	2
1.4	Performance classification	2
2	References	3
2.1	Normative references	3
2.2	Abbreviations	4
3	Definitions	4
4	Materials	5
4.1	Interior surfaces	5
4.2	Exterior surfaces	5
4.3	Welding	6
4.4	Dissimilar metals	6
5	Design and construction	6
5.1	Exposed surfaces	6
5.2	Structural integrity	6
5.3	Water tightness	6
5.4	Noise	6
5.5	Mechanical components	7
5.6	Electrical components	7
5.7	Access ports	7
5.8	Failure sensing and signaling equipment	7
5.9	Flow design	8
5.10	Dataplate and service label	8
6	Product literature	9
6.1	Owner's manual	9
6.2	Additional product literature	10
7	Other documentation	11
8	Performance testing and evaluation	11
8.1	Graywater treatment systems with capacities up to 5,678 L/day (1,500 gal/day)	11
8.2	Residential wastewater treatment systems with capacities up to 5,678 L/day (1,500 gal/day)	18
8.3	Commercial treatment systems with combined wastewater flows and commercial facility laundry water of any capacity, and graywater capacities exceeding 5,678 L/day (1,500 gal/day)	20
8.4	Sample collection	20
8.5	Analyses (applicable to all reuse systems evaluated in accordance with 8.1, 8.2 and 8.3)	22
8.6	Criteria (applicable to all reuse systems evaluated in accordance with 8.1, 8.2 and 8.3)	23
9	Final report	26
Annex A	A1
A.1	General description	A1
A.2	Test plan	A1
A.3	Quality assurance / quality control	A4
A.4	Statistical evaluation of data	A7
A.5	Reporting	A7

Annex B	B1
B.1 Purpose	B1
B.2 Manufacturer's requirements	B1
B.3 Owner's requirements	B1
B.4 Service provider's qualifications	B1
B.5 Service contract provisions	B2
B.6 Regulatory provisions	B2
Annex C	C1
Annex D	D1
Annex E	E1

Foreword²

This American National Standard, NSF/ANSI 350 Onsite residential and commercial water reuse treatment systems Standard, has been developed as part of the ongoing efforts of interested parties to establish minimum material, design and construction, and performance requirements for onsite residential and commercial water treatment systems. This standard also specifies the minimum literature that manufacturers shall supply to authorized representatives and owners as well as the minimum service-related obligations that a manufacturer shall extend to owners. The standard is intended to address public health and environmental issues. Actual performance for any site or system may vary, depending on variations in raw water supply (such as in alkalinity and hardness), graywater constituents, and patterns of use. The end use of the effluent is the responsibility of the owner, design professionals, and regulatory officials.

Management methods and end uses appropriate for the treated effluent discharged from onsite residential and commercial treatment systems meeting Class R (single family residential) or Class C (multi-family and commercial facilities) requirements of this Standard include indoor restricted urban water use, such as toilet and urinal flushing, and outdoor unrestricted urban water use, such as surface irrigation.

Systems may include:

- Graywater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day): This applies to onsite residential and commercial treatment systems that treat graywater, those that treat laundry water from residential laundry facilities, and those that treat bathing water.
- Residential wastewater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day). This applies to onsite residential treatment systems that treat combined wastewater generated by the occupants of residence(s). A reuse system treating 1,514 L/day (400 gal/day) to 5,678 L/day (1,500 gal/day) shall either be demonstrated to have met the Class I requirements of NSF/ANSI 40 Residential wastewater treatment systems, or shall meet these requirements during concurrent testing to this Standard. A treatment system treating less than 1,514 L/day (400 gal/day) shall not be required to have met the Class I requirements of NSF/ANSI 40.
- Commercial treatment systems: This applies to onsite commercial treatment systems that treat combined commercial facility wastewater and commercial facility laundry water of any capacity, and those treatment systems that treat graywater from commercial facilities with capacities exceeding 5,678 L/day (1,500 gal/day). These systems shall be performance tested and evaluated at the location of the reuse system installation, using the wastewater generated onsite from the facility serving the treatment system. See 8.3 for performance testing and evaluation. The key elements of a field evaluation of a commercial onsite treatment system are described in Annex A.

This Standard was developed by the NSF Joint Committee on Wastewater Technology using the consensus process described in the American National Standards Institute.

Suggestions for improvements of this Standard are welcome. Comments should be sent to Chair, Joint Committee on Wastewater Technology, c/o NSF International, Standards Department, PO Box 130140, Ann Arbor, Michigan 48113-0140, USA.

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally blank.

NSF/ANSI Standard
for Wastewater Treatment Systems —

Onsite residential and commercial water reuse treatment systems

1 General

1.1 Purpose

The purpose of this Standard is to establish minimum material, design and construction, and performance requirements for onsite residential and commercial water treatment systems. This standard also specifies the minimum literature that manufacturers shall supply to authorized representatives and owners as well as the minimum service-related obligations that a manufacturer shall extend to owners.

1.2 Scope

This Standard contains minimum requirements for onsite residential and commercial water treatment systems. Systems may include:

- Graywater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day). This applies to onsite residential and commercial treatment systems that treat graywater, those that treat laundry water from residential laundry facilities, and those that treat bathing water. See 8.1 for performance testing and evaluation.
- Residential wastewater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day). This applies to onsite residential treatment systems that treat combined wastewater generated by the occupants of residence(s). A reuse system treating 1,514 L/day (400 gal/day) to 5,678 L/day (1,500 gal/day) shall either be demonstrated to have met the Class I requirements of NSF/ANSI 40, or must meet these requirements during concurrent testing to this Standard. A treatment system treating less than 1,514 L/day (400 gal/day) is not required to have met the Class I requirements of NSF/ANSI 40. See 8.2 for performance testing and evaluation.
- Commercial treatment systems: This applies to onsite commercial treatment systems that treat combined commercial facility wastewater and commercial facility laundry water of any capacity, and those treatment systems that treat graywater from commercial facilities with capacities exceeding 5,678 L/day (1,500 gal/day). These systems shall be performance tested and evaluated at the location of the reuse system installation, using the wastewater generated onsite from the facility serving the treatment system. See 8.3 for performance testing and evaluation. The key elements of a field evaluation of a commercial onsite treatment system are described in Annex A.

Management methods and end uses appropriate for the treated effluent discharged from onsite residential and commercial treatment systems meeting Class R (single family residential) or Class C (multi-family and commercial facilities) requirements of this Standard include indoor restricted urban water use, such as toilet and urinal flushing, and outdoor unrestricted urban water use, such as surface irrigation. Effluent quality criteria consistent with these uses are described in 8.6, Criteria.