



*NSF International Standard /  
American National Standard*

## **NSF/ANSI 53 - 2011**

**Drinking Water Treatment Units -  
Health Effects**



*NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.*

This Standard is subject to revision.  
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Drinking Water Treatment Units  
c/o NSF International  
789 North Dixboro Road, P. O. Box 130140  
Ann Arbor, MI 48113-0140, USA  
Phone: (734) 769-8010 Telex: 753215 NSF INTL  
FAX: (734) 769-0109  
E-mail: [info@nsf.org](mailto:info@nsf.org)  
Web: <http://www.nsf.org>

NSF International Standard/  
American National Standard  
for Drinking Water Treatment Units —

**Drinking water treatment units –  
Health effects**

Standard Developer  
NSF International

**NSF International Board of Directors**

**Designated as an ANSI Standard**  
April 20, 2011

**American National Standards Institute**

Prepared by  
**The NSF Joint Committee on Drinking Water Treatment Units**

Recommended for adoption by  
**The NSF Council of Public Health Consultants**

Adopted by  
**The NSF Board of Directors**  
December 1981

Revised June 1982  
Revised June 1988  
Revised May 1990  
Revised November 1992  
Revised September 1993  
Revised March 1994  
Revised March 1996  
Revised September 1996  
Revised September 1997  
Revised November 1998  
Revised March 1999  
Revised September 1999  
Revised May 2000  
Revised November 2000  
Revised January 2001

Revised January 2002  
Addendum 1.0 – 2002, June 2002  
Addendum 2.0 – 2002, October 2002  
Editorial Revision – November 2003  
Revised July 2004  
Addendum 1.0 – 2002e, August 2004  
Revised February 2005  
Revised January 2006  
Addendum 1.0 – 2006, March 2006  
Revised February 2007  
Revised July 2007  
Addendum 1.0 – 2007, March 2008  
Revised August 2009  
Revised August 2010  
Revised April 2011

Published by

NSF International  
P. O. Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation “NSF/ANSI 53 – 2011.”

Copyright 2011 NSF International

Previous editions © 2009, 2008, 2007, 2006, 2005, 2004, 2002, 2001, 2000, 1998, 1997, 1996, 1994, 1993, 1992, 1990, 1988, 1982, 1981

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

## Disclaimers<sup>1</sup>

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

---

<sup>1</sup> The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

## Contents

|      |  |    |
|------|--|----|
| 1    | General  | 1  |
| 1.1  | Purpose  | 1  |
| 1.2  | Scope  | 1  |
| 1.3  | Minimum requirements   | 1  |
| 1.4  | Chemical and mechanical reduction performance claims   | 2  |
| 1.5  | Standard review  | 2  |
| 2    | Normative references   | 2  |
| 3    | Definitions  | 3  |
| 4    | Materials  | 7  |
| 4.1  | Materials in contact with drinking water   | 7  |
| 4.2  | Materials evaluation   | 7  |
| 4.3  | Gas chromatography/mass spectroscopy (GC/MS) analysis  | 8  |
|      | Table 1 – Extraction testing parameters  | 10 |
|      | Table 2 – Formulation dependent extraction testing parameters  | 12 |
|      | Table 3 – Materials listed in U. S. Code of Federal Regulations, Title 21,<br>not requiring formulation review | 14 |
|      | Table 4 – Non-specific extraction testing parameters   | 15 |
| 5    | Structural performance   | 15 |
| 5.1  | Structural integrity   | 15 |
|      | Table 5 – Structural integrity testing requirements  | 16 |
| 6    | Minimum performance requirements   | 20 |
| 6.1  | Performance indication of chemical reduction capacity  | 20 |
| 6.2  | Elements   | 22 |
| 6.3  | Flow control   | 22 |
| 6.4  | Waste connections  | 22 |
| 6.5  | Product water dispensing outlets   | 22 |
| 6.6  | Hazards  | 23 |
| 6.7  | Systems used in bottled water plants   | 23 |
| 6.8  | Operation temperature  | 23 |
| 6.9  | POE rated pressure drop  | 23 |
| 6.10 | Minimum service flow   | 23 |
|      | Table 6 – Minimum service flow   | 24 |
| 6.11 | Rated service flow   | 24 |
| 6.12 | Active agents and additives  | 24 |
| 6.13 | Media  | 25 |
| 6.14 | Filter media   | 26 |
| 7    | Elective performance claims – test methods   | 27 |
| 7.1  | General requirements   | 27 |
| 7.2  | Chemical reduction claims  | 29 |
|      | Table 7 – Chemical reduction requirements  | 29 |
|      | Table 8 – Chemical reduction requirements  | 33 |
|      | Table 9 – Radon reduction requirements   | 36 |
|      | Table 10 – Organic chemicals included by surrogate testing   | 39 |
| 7.3  | Mechanical filtration reduction claims   | 42 |
| 7.4  | Metals reduction testing   | 55 |
|      | Table 11 – Chemical reduction requirements   | 56 |
|      | Table 12 – Arsenic reduction requirements (Trivalent challenge)  | 59 |
|      | Table 13 – General metals reduction requirements   | 63 |

|   |     |
|---|-----|
| Table 14 – Lead reduction requirements .....  | 66  |
| Table 15 – Mercury reduction requirements .....   | 72  |
| 8 Instruction and information .....   | 74  |
| 8.1 Installation, operation, and maintenance instructions .....                             | 74  |
| 8.2 Data plate .....  | 76  |
| 8.3 Replacement components .....  | 78  |
| 8.4 Performance data sheet .....  | 79  |
| Table 16 – Performance data sheet reduction claims .....                                    | 79  |
| Table 17 – Performance data sheet reduction claims for organic chemicals .....              | 81  |
| Table 18 – Performance data sheet performance claims for percent reduction .....            | 82  |
| Annex A .....   | A1  |
| A.1 Summary of method .....   | A1  |
| A.2 Equipment .....   | A1  |
| A.3 Reagents .....  | A2  |
| A.4 Safety .....  | A2  |
| A.5 Enumeration of stock oocyst suspension .....  | A3  |
| A.6 Procedure .....   | A4  |
| A.7 Quality control .....   | A7  |
| A.8 Analyst verification .....  | A9  |
| Table A1 – Ethanol/glycerol series .....  | A10 |
| Table A2 – Suggested sample volumes for 25 mm membrane filters .....                        | A10 |
| Table A3 – Quality control acceptance criteria for performance tests .....                  | A10 |
| Annex B .....   | B1  |
| B.1 Summary of method .....   | B1  |
| B.2 Equipment .....   | B1  |
| B.3 Reagents .....  | B1  |
| B.4 Enumeration of stock microspheres .....   | B2  |
| B.5 Procedure .....   | B2  |
| B.6 Quality control .....   | B4  |
| B.7 Analyst verification .....  | B6  |
| Table B1 – Suggested sample volumes for 25 mm membrane filters .....                        | B7  |
| Table B2 – Quality control acceptance criteria for performance tests for microspheres ..... | B7  |
| Annex C .....   | C1  |
| C.1 Example fact section for pentavalent arsenic treatment systems .....                    | C1  |
| C.2 Example fact section for arsenic treatment systems .....                                | C2  |
| Annex D .....   | D1  |
| D.1 Marking the product .....   | D1  |
| D.2 Listing certified companies .....   | D1  |
| D.3 Annual audits .....   | D1  |
| D.4 Testing .....   | D2  |
| D.5 Toxicological evaluation of materials formulations .....                                | D2  |
| D.6 Corrective action .....   | D2  |
| D.7 Enforcement .....   | D2  |
| D.8 Administrative review .....   | D2  |
| D.9 Appeals .....   | D2  |
| D.10 Complaints .....   | D3  |
| D.11 Advertising .....  | D3  |
| D.12 Records .....  | D3  |
| D.13 Public notice .....  | D3  |
| D.14 Confidentiality .....  | D3  |

## Foreword<sup>2</sup>

The purpose of this Standard is to establish minimum requirements for materials, design and construction, and performance of drinking water treatment systems that are designed to reduce specific health-related contaminants in public or private water supplies. NSF/ANSI 53 specifies minimum product literature requirements that manufacturers must provide to authorized representatives and owners.

This edition of the Standard contains the following revisions:

### Issue 77

This revision clarifies the rated service flow requirement by not allowing a rated service flow to be less than the required minimum service flow.

### Issue 78

EPA methods for 524.2 and 524.3 for VOC analysis were added to Table 7.

This Standard was developed by the NSF Joint Committee on Drinking Water Treatment Units using the consensus process described by the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units, c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

---

<sup>2</sup> The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

## NSF/ANSI Standard for Drinking Water Treatment Units —

# Drinking water treatment units — Health effects

## 1 General

### 1.1 Purpose

It is the purpose of this Standard to establish minimum requirements for materials, design and construction, and performance of point-of-use and point-of-entry drinking water treatment systems that are designed to reduce specific health-related contaminants in public or private water supplies. Such systems include point-of-entry drinking water treatment systems used to treat all or part of the water at the inlet to a residential facility or a bottled water production facility, and includes the material and components used in these systems. This Standard also specifies the minimum product literature and labeling information that a manufacturer shall supply to authorized representatives and system owners, as well as the minimum service-related obligations that the manufacturer shall extend to system owners.

### 1.2 Scope

The point-of-use and point-of-entry systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water (public or private). These substances are considered established or potential health hazards. They may be microbiological, chemical, or particulate (including filterable cysts) in nature. It is recognized that a system may be effective in controlling one or more of these contaminants, but systems are not required to control all. Activated carbon filter systems covered by this Standard are not intended to be used with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system.

### 1.3 Minimum requirements

A system as defined in this standard shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7.

A component as defined in this standard shall meet the requirements of 4 and 8. If the component is pressure-bearing, it shall also meet the applicable requirements of 5.

A commercial modular system as defined in this standard shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7. Manifolds of commercial modular systems shall meet the requirements of 4, 5 (if pressure bearing), and 8, and shall be evaluated as stand-alone components. Manifolds shall have a minimum internal diameter such that the water velocity in the manifold will not exceed 3 m (10 ft) per second (which can be calculated based upon the system flow rate and the manifold internal diameter). Individual modular elements evaluated as a manifold and modular element combination shall meet the applicable requirements of 4, 5, 6, and 8, plus at least one performance claim as described in 7.