

IEEE Guide for Application for Monitoring Equipment to Liquid-Immersed Transformers and Components

IEEE Power and Energy Society

Sponsored by the
Transformers Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std C57.143™-2012

19 December 2012

IEEE Guide for Application for Monitoring Equipment to Liquid-Immersed Transformers and Components

Sponsor

**Transformers Committee
of the
IEEE Power and Energy Society**

Approved 5 December 2012

IEEE-SA Standards Board

Abstract: Identification of the key parameters that can be monitored for obtaining an indication of the condition of liquid-immersed transformers is covered by this guide. It also covers risk/benefit analysis, sensor application, and monitoring systems application. This guide does not cover interpretation of monitoring results.

Keywords: IEEE C57.143, liquid-immersed transformers, transformer monitoring

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2012 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 19 December 2012. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-8027-4 STD98027
Print: ISBN 978-0-7381-8030-4 STDPD98027

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Notice and Disclaimer of Liability Concerning the Use of IEEE Documents: IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon any IEEE Standard document.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained in its standards is free from patent infringement. IEEE Standards documents are supplied "AS IS."

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Translations: The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official Statements: A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on Standards: Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important to ensure that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. Any person who would like to participate in evaluating comments or revisions to an IEEE standard is welcome to join the relevant IEEE working group at <http://standards.ieee.org/develop/wg/>.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Photocopies: Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://standards.ieee.org/index.html> or contact the IEEE at the address listed previously. For more information about the IEEE Standards Association or the IEEE standards development process, visit IEEE-SA Website at <http://standards.ieee.org/index.html>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Introduction

This introduction is not part of IEEE Std C57.143-2012, IEEE Guide for Application for Monitoring Equipment to Liquid-Immersed Transformers and Components.

For many decades, transformer users have sought ways to assess the general condition of electrical power apparatus and identify specific problems. Over the years, diagnostic tests have been developed, based on available technology. In the last few years, a sophisticated means has evolved for collecting a great deal of diagnostic information while the equipment is in service.

Periodic off-line diagnostic tests still play an important role in industry. However, “continuous” or “on-line” monitoring can overcome some of the fundamental limitations of off-line tests, in that it can increase the performance and reliability of substation power apparatus, it can reduce maintenance costs, and it can aid in the optimization of apparatus operations and maintenance procedures and help manage the growing risk of an aging population of transformers and components.

Starting in the 1980s, industry and electric utilities shifted their strategies and resources from construction and expansion, to maintenance and diagnostics for the plants that were built in the development boom of the 1960s and 1970s. Maintenance records were retrieved, tabulated, and analyzed; databases were created. Maintenance technology evolved through the following four levels:

- Corrective: Ensuring that equipment is operating and functional
- Preventive: Optimizing the performance of the equipment
- Predictive: Diagnosing impending downtime for maintenance
- Strategic/optimization: Operational controls and corporate wide asset management

Today, plant optimization systems have become fairly common, and the leading edge of technology is now focused on predictive maintenance systems. However, the monitoring of transformers and other electrical apparatus has several challenges: the reliability of the electronic equipment, cost of the monitors, continuing development of the sensors and monitoring systems, performance under harsh field conditions, lack of availability of field expertise, data collection, and interpretation.

This guide describes most of the continuous on-line monitoring and diagnostic methods that are in common practice at the time this guide was written, and provides additional information in the case of developing techniques. This guide addresses transformer operational parameters that can be monitored and the risks and benefits of the monitoring. It also provides specification considerations for monitoring hardware, software, and communication systems. For the purposes of this guide, the term *transformer* refers, but is not limited to: generator step-up transformers; autotransformers; phase-shifting transformers; regulating transformers; intertie transmission transformers; DC converter transformers; instrument transformers; retail, customer, or industrial service transformers; and shunt, series, and saturable reactors.

Participants

At the time this guide was completed, the On-Line Monitoring Guide Working Group had the following membership:

Donald Chu, *Chair*
Andre Lux, *Vice-chair*
Tony Pink *Secretary*

Jacques Aubin
Carlo Arpino
Derek Ashby
Ron Barker
David Barnard
William Bartley
Claude Beauchemin
Jeff Benach
Zalya Berler
Enrique Betancourt
Tom Breckenridge
Kent Brown
Donald Cash
Luiz Cheim
Bill Chiu
John Crouse
William Darovny
Dieter Dohnal
Donald Fallon
Pierre Feghali
George Forrest
Michael Franchek
James Gardner
Andreas Garnitschnig

James Graham
Bill Griesacker
Jack Hammers
John Harley
Gary Hoffman
Rowland James, Jr.
Virendra Jhonsa
Claude Kane
C. J. Kalra
Joseph Kelly
Dong Kim
John Lackey
Stanley Lindgren
Thomas Lundquist
Michael W. Martin
Terence J. Martin
Phillip McClure
Doug McCullough
Paul Mushill
Russell Nordman
Arturo Nunez
Remi Pages
Paul Pillitteri
Thomas Prevost

Mark Rivers
Oleg Roizman
Surinder Sandhu
Ewald Schweiger
Devki Sharma
H. Jin Sim
Brian Sparling
Thomas Spitzer
Bengt-Olof Stenestam
Craig Stiegemeier
Christopher Sullivan
Jim Thompson
Robert Thompson
Robert Tillman
Greg Troxell
Luke Vanderzel
Richard Van Neste
Roger Verdolin
Herman Vogel
David Wallach
Joe Watson
Roger Wicks
Shuzhen Xu
Peter Zhao

The following members of the balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Mohamed Abdel Khalek
William Ackerman
Michael Adams
Donald Angell
Stan Arnot
Carlo Arpino
Jacques Aubin
Barry Beaster
Claude Beauchemin
Jeffrey Benach
W. J. Bil Bergman
Enrique Betancourt
Steven Bezner
Wallace Binder
Thomas Blackburn
William Bloethe
W. Boettger
Paul Boman
Dietrich Bonmann
Steven Brockschink
Antonio Cardoso
Arvind K. Chaudhary

Bill Chiu
C. Clair Claiborne
Larry Coffeen
Craig Colopy
Jerry Corkran
John Crouse
Willaim Darovny
Dieter Dohnal
Gary Donner
Donald Dunn
Gary Engmann
James Fairris
Donald Fallon
Rabiz Foda
Joseph Foldi
George Forrest
Marcel Fortin
Fredric Friend
George Frimpong
Jalal Gohari
Edwin Goodwin
James Graham

Randall Groves
Bal Gupta
Said Hachichi
John Harley
J. Harlow
David Harris
Roger Hayes
Joshua Herz
Gary Heuston
Gary Hoffman
Philip Hopkinson
Catherine Hurley
R. Jackson
Rowland James
Wayne Johnson
Lars Juhlin
Laszlo Kadar
C. Kalra
Gael Kennedy
Sheldon Kennedy
Joseph L. Koepfinger
Alexander Kraetge

Jim Kulchisky
Saumen Kundu
John Lackey
Chung-Yiu Lam
Stephen Lambert
Thomas La Rose
S. Lindgren
Hua Liu
Thomas Lundquist
Greg Luri
J. Dennis Marlow
Terence Martin
John Matthews
Omar Mazzoni
James McBride
Phillip McClure
William McDermid
Joseph Melanson
Gary Michel
C. Michael Miller
Daniel Mulkey
Jerry Murphy
Ryan Musgrove
Paul Mushill
Michael S. Newman
Joe Nims

Bansi Patel
Shawn Patterson
Wesley Patterson
J. Patton
Brian Penny
Alan Peterson
Christopher Petrola
Paul Pillitteri
Tony Pink
Donald Platts
Alvaro Portillo
Lewis Powell
Gustav Preininger
Tom Prevost
Jean-Christophe Riboud
Johannes Rickmann
Michael Roberts
Charles Rogers
Oleg Roizman
Zoltan Roman
Marnie Roussel
Thomas Rozek
Sukhbir Sachdev
Dinesh Sankarakurup
Bartien Sayogo

Ewald Schweiger
Lubomir Sevov
Hamid Sharifnia
Devki Sharma
Gil Shultz
Hyeong Sim
Charles Simmons
James Smith
Brian Sparling
Thomas Spitzer
Nagu Srinivas
Gary Stoedter
James Thompson
Eric Udren
A. John Vandermaar
Richard VanNeste
John Vergis
David Wallach
Barry Ward
Joe Watson
Kenneth White
Roger Wicks
Alan Wilks
John Wilson
Jian Yu
Hugh Zhu

When the IEEE-SA Standards Board approved this standard on 5 December 2012, it had the following membership:

Richard H. Hulett, *Chair*
John Kulick, *Vice Chair*
Robert M. Grow, *Past Chair*
Konstantinos Karachalios, *Secretary*

Satish Aggarwal
Masayuki Ariyoshi
Peter Balma
William Bartley
Ted Burse
Clint Chaplin
Wael Diab
Jean-Philippe Faure

Alexander Gelman
Paul Houz e
Jim Hughes
Young Kyun Kim
Joseph L. Koepfinger*
David J. Law
Thomas Lee
Hung Ling

Oleg Logvinov
Ted Olsen
Gary Robinson
Jon Walter Rosdahl
Mike Seavey
Yatin Trivedi
Phil Winston
Yu Yuan

* Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Catherine Berger
IEEE Standards Senior Program Manager, Document Development

Erin Spiewak
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. Normative references.....	2
3. Definitions	3
4. Surveillance needs of high-voltage transformers and accessories	4
4.1 General	4
4.2 Power transformers.....	4
4.3 Instrument transformers.....	6
4.4 Bushings	8
4.5 Load tap changers.....	10
5. Monitored parameters.....	16
5.1 General	16
5.2 Dissolved gas-in oil analysis	16
5.3 Moisture in oil	18
5.4 Partial discharge	19
5.5 Transformer temperatures.....	21
5.6 Winding temperatures.....	21
5.7 Load current and voltage	22
5.8 Insulation power factor	23
5.9 Pump/Fan operation.....	23
5.10 Load tap changer (LTC) operations.....	24
5.11 Conservator membrane.....	24
6. Monitoring systems and equipment.....	25
6.1 Monitoring system description	25
6.2 Sensors.....	25
6.3 Hardware specification	26
6.4 Signals	27
6.5 Signal acquisition	27
6.6 Application of sensors	28
6.7 Installation considerations	29
6.8 Control function.....	31
6.9 Selecting communications hardware and protocols.....	31
6.10 Data application.....	32
6.11 Selection criterion for on-line monitoring system	33
6.12 On-line diagnostics for transformers	33
7. Cost benefits	34
7.1 Introduction	34
7.2 Inspection and maintenance costs.....	35
7.3 Failure resolution cost.....	36
7.4 Reinforcement of overload capability.....	43
7.5 Deferring transformer replacement.....	46

7.6 Monitoring system cost.....	47
7.7 Global evaluation.....	47
Annex A (informative) Bibliography	48
Annex B (informative) Bushing power factor and capacitance.....	54
B.1 Introduction.....	54
B.2 Current sum method.....	54
B.3 Tan δ method	55
B.4 Relative Power Factor/Tan δ	55
Annex C (informative) Partial discharge: electrical and acoustic methods	57
C.1 Introduction.....	57
C.2 Electrical PD.....	57
C.3 Acoustic PD.....	59
Annex D (informative) Direct winding temperature	62
D.1 Fluorescence decay time.....	62
D.2 Distributed temperature sensor	66
Annex E (informative) Communications protocols for on-line monitoring equipment.....	68
E.1 Introduction.....	68
E.2 The role and requirements of a protocol.....	68
E.3 Protocol selection.....	69
E.4 Recommended practice	70
E.5 Communication hardware considerations	72

IEEE Guide for Application for Monitoring Equipment to Liquid-Immersed Transformers and Components

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

On-line monitoring of power transformers and associated accessories is becoming an essential feature of electric utility systems. The justification for on-line monitoring is driven by the need to increase the availability of power transformers, re-direction of time and/or operational-based maintenance to condition-based maintenance, asset and life management and failure cause analysis.

1.1 Scope

This guide covers identification of the key parameters that can be monitored for obtaining an indication of the condition of liquid-immersed transformers. It also covers risk/benefit analysis, sensor application, and monitoring systems application. This guide does not cover interpretation of monitoring results.

1.2 Purpose

The purpose of this document is to provide guidance to those who specify, apply, install and use on-line monitoring equipment on liquid-immersed power transformers and their components.