

IEEE Standard for Metal-Clad Switchgear

IEEE Power and Energy Society

Sponsored by the
Switchgear Committee

IEEE Std C37.20.2™-2015

(Revision of
IEEE Std C37.20.2-1999)

IEEE Standard for Metal-Clad Switchgear

Sponsor

Switchgear Committee
of the
IEEE Power and Energy Society

Approved 11 June 2015

IEEE-SA Standards Board

Abstract: Metal-clad (MC) medium-voltage switchgear that contains drawout electrically operated circuit breakers is covered. MC switchgear is compartmentalized to isolate components such as instrumentation, main bus, and both incoming and outgoing connections with grounded metal barriers. Rated maximum voltage levels for metal-clad switchgear range from 4.76 kV to 38 kV with main bus continuous current ratings of 1200 A, 2000 A, 3000 A, and 4000 A. MC switchgear also contains associated control, instruments, metering, relaying, protective, and regulating devices, as necessary. Service conditions, ratings, temperature limitations and classification of insulating materials, insulation (dielectric) withstand voltage requirements, test procedures, and applications are discussed.

Keywords: control, cumulative loading, current transformers, drawout, IEEE C37.20.2™, indoor, instrumentation, load current-carrying, metal-clad (MC) switchgear, metal-enclosed (ME) power switchgear, outdoor, protection, switchgear assemblies, transformer accuracy, voltage transformers

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2015 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 22 September 2015. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-9943-6 STD20391
Print: ISBN 978-0-7381-9944-3 STDPD20391

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/xpl/standards.jsp> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the SASC-IEEE Standard for Metal-Clad Switchgear Working Group Working Group had the following membership:

Michael Wactor, *Chair*
T. W. Olsen, *Vice Chair*

Paul D. Barnhart
James E. Bowen
Ted Burse
Eldridge R. Byron
Jerry Earl
Douglas J. Edwards
Larry Farr
S. S. Gohil

David J. Lemmerman
Frank Mayle
Deepak Mazumdar
Daleep C. Mohla
Miklos J. Orosz
Amit Patel
Julian Profir

Robert J. Puckett
Carl Schneider
James E. Smith
H. Song
Paul B. Sullivan
Chand Z. Tailor
John Toney
Marcelo Valdes

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William Ackerman
Mohammed Ashraf Ali
Charles Ball
Thomas Barnes
Paul Barnhart
George Becker
Robert Behl
Seth Benson
W. J. (Bill) Bergman
David Beseda
Steven Bezner
Wallace Binder
Thomas Blair
William Bloethe
David Burns
Ted Burse
Thomas Callsen
Paul Cardinal
Stephen Cary
Darold Davis
Gary Donner
Randall Dotson
Louis Doucet
Neal Dowling
Dana Dufield
Edgar Dullni
Jerry Earl
Douglas J. Edwards
Donald Elliott
Ronald Esco
Keith Flowers
Rabiz Foda
Marcel Fortin
Fredric Friend
Doaa Galal
Frank Gerleve
Douglas Giraud
Robert Goodin
James Graham

Randall Groves
Ajit Gwal
Charles Hand
Jeff Hanson
John Harley
Jeffrey Helzer
Steven Hensley
Reid Herzog
Gary Heuston
Robert Hoerauf
David Horvath
Song Jin
Andrew Jones
Laszlo Kadar
John Kay
Chad Kennedy
Gael Kennedy
Yuri Khersonsky
Morteza Khodaie
Boris Kogan
Jim Kulchisky
Marc Lacroix
Chung-Yiu Lam
Albert Livshitz
R. Long
Thomas Lundquist
Frank Mayle
William McBride
Jeffery Mizener
Daleep C. Mohla
Charles Morse
Thomas Mulcahy
Jerry Murphy
Dennis Neitzel
Michael Newman
Joe Nims
George Nourse
T. W. Olsen
Lorraine Padden

Edward Peters
Christopher Petrola
Julian Profir
Samala Santosh Reddy
Johannes Rickmann
Michael Roberts
Charles Rogers
Tim Rohrer
Thomas Rozek
Bartien Sayogo
Carl Schneider
Robert Seitz
Hamid Sharifnia
Devki Sharma
John Shullaw
Michael Sigmon
David Singleton
James E. Smith
Jerry Smith
Ralph Stell
Paul B. Sullivan
James Swank
Michael Swearingen
Donald Swing
Chand Z. Tailor
David Tepen
Wayne Timm
Marcelo Valdes
John Vergis
Michael Wactor
Mark Waldron
William Walter
John Webb
Kenneth White
James Wilson
Larry Yonce
Jian Yu
Kipp Yule
Matthew Zeedyk

When the IEEE-SA Standards Board approved this standard on 11 June 2015, it had the following membership:

John D. Kulick, *Chair*
Jon Walter Rosdahl, *Vice Chair*
Richard H. Hulett, *Past Chair*
Konstantinos Karachalios, *Secretary*

Masayuki Ariyoshi
Ted Burse
Stephen Dukes
Jean-Philippe Faure
J. Travis Griffith
Gary Hoffman
Michael Janezic

Joseph L. Koepfinger*
David J. Law
Hung Ling
Andrew Myles
T. W. Olsen
Glenn Parsons
Ronald C. Petersen
Annette D. Reilly

Stephen J. Shellhammer
Adrian P. Stephens
Yatin Trivedi
Philip Winston
Don Wright
Yu Yuan
Daidi Zhong

*Member Emeritus

Introduction

This introduction is not part of IEEE Std C37.20.2™-2015, IEEE Standard for Metal-Clad Switchgear.

This standard has been revised to reflect needed technical changes that have been suggested since the last revision to IEEE C37.20.2™ was published in 1999. The significant changes include:

- Addition of 4000 A as a preferred continuous current rating
- Addition of new definitions for types of insulation as used in metal-clad (MC) switchgear
- Addition of special considerations/requirements when generator circuit breakers are used in MC switchgear
- Clarification/expansion of the tests for insulation materials
- Updating of the seismic qualification test references
- Update to finish and construction requirements
- Addition of Annex C for Partial Discharge testing and Annex D for Voltage Dividers
- Conversion of “Notes” to normative text (where appropriate)

This standard includes only the requirements for metal-clad switchgear. These requirements were previously a part of IEEE Std C37.20™-1969, IEEE Standard for Switchgear Assemblies Including Metal-Enclosed Bus (1974 consolidated edition).¹ Other types of equipment previously included in IEEE Std C37.20-1969 are incorporated in separate publications.

For many years, IEEE Std C37.20-1969 covered all switchgear assemblies, including metal-enclosed bus. Standards committees of the IEEE Switchgear Assemblies Subcommittee and the NEMA Power Switchgear Assemblies Technical Committee recommended that the document be further developed and, where appropriate, that the various sections be identified with their own standards. This approach also coordinates with the Conformance Test Procedure Standards.

The IEEE Switchgear Assemblies Subcommittee was responsible for this revision.

This publication is one of a series covering Switchgear Assemblies. Members of the series are as follows:

- IEEE Std C37.20.1™, IEEE Standard for Metal-Enclosed Low-Voltage Power Circuit Breaker Switchgear.^{2,3}
- IEEE Std C37.20.2™, IEEE Standard for Metal-Clad Switchgear.
- IEEE Std C37.20.3™, IEEE Standard for Metal-Enclosed Interrupter Switchgear.
- IEEE Std C37.20.6™, IEEE Standard for 4.76 kV to 38 kV Rated Ground and Test Devices Used in Enclosures.

¹ Information on references can be found in Clause 2.

² The IEEE standards or products referred to in this clause are trademarks of The Institute of Electrical and Electronics Engineers, Inc.

³ IEEE publications are available from The Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854, USA (<http://standards.ieee.org/>).

- IEEE Std C37.20.7TM, Guide for Testing Metal-Enclosed Switchgear for Internal Arcing Faults.
- IEEE PC37.20.9TM, IEEE Standard for Gas-Insulated Switchgear rated up to 52kV.⁴
- IEEE Std C37.21TM, IEEE Standard for Control Switchboards.
- IEEE Std C37.23TM, IEEE Standard for Metal-Enclosed Bus.
- IEEE C37.24TM, IEEE Guide for Evaluating the Effect of Solar Radiation on Outdoor Metal-Enclosed Switchgear.

Figure A depicts types of switchgear assemblies and related standards documents:




Figure A—Types of switchgear assemblies

⁴ Numbers preceded by P are IEEE authorized standards projects that were not approved by the IEEE-SA Standards Board at the time this publication went to press. For information about obtaining drafts, contact the IEEE. Note that PC37.20.9 is in process.

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. Normative references.....	2
3. Definitions	4
4. Service conditions	7
5. Ratings.....	8
5.1 General	8
5.2 Voltage and insulation levels.....	8
5.3 Rated power frequency	9
5.4 Rated current	9
5.5 Temperature limitations.....	10
5.6 Current transformer ratings.....	12
5.7 Current transformer accuracies.....	13
5.8 Voltage transformers	13
5.9 Other devices	13
6. Tests	14
6.1 General	14
6.2 Design tests.....	14
6.3 Production tests.....	32
6.4 Conformance tests	33
6.5 Field dielectric tests	33
6.6 Optional tests	34
7. Construction	34
7.1 Buses and primary connections	34
7.2 Grounding and bonding.....	35
7.3 Control and secondary circuits and devices.....	35
7.4 Miscellaneous	40
7.5 Materials, finishes, and color.....	41
7.6 Precautionary labels.....	42
7.7 Metallic Barriers	42
7.8 Shutters	42
7.9 Insulating materials for covering buses and connections.....	42
7.10 Interlocks	43
7.11 Interchangeability of removable switching and interrupting devices	43
7.12 Primary fuses and transformers	44
7.13 Secondary disconnect devices	44
7.14 Control wiring.....	44
7.15 Handling device.....	44
7.16 Test cabinet.....	45
7.17 Indoor MC switchgear, access, and ventilation	45
7.18 Outdoor MC switchgear, access, and ventilation.....	45
7.19 Circuit breaker open/close position indication	45

7.20 Enclosure categories	45
7.21 Ground and test devices.....	46
7.22 Load interrupter switches	46
7.23 Voltage dividers.....	46
8. Application guide for MC switchgear	46
8.1 Unusual service conditions	46
8.2 System characteristics—voltage and frequency	50
8.3 Overvoltage considerations—insulation levels.....	50
8.4 Continuous current rating and overload capability	50
8.5 Short-circuit considerations	58
8.6 Nuclear power plant application.....	58
8.7 Associated devices often used in MC switchgear.....	58
8.8 Protection and isolation of switchgear connected to other circuit protective equipment.....	60
9. Guide for handling, storage, and installation.....	60
9.1 General	60
9.2 Handling	60
9.3 Preoperation check	62
9.4 Removable elements.....	63
9.5 Interlocks	63
9.6 Energizing.....	63
Annex A (informative) Bibliography	64
Annex B (normative) Guide for enclosure categories and related requirements	66
B.1 Introduction.....	66
B.2 Enclosure categories	66
B.3 Enclosure requirements.....	67
Annex C (informative) Partial discharge testing	73
C.1 General.....	73
C.2 Application.....	73
C.3 Test circuits and measuring instruments	74
C.4 Test procedure.....	74
C.5 Maximum permissible partial discharge quantity	75
Annex D (normative) Voltage dividers	76
D.1 Introduction	76
D.2 Glossary	76
D.3 Construction.....	76
D.4 Performance.....	77

IEEE Standard for Metal-Clad Switchgear

IMPORTANT NOTICE: IEEE Standards documents are not intended to ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notice” or “Important Notices and Disclaimers Concerning IEEE Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This standard covers metal-clad switchgear containing, but not limited to, such devices as power circuit breakers, other interrupting devices, switches, control, instrumentation and metering, and protective and regulating equipment. It includes, but is not specifically limited to, equipment for the control and protection of apparatus used for power generation, conversion, and transmission and distribution.

This standard is concerned with enclosed, rather than open, indoor and outdoor switchgear assemblies rated above 1000 V ac. Included is equipment that is part of primary and secondary unit substations. Gas insulated substation equipment is not included.

In this standard, metal-clad switchgear will be called MC switchgear.

1.2 Purpose

This standard provides information essential to designing and testing of metal-clad switchgear. Included herein are preferred ratings, required design test procedures, and acceptance criteria. A detailed description of construction requirements; including required functional performance features, structural materials, insulation, and interlocking is provided. Additionally, information on equipment application with respect to operating conditions, dielectric capabilities, and detailed application information regarding continuous current capabilities under differing ambient temperature conditions and application involving short-term overloading is included.