



*NSF International Standard /  
American National Standard*

## NSF/ANSI 58 - 2016

Reverse Osmosis Drinking Water  
Treatment Systems



*NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.*

This Standard is subject to revision.  
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Drinking Water Treatment Units  
c/o NSF International  
789 North Dixboro Road, P. O. Box 130140  
Ann Arbor, Michigan 48113-0140 USA  
Phone: (734) 769-8010 Telex: 753215 NSF INTL  
FAX: (734) 769-0109  
E-mail: [info@nsf.org](mailto:info@nsf.org)  
Web: <http://www.nsf.org>

NSF International Standard/  
American National Standard  
for Drinking Water Treatment Units –

**Reverse osmosis  
drinking water  
treatment systems**

Standard Developer  
**NSF International**

**NSF International**

**Designated as an ANSI standard**  
May 23, 2016  
**American National Standards Institute**

Recommended for adoption by  
**The NSF Joint Committee on Drinking Water Treatment Units**  
**The NSF Council of Public Health Consultants**

Adopted by  
**The NSF Board of Directors**  
**November 1986**

Revised May 1990	Revised December 2003	Revised November 2016
Revised November 1992	Editorial revision March 2004	
Revised January 1996	Revised March 2004	
Revised September 1996	Revised June 2005	
Revised September 1996	Revised March 2006	
Revised September 1997	Revised October 2007	
Revised September 1999	Revised August 2009	
Revised May 2000	Addendum May 2011	
Revised November 2000	Revised February 2012	
Revised January 2001	Revised December 2012	
Revised January 2002	Revised December 2013	
Addendum June 2002	Revised November 2014	
Addendum October 2002	Revised October 2015	

Published by

**NSF International**  
**P. O. Box 130140, Ann Arbor, Michigan 48113-0140, USA**

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 58 –2016."

Copyright 2016 NSF International

Previous editions © 2015, 2014, 2013, 2012, 2011, 2009, 2007, 2006, 2005, 2004, 2003, 2002, 2001, 2000, 1999, 1997, 1996, 1992, 1990, 1986

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

## Disclaimers<sup>1</sup>

NSF, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

---

<sup>1</sup> The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

Contents

1	General .....	1
1.1	Purpose .....	1
1.2	Scope .....	1
1.3	Chemical and mechanical reduction performance claims .....	1
1.4	Treatment train .....	1
2	Normative references .....	1
3	Definitions .....	2
4	Materials .....	2
4.1	Materials in contact with drinking water .....	2
4.2	Membrane preservatives.....	3
4.3	Temperature resistance .....	3
4.4	Materials evaluation .....	4
4.5	Gas chromatography/mass spectroscopy (GC/MS) analysis .....	5
5	Structural performance .....	14
5.1	Structural integrity .....	14
6	Minimum performance requirements.....	19
6.1	General.....	19
6.2	Flow control.....	19
6.3	Reject water connections .....	19
6.4	Storage tank capacity.....	20
6.5	Product water dispensing outlets .....	20
6.6	Drinking fountain outlets.....	20
6.7	Performance indication .....	20
6.8	Hazards.....	21
6.9	TDS reduction, recovery rating, and efficiency rating claims.....	21
7	Elective performance claims – test methods.....	29
7.1	Chemical reduction claims .....	29
7.2	Mechanical filtration claims .....	40
7.3	Data transfer protocol (DTP).....	45
8	Instructions and information .....	48
8.1	Installation, operation, and maintenance instructions.....	48
8.2	Data plate.....	50
8.3	Performance data sheet.....	51
	Annex A.....	A1
	Annex B.....	B1
	Annex C.....	C1
	Annex D.....	D1
	Annex E.....	E1
	Interpretations Annex .....	Interpretations 1

This page is intentionally left blank.

## Foreword<sup>2</sup>

The purpose of this Standard is to establish minimum requirements for materials, design and construction, and performance of point-of-use reverse osmosis drinking water treatment systems. NSF/ANSI 58 also specifies minimum product literature requirements that manufacturers must provide to authorized representatives and owners. Minimum service related obligations for manufacturers to extend to system owners are also specified in this Standard.

Water contact materials in Drinking Water Treatment Units listed under NSF/ANSI 42, 44, 53, 55, 58, and 62 are tested and evaluated under a separate protocol from NSF/ANSI 61 with criteria that were developed specifically for the intended end-use. NSF/ANSI 61 listing should not be additionally required for acceptance of these listed units for water contact application.

This edition of the Standard contains the following revisions:

### Issue 72

The nitrate claims under section 8 were revised to the actual test pressure used.

### Issue 76

CAS numbers were added to Table 4.1 (previously Table 1) of the materials evaluation criteria.

### Issue 77

This revision added language to state that systems be conditioned using the test water with the specified contaminant for chemical reduction claims under section 7.

The tables in this edition have also been changed to reflect the appropriate section in which it is located:

Previous edition of NSF/ANSI 58	Current edition of NSF/ANSI 58
Table 1	Table 4.1
Table 2	Table 4.2
Table 3	Table 4.3
Table 4	Table 4.4
Table 5	Table 5.1
Table 6	Table 6.1
Table 7	Table 7.1
Table 8	Table 7.2
Table 9	Table 7.3
Table 10	Table 8.1
Table 11	Table 8.2
Table 12	Table 8.3

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments should be sent to Chair, Joint Committee on Drinking Water Treatment Units at [standards@nsf.org](mailto:standards@nsf.org), or c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

---

<sup>2</sup> The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. Therefore, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

---

# NSF/ANSI Standard for Drinking Water Treatment Units —

## Reverse osmosis drinking water treatment systems

### 1 General

#### 1.1 Purpose

The purpose of this Standard is to establish minimum requirements for materials, design and construction, and performance of reverse osmosis drinking water treatment systems. This Standard also specifies the minimum product literature that manufacturers shall supply to authorized representatives and owners, as well as the minimum service-related obligations that manufacturers shall extend to system owners.

#### 1.2 Scope

The point-of-use reverse osmosis drinking water treatment systems addressed by this Standard are designed to be used for the reduction of specific substances that may be present in drinking water supplies (public or private) considered to be microbiologically safe and of known quality (except that claims for the reduction of filterable cysts may be permitted). Systems covered by this Standard are intended for reduction of total dissolved solids (TDS) and other contaminants specified herein. Systems with components or functions covered under other NSF or NSF/ANSI Standards or Criteria shall conform to the applicable requirements therein.

#### 1.3 Chemical and mechanical reduction performance claims

**1.3.1** All NSF/ANSI 58 performance claims shall be verified and substantiated by test data generated under the requirements of NSF/ANSI 58.

**1.3.2** When performance claims are made for substances not specifically addressed in the scope of this Standard or for those substances not specifically addressed but falling under the scope of NSF/ANSI 58, claims not specifically addressed in the Standard shall be so identified.

#### 1.4 Treatment train

A system that contains multiple, sequential treatment technologies for a performance claim under this Standard shall meet the applicable requirements as described in Annex E.

### 2 Normative references

The following documents contain provisions that constitute requirements of this Standard. At the time of publication, the indicated editions were valid. All standards are subject to revision, and parties are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. The most recent published edition of the document shall be used for undated references.

APHA, *Standard Methods for the Examination of Water and Wastewater*, twentieth edition<sup>3</sup>

NSF/ANSI 53. *Drinking water treatment units – Health effects*

NSF/ANSI 61. *Drinking water system components – Health effects*

Ontario Ministry of the Environment 1977. *An Interim Method for Determination of Asbestos Fibre Concentration in Water by Transmission Electron Microscopy*<sup>4</sup>

SAE J726 *Air Cleaner Test Code*, June 1993<sup>5</sup>

USEPA-600/4-84-053. *Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater*, June 1984<sup>6</sup>

USEPA-600/4B79/020. *Methods for the Chemical Analysis of Water and Wastes*, March 1983<sup>6</sup>

USEPA-600/RB93/100. *Methods for the Determination of Inorganic Substances in Environmental Samples*, August 1993<sup>6</sup>

USEPA-600/R-94/111. *Methods for the Determination of Metals in Environmental Samples*, Supplement 1, May 1994<sup>6</sup>

USEPA-600/4-90/020. *Methods for the Determination of Organic Compounds in Drinking Water*, Supplement 1, July 1990<sup>6</sup>

USEPA *National Primary Drinking Water Regulations*, 40 CFR Part 141<sup>7</sup>

USEPA *National Secondary Drinking Water Regulations*, 40 CFR Part 143<sup>7</sup>

USFDA Code of Federal Regulations, Title 21, (*Food and drugs*) *Direct Food Additive Substances parts 170 through 199*, April 1, 1992<sup>7</sup>

### 3 Definitions

Terms used in this Standard that have a specific technical meaning are defined in NSF/ANSI 330.

## 4 Materials

### 4.1 Materials in contact with drinking water

#### 4.1.1 Acceptance criteria

**4.1.1.1** Materials in contact with drinking water shall not impart levels of target compounds or Tentatively Identified Compounds (TICs) that exceed the Total Allowable Concentration (TAC), Maximum Contaminant

---

<sup>3</sup> American Public Health Association (APHA), 1015 Fifteenth Street, NW, Washington, DC 20005 <www.apha.org>.

<sup>4</sup> Ontario Ministry of the Environment, Toronto, Canada M4V 1P5 <www.ene.gov.on.ca>.

<sup>5</sup> Society of Automotive Engineers (SAE), 400 Commonwealth Drive, Warrendale, PA 15096 <www.sae.org>.

<sup>6</sup> U. S. Environmental Protection Agency (USEPA), Environmental Monitoring and Support Laboratory, Cincinnati, OH 45268 <www.epa.gov>.

<sup>7</sup> Superintendent of Documents, U. S. Government Printing Office, Washington, DC 20402 <www.gpo.gov>.