

IEEE Guide for Testing Switchgear Rated Up to 52 kV for Internal Arcing Faults

IEEE Power and Energy Society

Sponsored by the
Switchgear Committee

IEEE Guide for Testing Switchgear Rated Up to 52 kV for Internal Arcing Faults

Sponsor

Switchgear Committee
of the
IEEE Power and Energy Society

Approved 6 December 2017

IEEE-SA Standards Board

Abstract: Procedures for testing and evaluating the performance of switchgear for internal arcing faults is covered. A method of identifying the capabilities of this equipment is given. Service conditions, installation, and application of equipment are also discussed. As used in this document, the term *switchgear* is used as a general term covering switching and interrupting devices and their combination with associated control, instrumentation, metering, protective and regulating devices, assemblies of those devices with associated interconnections, accessories, and supporting structures used primarily in conjunction with the generation, transmission, distribution, and conversion of electrical power.

Keywords: accessibility, arc, arc-resistant, bus, compartment, IEEE C37.20.7, internal arcing fault, medium-voltage controllers, metal-clad switchgear, metal-enclosed bus, metal-enclosed gas-insulated switchgear, metal-enclosed interrupter switchgear, metal-enclosed low-voltage power circuit breaker switchgear, metal-enclosed switchgear, motor control centers, overpressure, protection, switchboard

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2018 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 7 February 2018. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-4486-6 STD22877
Print: ISBN 978-1-5044-4487-3 STDPD22877

IEEE prohibits discrimination, harassment, and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE-SA Website at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE guide was completed, the Arc-Resistant Switchgear Working Group had the following membership:

Michael Wactor, *Chair*
T. W. Olsen, *Vice Chair*

Paul D. Barnhart	Thomas Hawkins	Amit Patel
Jerry Baskin	Arthur Jur	Tim Rohrer
Russell Boyce	Chad Kennedy	Todd Sauve
James E. Bowen	Mike LaFond	Carl Schneider
Eldridge R. Byron	David J. Lemmerman	James E. Smith
Jerry Earl	Frank Mayle	Paul Sullivan
Douglas J. Edwards	Deepak Mazumdar	Chand Tailor
Michael Flack	Daleep Mohla	Marcelo Valdes
Keith Flowers	Charles Allan Morse	Robert Warren
S. S. Gohil	Darryl Moser	Terry Woodyard
	Miklos J. Orosz	

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Ali Ali	Randall Groves	Christopher Petrola
Charles Ball	Ajit Gwal	Iulian Profir
Thomas Barnes	John Harley	Larry Putman
Paul D. Barnhart	Thomas Hawkins	Samala Santosh Reddy
Michael Bayer	Jeffrey Helzer	Timothy Robirds
W. J. (Bill) Bergman	Werner Hoelzl	Tim Rohrer
Jean-Marc Biasse	Robert Hoerauf	Thomas Rozek
William Bloethe	Dan Hrcncir	Ryandi Ryandi
James E. Bowen	Richard Jackson	Todd Sauve
Rachel Bugaris	Jose Jarque	Bartien Sayogo
David Burns	Wolfgang Jung	Nikunj Shah
Ted Burse	Uwe Kaltenborn	Devki Sharma
William Byrd	John Kaminski	Michael Sigmon
Eldridge R. Byron	John Kay	Garett Sims
Paul Cardinal	Chad Kennedy	James E. Smith
Robert Cohn	Yuri Khersonsky	Jeremy Smith
Bryan Cole	James Kinney	Jerry Smith
Glenn Davis	Boris Kogan	Tom Stefanski
Gary Donner	Jim Kulchisky	Paul Sullivan
Louis Doucet	Chung-Yiu Lam	Chand Tailor
Edgar Dullni	Benjamin Lanz	David Tepen
Donald Dunn	Hua Liu	Dennis Thonsgard
Jerry Earl	Frank Mayle	Wayne Timm
Douglas J. Edwards	William McBride	Nenad Uzelac
Donald Elliott	John McClelland	Marcelo Valdes
Ronald Esco	Daleep Mohla	James Van De Ligt
Michael Flack	Charles Allan Morse	John Vergis
Keith Flowers	Darryl Moser	Michael Wactor
Marcel Fortin	Dennis Neitzel	John Wang
Fredric Friend	Arthur Neubauer	John Webb
Paul Gingrich	Michael Newman	Kenneth White
Mietek Glinkowski	T. W. Olsen	Terry Woodyard
S. S. Gohil	Lorraine Padden	Dean Yager
Robert Goodin	Mirko Palazzo	Robert Yanniello
Lou Grahor	Rahul Pawar	Larry Yonce

When the IEEE-SA Standards Board approved this guide on 6 December 2017, it had the following membership:

Jean-Philippe Faure, *Chair*
Gary Hoffman, *Vice Chair*
John Kulick, *Past Chair*
Konstantinos Karachalios, *Secretary*

Chuck Adams
Masayuki Ariyoshi
Ted Burse
Stephen Dukes
Doug Edwards
J. Travis Griffith
Michael Janezic

Thomas Koshy
Joseph L. Koepfinger*
Kevin Lu
Daleep Mohla
Damir Novosel
Ronald C. Petersen
Annette D. Reilly

Robby Robson
Dorothy Stanley
Adrian Stephens
Mehmet Ulema
Phil Wennblom
Howard Wolfman
Yu Yuan

*Member Emeritus

Introduction

This introduction is not part of IEEE Std C37.20.7™-2017, IEEE Guide for Testing Switchgear Rated Up to 52 kV for Internal Arcing Faults.

The standards and guides in the IEEE C37™ series¹ have been developed over a period of many years through the cooperative efforts of users, specifiers, manufacturers, and other interested parties. This edition of IEEE Std C37.20.7² includes a detailed application guide and improvements in the testing procedure. The original development of the 2001 edition of this guide rests heavily on Annex AA of IEC 298-1981³ and Amendment 1: 1994. This revision reflects lessons learned from use of the 2001 and 2007 editions of IEEE Std C37.20.7. This revision also extends the scope to include testing of low-voltage motor control centers, switchboards, medium-voltage ac controllers, metal-enclosed bus, metal-enclosed medium-voltage outdoor circuit breakers, and gas-insulated switchgear.

In the 1970s, principally in Europe, interest in evaluating electrical equipment under conditions of internal arcing emerged. As a result, a draft Annex AA to IEC 298 “A.C. Metal-Enclosed Switchgear and Controlgear for Rated Voltages Above 1 kV and Up to and Including 52 kV” was issued by the IEC in 1981 and revised in 1990. It was redesignated IEC 62271-200 and revised in 2003 and 2011.

Subsequent to the creation of IEC 298, IEC subcommittee 17D issued Technical Report IEC/TR 1641 in 1996 (now redesignated as IEC/TR 61641) entitled “Enclosed Low-Voltage Switchgear and Controlgear Assemblies—Guide for Testing Under Conditions of Arcing Due to Internal Fault.”

Knowledge of the arc resistance testing guide in IEC 298 spread to North America, and it was used as the basis for EEMAC G14–1, 1987, “Procedure for Testing the Resistance of Metalclad Switchgear Under Conditions of Arcing Due to an Internal Fault.” EEMAC G14–1 incorporated improvements in knowledge and understanding in over a decade of use of Annex AA of IEC 298 in Europe.

Failure within a switchgear assembly, whether from a defect, an unusual service condition, lack of maintenance, or misoperation, may initiate an internal arc. There is little likelihood of an internal arc in equipment meeting the requirements of IEEE Std C37.20.1™, IEEE Std C37.20.2™, IEEE Std C37.20.3™, IEEE Std C37.20.9™, IEEE Std C37.23™, UL 347, UL 845, or UL 891. There is even less likelihood of an internal arc in equipment that has insulated bus, compartmentalization, barriers, and interlocks, such as those described in IEEE Std C37.20.2; however, the possibility cannot be disregarded completely. The intent of this guide is to address the testing procedure for internal arcing faults in switchgear.

Even when arc-resistant construction is specified, it is strongly recommended that supplemental power system protection be provided. This supplemental protection should limit the total energy that can be delivered in the event of internal arcing faults. This protection can be provided in a variety of ways, depending on the nature of the system. Among the forms of protection that may be appropriate are current-limiting fuses, current-limiting circuit breakers, zone differential or bus differential relaying, ground differential protection, or arc-sensing systems sensitive to light or pressure effects that accompany internal arcing faults. The objective of such protection is to cause the interruption of all sources of power to the arcing fault in a time interval that is shorter than the rated arcing duration capability demonstrated by the tests contained within this document (refer to 4.4).

In addition to supplemental power system protection, adequate personal protective equipment is required, as all hazards associated with an internal arcing fault are not eliminated when equipment tested to this guide is used.

¹The IEEE standards or products referred to in this document are trademarks owned by the Institute of Electrical and Electronics Engineers, Incorporated.

²IEEE publications are available from the Institute of Electrical and Electronics Engineers (<http://standards.ieee.org/>).

³IEC publications are available from the International Electrotechnical Commission (<http://www.iec.ch>) and the American National Standards Institute (<http://www.ansi.org/>).

This revision also incorporates the changes found in Corrigendum 1 (2010) to IEEE Std C37.20.7–2007.

In this document, the term *switchgear* is used in its broadest sense (see definition of switchgear in [Clause 3](#)), and is not restricted only to equipment as described in IEEE Std C37.20.1™, IEEE Std C37.20.2™, or IEEE Std C37.20.3™.

Contents

1. Overview	11
1.1 Scope	11
1.2 Background	11
2. Normative references	14
3. Definitions	15
4. Ratings	16
4.1 General	16
4.2 Accessibility type	16
4.3 Internal arcing short-circuit current	16
4.4 Arcing duration	17
5. Tests	17
5.1 General	17
5.2 Test sample configuration (general considerations for all equipment)	17
5.3 Test conditions	19
5.4 Arc initiation	26
5.5 Burn indicators (for observing the thermal effects of gases)	27
6. Assessment	30
6.1 Assessment of test results	30
6.2 Test report	31
6.3 Nameplate	32
7. Application considerations	33
7.1 General	33
7.2 Potential areas for arcing	33
7.3 Design changes	33
7.4 Equipment maintenance	33
Annex A (informative) Bibliography	34
Annex B (informative) Application guide	35
Annex C (normative) Supplemental ratings	44
Annex D (normative) Metal-enclosed low-voltage power circuit breaker switchgear (IEEE Std C37.20.1) ..	47
Annex E (normative) Metal-clad switchgear (IEEE Std C37.20.2)	51
Annex F (normative) Metal-enclosed interrupter switchgear (IEEE Std C37.20.3)	55
Annex G (normative) Outdoor equipment	58
Annex H (normative) Motor control centers (UL 845)	63
Annex I (normative) Medium-voltage ac controllers (UL 347)	67
Annex J (normative) Switchboards (UL 891)	70
Annex K (normative) Metal-enclosed bus (IEEE Std C37.23)	74
Annex L (normative) Metal enclosed switchgear incorporating gas-insulating systems (IEEE PC37.20.9) ..	80

IEEE Guide for Testing Switchgear Rated Up to 52 kV for Internal Arcing Faults

1. Overview

1.1 Scope

This guide establishes methods by which equipment may be tested for resistance to the effects of arcing due to an internal fault. Equipment types covered in this guide include metal-enclosed switchgear as defined by IEEE Std C37.20.1™, IEEE Std C37.20.2™, IEEE Std C37.20.3™ and IEEE Std C37.20.9™; metal-enclosed bus as defined by IEEE Std C37.23™; medium-voltage ac controllers as defined by UL 347; motor control centers as defined by UL 845; switchboards as defined by UL 891; and metal-enclosed medium-voltage air-insulated circuit breakers for outdoor application defined by IEEE Std C37.04™ (see note). This guide applies only to equipment utilizing air or other insulating gas as the primary insulation medium and rated 52 kV ac or below. It applies to both indoor and outdoor equipment; however, special consideration should be given to the building size and construction for indoor applications (not fully addressed by this document).

The tests and assessments described in this guide are only applicable to arcing faults occurring entirely in air within the enclosure when doors and covers are properly secured in accordance with the rated accessibility type. This guide does not apply to arcing faults that occur within components of the equipment, such as instrument transformers, sealed interrupting devices, fuses, and so on.

Designs that meet the requirements of this guide will be referred to as *arc-resistant*.

NOTE—These circuit breakers are sometimes referred to as dead-tank circuit breakers.⁴

1.2 Background

1.2.1 Consequences of internal arc faults

Switchgear is designed to withstand the worst-case mechanical forces between conductors, which occur when a short circuit occurs directly on the load terminals of the switchgear. This condition is referred to as a *bolted fault*, a short-circuit condition that assumes zero impedance exists at the point of the fault. The ability of switchgear to withstand the effects of the bolted fault is demonstrated in the short-time withstand current tests and the short-circuit current withstand tests as required by the specific equipment standard or the corresponding tests in the relevant standards for other equipment types. When a bolted fault occurs, the voltage at the fault

⁴Notes in text, tables, and figures are given for information only and do not contain requirements needed to implement the guide.