



*NSF International Standard /
American National Standard*

NSF/ANSI 350 - 2017a

Onsite Residential and Commercial
Water Reuse Treatment Systems



NSF International, an independent, not-for-profit, non-governmental organization, is dedicated to being the leading global provider of public health and safety-based risk management solutions while serving the interests of all stakeholders.

This Standard is subject to revision.
Contact NSF to confirm this revision is current.

Users of this Standard may request clarifications and interpretations, or propose revisions by contacting:

Chair, Joint Committee on Wastewater Technology
c/o NSF International
789 North Dixboro Road, P.O. Box 130140
Ann Arbor, Michigan 48113-0140 USA
Phone: (734) 769-8010 Telex: 753215 NSF INTL
FAX: (734) 769-0109
E-mail: info@nsf.org
Web: <http://www.nsf.org>

NSF International Standard/
American National Standard
for Wastewater Technology—

**Onsite residential and commercial
water reuse treatment systems**

Standard Developer

NSF International

Designated as an ANSI Standard

May 31, 2017

American National Standards Institute

Prepared by
The NSF Joint Committee on Wastewater Technology

Recommended for Adoption by
The NSF Council of Public Health Consultants

Adopted by
The NSF Board of Trustees
July 2011

Revised December 2012
Revised December 2014
Revised February 2017
Revised February 2018

Published by

NSF International
PO Box 130140, Ann Arbor, Michigan 48113-0140, USA

For ordering copies or for making inquiries with regard to this Standard, please reference the designation "NSF/ANSI 350 – 2017a."

Copyright 2018 NSF International

Previous editions © 2017, 2015, 2014, 2012

Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from NSF International.

Printed in the United States of America.

Disclaimers¹

NSF International (NSF), in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of NSF represent its professional judgment. NSF shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. NSF shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

NSF Standards provide basic criteria to promote sanitation and protection of the public health. Provisions for mechanical and electrical safety have not been included in this Standard because governmental agencies or other national standards-setting organizations provide safety requirements.

Participation in NSF's Standards development activities by regulatory agency representatives (federal, local, state) shall not constitute their agency's endorsement of NSF or any of its Standards.

Preference is given to the use of performance criteria measurable by examination or testing in NSF Standards development when such performance criteria may reasonably be used in lieu of design, materials, or construction criteria.

The illustrations, if provided, are intended to assist in understanding their adjacent standard requirements. However, the illustrations may not include **all** requirements for a specific product or unit, nor do they show the only method of fabricating such arrangements. Such partial drawings shall not be used to justify improper or incomplete design and construction.

Unless otherwise referenced, the annexes are not considered an integral part of NSF Standards. The annexes are provided as general guidelines to the manufacturer, regulatory agency, user, or certifying organization.

¹ The information contained in this Disclaimer is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Disclaimer may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

This page is intentionally left blank.

Contents

1	General	
1.1	Purpose	1
1.2	Scope	1
1.3	Alternate materials, design, and construction	2
1.4	Performance classification	2
2	Normative references	2
3	Definitions	4
4	Materials	5
4.1	Interior surfaces	5
4.2	Exterior surfaces	5
4.3	Welding	5
4.4	Dissimilar metals	5
5	Design and construction	6
5.1	Exposed surfaces	6
5.2	Structural integrity	6
5.3	Water tightness	6
5.4	Noise	6
5.5	Mechanical components	6
5.6	Electrical components	6
5.7	Access ports	7
5.8	Failure sensing and signaling equipment	7
5.9	Flow design	8
5.10	Dataplate and service label	8
6	Product literature	9
6.1	Owner's manual	9
6.2	Additional product literature	10
7	Other documentation	11
8	Performance testing and evaluation	12
8.1	Greywater treatment systems with capacities up to 5,678 L/day (1,500 gal/day)	12
8.2	Residential wastewater treatment systems with capacities up to 5,678 L/day (1,500 gal/day)	22
8.3	Commercial treatment systems with combined wastewater flows and commercial laundry water of any capacity, and greywater capacities exceeding 5,678 L/day (1,500 gal/day)	24
8.4	Sample collection	24
8.5	Analyses (applicable to all reuse systems evaluated in accordance with 8.1, 8.2, and 8.3)	26
8.6	Criteria (applicable to all reuse systems evaluated in accordance with 8.1, 8.2, and 8.3)	26
9	Final report	29
	Annex A Key elements for a field evaluation of a commercial (C) onsite treatment system	31
	Annex B Key elements of a maintenance/management plan for onsite treatment systems	41
	Annex C	43
	Annex D Basis for greywater test water	45
	Annex E NSF International individual ingredient use study	49

This page is intentionally left blank.

Foreword²

This American National Standard, NSF/ANSI 350 *Onsite residential and commercial water reuse treatment systems*, has been developed as part of the ongoing efforts of interested parties to establish minimum material, design and construction, and performance requirements for onsite residential and commercial water treatment systems. This Standard also specifies the minimum literature that manufacturers shall supply to authorized representatives and owners as well as the minimum service-related obligations that a manufacturer shall extend to owners. This Standard is intended to address public health and environmental issues. Actual performance for any site or system may vary, depending on variations in raw water supply (such as in alkalinity and hardness), greywater constituents, and patterns of use. The end use of the effluent is the responsibility of the owner, design professionals, and regulatory officials.

Management methods and end uses appropriate for the treated effluent discharged from onsite residential and commercial treatment systems meeting Class R (single family residential) or Class C (multi-family and commercial facilities) requirements of this Standard include indoor restricted urban water use, such as toilet and urinal flushing, and outdoor unrestricted urban water use, such as surface irrigation.

Systems may include:

- Greywater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day): this applies to onsite residential and commercial treatment systems that treat greywater, those that treat laundry water from residential laundry facilities, and those that treat bathing water.
- Residential wastewater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day): this applies to onsite residential treatment systems that treat combined wastewater generated by the occupants of residence(s). A reuse system treating 1,514 L/day (400 gal/day) to 5,678 L/day (1,500 gal/day) shall either be demonstrated to have met the Class I requirements of NSF/ANSI 40 *Residential wastewater treatment systems*, or shall meet these requirements during concurrent testing to this Standard. A treatment system treating less than 1,514 L/day (400 gal/day) shall not be required to have met the Class I requirements of NSF/ANSI 40.
- Commercial treatment systems: this applies to onsite commercial treatment systems that treat combined commercial facility wastewater and commercial facility laundry water of any capacity, and those treatment systems that treat greywater from commercial facilities with capacities exceeding 5,678 L/day (1,500 gal/day). These systems shall be performance tested and evaluated at the location of the reuse system installation, using the wastewater generated onsite from the facility serving the treatment system. See 8.3 for performance testing and evaluation. The key elements of a field evaluation of a commercial onsite treatment system are described in Annex A.

This edition of the Standard contains the following revisions:

Issue 15

Language was added to section 8 and A.3.1.3 to cover all equivalent analytical methods.

Issue 16

Na₂PO₄ was corrected to Na₃PO₄ throughout the Standard

² The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

Issue 18

This issue modified the influent TSS and Turbidity ranges in the section 8.1.2.1.3 table.

Issue 19

The greywater ingredients tables were revised to allow for adjustment of the TKN concentration by addition of urea.

Issue 20

The greywater ingredients tables were revised to allow for adjustment of pH and expand the influent pH range.

Issue 21

The influent tables were revised to expand the influent range for E. Coli and total coliform.

Issue 22

The influent tables were revised to exclude the influent TOC requirements from the influent parameters of bathing, laundry and combined water sources.

Issue 23

The ingredients tables for greywater challenge water were modified to allow screened raw influent.

Issue 24

An error that removed residential systems from the scope was corrected.

Issue 25

References to SAR, FOG, iron, and surfactants parameters were removed.

Issue 26

Language addressing noise requirements for indoor systems was added.

Issue 27

Definitions for 30 day average and 30 day geometric mean were added, and language regarding challenge water requirements was clarified.

This Standard was developed by the NSF Joint Committee on Wastewater Technology using the consensus process described in the American National Standards Institute.

Suggestions for improvement of this Standard are welcome. This Standard is maintained on a Continuous Maintenance schedule and can be opened for comment at any time. Comments on this Standard should be sent to Chair, Joint Committee on Wastewater Technology at standards@nsf.org, or c/o NSF International, Standards Department, P.O. Box 130140, Ann Arbor, Michigan 48113-0140, USA.

NSF/ANSI Standard For Wastewater Technology –

Onsite residential and commercial water reuse treatment systems

1 General

1.1 Purpose

The purpose of this Standard is to establish minimum material, design, and construction, and performance requirements for onsite residential and commercial water treatment systems. This Standard also specifies the minimum literature that manufacturers shall supply to authorized representatives and owners as well as the minimum service-related obligations that a manufacturer shall extend to owners.

1.2 Scope

This Standard contains minimum requirements for onsite residential and commercial water treatment systems. Systems may include the following:

- Greywater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day). This applies to onsite residential and commercial treatment systems that treat greywater, those that treat laundry water from residential laundry facilities, and those that treat bathing water. See 8.1 for performance testing and evaluation.
- Residential wastewater treatment systems having a rated treatment capacity up to 5,678 L/day (1,500 gal/day). This applies to onsite residential treatment systems that treat combined wastewater generated by the occupants of residence(s). A reuse system treating 1,514 L/day (400 gal/day) to 5,678 L/day (1,500 gal/day) shall either be demonstrated to have met the Class I requirements of NSF/ANSI 40, or must meet these requirements during concurrent testing to this Standard. A treatment system treating less than 1,514 L/day (400 gal/day) is not required to have met the Class I requirements of NSF/ANSI 40. See 8.2 for performance testing and evaluation.
- Commercial treatment systems – this applies to onsite commercial treatment systems that treat combined commercial facility wastewater and commercial facility laundry water of any capacity, and those treatment systems that treat greywater from commercial facilities with capacities exceeding 5,678 L/day (1,500 gal/day). These systems shall be performance tested and evaluated at the location of the reuse system installation, using the wastewater generated onsite from the facility serving the treatment system. See 8.3 for performance testing and evaluation. The key elements of a field evaluation of a commercial treatment system are described in Annex A.

Management methods and end uses appropriate for the treated effluent discharged from onsite residential and commercial treatment systems meeting Class R (single family residential) or Class C (multi-family and commercial facilities) requirements of this Standard include indoor restricted urban water use, such as toilet and urinal flushing, and outdoor unrestricted urban water use, such as surface irrigation. Effluent quality criteria consistent with these uses are described in 8.6, Criteria.

This Standard is intended to address public health and environmental issues. Actual performance for any site or system may vary, depending on variations in raw water supply (such as alkalinity and hardness), wastewater constituents, and patterns of use. The end use of the effluent is the responsibility of the owner, design professionals, and regulatory officials.

System components covered under other NSF or NSF/ANSI standards or criteria shall also comply with the requirements therein. This Standard shall in no way restrict new system designs, provided such designs meet the minimum specifications described herein.

1.3 Alternate materials, design, and construction

While specific materials, designs, and constructions may be stipulated in this Standard, systems that incorporate alternate materials, designs, or constructions may be acceptable when it is verified that such systems meet the applicable requirements of this Standard.

1.4 Performance classification

For the purpose of this Standard, systems are classified according to the chemical, biological, and physical characteristics of their effluents as determined by the performance testing and evaluations described herein.

Greywater treatment systems within a manufacturer's model series may be classified according to the performance testing and evaluation of the system (8.1) expected to produce the poorest effluent quality within the series based upon design characteristics.

Residential wastewater treatment systems within a manufacturer's model series may be classified according to the performance testing and evaluation of the system (8.2) with the smallest hydraulic capacity within the series. A series is limited to treatment capacities below 1,514 L/day (400 gal/day), and treatment capacities between 1,514 L/day (400 gal/day) and 5,678 L/day (1,500 gal/day).

Greywater and residential wastewater treatment systems having rated treatment capacities less than 378 L/day (100 gal/day) shall be within a manufacturer's model series having rated treated capacities at or above 378 L/day (100 gal/day).

The manufacturer shall submit design drawings and specifications of the entire model series, which shall include critical design parameters for the systems. An engineering review of the design parameters may be completed in lieu of performance testing and evaluation of other systems within the series provided they are determined to be appropriately proportionate to the evaluated system based on sound engineering principles.

Commercial treatment systems that treat combined commercial facility wastewater and commercial facility laundry water of any capacity, and treatment systems that treat greywater from commercial facilities with capacities exceeding 5678 L/day (1500 gal/day) performance tested and evaluated in accordance with 8.3 and Annex A, may be similarly classified within a manufacturer's model series. However, consideration must be given to the conditions of the field evaluation of the system, including the wastewater characteristics, treatment system loading conditions, and other variables affecting performance. These conditions shall become limitations for classifying other systems within a manufacturer's model series.

2 Normative references

The following documents contain provisions that, through reference in this text, constitute provisions of this Standard. At the time of publication, the indicated editions were valid. All standards are subject to revision, and parties are encouraged to investigate the possibility of applying the recent editions of the standards indicated below. The most recent published edition of the document shall be used for undated reference.