

# IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities

IEEE Power and Energy Society

Sponsored by the  
Analytical Methods for Power Systems Committee

# **IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities**

Sponsor

**Analytical Methods for Power Systems Committee**  
of the  
**IEEE Power and Energy Society**

Approved 5 December 2018

**IEEE-SA Standards Board**

**Abstract:** Terminology and indices for reporting and analyzing outage occurrences of transmission facilities are defined in this standard. Outage definitions and indices are given for two general types of facilities: units and components. Units are functional facilities that transfer power between designated points, while components are specific pieces of equipment. Outage definitions are given both for describing the outage history of a particular facility and for describing groups of individual outage occurrences that are related in some way.

**Keywords:** data, electricity transmission, exposure, failure, IEEE 859™, maintenance, outage, power systems, reliability, weather

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2019 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 12 April 2019. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-1-5044-5349-3      STD23437  
Print: ISBN 978-1-5044-5350-9      STDPD23437

*IEEE prohibits discrimination, harassment, and bullying.*

*For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.*

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

## **Important Notices and Disclaimers Concerning IEEE Standards Documents**

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/ipr/disclaimers.html>.

### **Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents**

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

## **Translations**

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

## **Official statements**

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

## **Comments on standards**

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854 USA

## **Laws and regulations**

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## **Copyrights**

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. A current IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Xplore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

## Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

## Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## Participants

At the time this IEEE standard was completed, the Update of IEEE Standard 859: “Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities” Working Group had the following membership:

**Chris Dent, *Chair***

Murty Bhavaraju  
Mark Lauby  
Wenyuan Li  
Milorad Papic

Donna Pratt  
Zhouyan Ren  
Alex Schneider  
David Till

Simon Tindemans  
Kaigui Xie

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Ali AlAwazi  
Murty Bhavaraju  
William Bloethe  
Gustavo Brunello  
Demetrio Bucaneg Jr.  
Kristine Buchholz  
William Byrd  
Paul Cardinal  
Michael Chirico  
Neal Dowling  
Donald Dunn  
Michael Garrels  
Randall Groves  
Werner Hoelzl

Laszlo Kadar  
Peter Kelly  
Jim Kulchisky  
Mikhail Lagoda  
Wenyuan Li  
John McDaniel  
Michael Newman  
Gearold O. H. Eidhin  
Lorraine Padden  
Bansi Patel  
Stephen Pell  
Howard Penrose  
Christopher Petrola  
Lakshman Raut

James Reilly  
Charles Rogers  
Alex Schneider  
Hyeong Sim  
Gary Smullin  
Gary Stoedter  
K. Stump  
John Vergis  
Daniel Ward  
Val Werner  
Tamatha Womack  
Jonathan Woodworth

When the IEEE-SA Standards Board approved this standard on 5 December 2018, it had the following membership:

**Jean-Phillipe Faure, *Chair***

**Gary Hoffman, *Vice Chair***

**John D. Kulick, *Past Chair***

**Konstantinos Karachalios, *Secretary***

Ted Burse  
Guido Hiertz  
Christel Hunter  
Joseph Koepfinger\*  
Thomas Koshy  
Hung Ling  
Dong Liu

Xiaohui Liu  
Kevin Lu  
Daleep Mohla  
Andrew Myles  
Paul Nikolich  
Ron Petersen  
Annette Reilly

Robby Robson  
Dorothy Stanley  
Mehmet Ulema  
Phil Wennblom  
Philip Winston  
Howard Wolfman  
Jingyi Zhou

\*Member Emeritus

## Introduction

This introduction is not part of IEEE Std 859-2018, IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities.

### Foreword to 2018 revision

This new edition of IEEE Std 859 is a revision of IEEE Std 859-1987, which has since been reaffirmed twice with no alterations to the 1987 text. The Review Working Group began by consulting members of the user community and wider power system reliability community on the need for revisions. The clear consensus from this was that the 1987 content remains relevant and that there is no need for significant changes in content—a number of useful suggestions for clarification of the existing text did, however, emerge, and in particular there was general agreement that clarification of the terms **component**, **subcomponent** and **unit** in [Clause 3](#) would be helpful to new users of the standard.

Where clarifications were deemed beneficial, the Working Group decided to proceed as far as possible by adding additional explanatory notes rather than changing the main text of the standard. Indeed, the only changes to the main text are the addition of “Maintenance outage” as a second major type of scheduled outage in 2.3, and the addition of “Adverse weather forced outage rate” in 7.1.1. A full list of changes from the 1987 edition is included in [Annex A](#).

The primary purpose of this standard is to define summary statistics of historic data, for reporting and analyzing outage occurrences, and to facilitate exchange of data between utilities (see [Clause 2](#)). The original Foreword to the 1987 edition states that “The indices defined here are intended to serve as estimates for parameters of models which are used in transmission system reliability evaluation,” and a similar statement is made in [Clause 2](#). Users are reminded that if indices from [Clause 5](#) of this standard are used as inputs to predictive models, it is necessary to ensure that (a) the transmission elements and the environment in which their performance was observed are similar to the system whose performance is to be predicted; (b) the period of observation over which the input data was collected is a sufficient multiple of the mean time to outage to achieve a reasonable confidence interval for the indices to be used in the predictive models, and (c) that adequate consideration of common mode and dependent events has been given to avoid the fallacy of assuming that all transmission outages are independent.

The Working Group wishes to thank the following for making valuable comments, which have contributed to the review process, without taking a formal role in the process: R.N. Allan, D. Gorinevsky, J. Schaller, M.C.M. Troffaes, and members of the GARPUR project and the NERC TADS Working Group.

### Foreword to 1987 edition

Data on outage occurrences of transmission facilities have been collected for many years. Initially, reporting was generally limited to reporting frequency of outage occurrence on transmission lines. Total outage frequency was classified into several general cause categories, but there were no formal definitions for the events and statistics reported beyond those contained in the data forms and instructions. Early efforts did not generally collect data on outage duration, except to class outages as temporary or permanent according to type of restoration used.

In the 1960s, methods were first proposed for calculating reliability of transmission and distribution “systems” (networks) in terms of the reliability of their individual “components.” This led to the need for more formal definitions of terms to foster uniformity and standardization of language among engineers engaged in reporting, analyzing, and predicting outages of transmission and distribution facilities and interruptions to customers. This resulted in development of IEEE Std 346-1973, IEEE Standard Definitions in Power Operations Terminology Including Terms for Reporting and Analyzing Outages of Electrical Transmission

and Distribution Facilities and Interruptions to Customer Service. More recent developments have shown the need to include definitions for a broader scope of outage events. For example, two general categories of facilities (reportable entities) must be recognized to support presently available models. In one type of model, a transmission system is partitioned functionally into “units,” which represent the capability to transfer power between specified points. In the second type of model, a system is partitioned physically into “components?”

Another recent development is the increasing recognition of the importance of “related outage occurrences” in which outage occurrences of two or more facilities are related in some way due to the physical construction of equipment (such as common structure), the electrical interconnection of equipment (common bus, for example), or exposure to a common environment (storms). Achieving clear and unambiguous definitions for related outage occurrences is important for reporting outage occurrences at the transmission unit level. At the component level, an important consideration is the recognition of several modes of failure, particularly for switching, protection, and automatic reclosing equipment.

No attempt is made here to standardize procedures for the collection of outage data. What is attempted is to specify certain common terms and indices to provide a basis of information exchange. The task force has attempted to keep the list of terms and indices as brief as possible. The indices defined here are intended to serve as estimates for parameters of models which are used in transmission system reliability evaluation. The indices may also be used directly to guide system operation or in assessment of equipment performance. No attempt is made to recommend acceptable equipment reliability levels.

This is a revision of IEEE Std 346-1973. However, terms related to distribution system facilities and interruptions were eliminated from the scope of this document. This document was prepared by the Transmission and Distribution Outage and Interruption Definitions Task Force. This task force was formed by the PROSD (Performance Records for Optimizing System Design) Working Group, which is under the guidance of the Power System Engineering Committee.

## Contents

1. Scope.....	10
2. Purpose.....	10
3. Equipment classifications.....	10
3.1 Component.....	10
3.2 Subcomponent.....	11
3.3 Unit.....	11
3.4 Terminal.....	12
4. Component and unit states and events.....	12
4.1 State.....	12
4.2 Changes in state.....	12
4.3 Outage initiation.....	14
4.4 Outage type.....	14
4.5 Failure.....	15
5. State times.....	16
5.1 Service time.....	16
5.2 Outage time.....	16
5.3 Reporting period time.....	16
5.4 Outage duration.....	16
6. Exposure parameters.....	16
6.1 Exposure (time).....	16
6.2 Exposure (operations).....	17
6.3 Weather.....	17
7. Outage indices.....	18
7.1 Rate indices.....	18
7.2 Duration indices.....	19
7.3 State probability indices.....	19
7.4 Probability of failure indices.....	19
Annex A (informative) Differences between current and original edition.....	21
Annex B (informative) Bibliography.....	22

# IEEE Standard Terms for Reporting and Analyzing Outage Occurrences and Outage States of Electrical Transmission Facilities

## 1. Scope

This standard defines terminology and indices for reporting and analyzing outage occurrences of transmission facilities. Outage definitions and indices are given for two general types of facilities: units and components. Units are functional facilities that transfer power between designated points, while components are specific pieces of equipment.

Outage definitions are given both for describing the outage history of a particular facility and for describing groups of individual outage occurrences that are related in some way.

## 2. Purpose

This standard is intended to aid the electric power industry in reporting and analyzing outage occurrences of transmission facilities. Use of systematic, precise definitions is essential for meaningful exchange of data. It is expected that specific instructions for reporting outages will be developed by the industry based on these definitions. The outage definitions and indices are intended for use in system planning models, operations and maintenance planning, and system design. The definitions and indices may not be sufficiently detailed to cover the information required for equipment design.

## 3. Equipment classifications

### 3.1 Component

A device which performs a major operating function and which is regarded as an entity for purposes of recording and analyzing data on outage occurrences.

NOTE 1—Some examples of components are line sections, transformers, ac/dc converters, series capacitors or reactors, shunt capacitors or reactors, circuit breakers, line protection systems, and bus sections.

NOTE 2—Sometimes it is necessary to subdivide a line section into segments to allow proper calculation of failure rates and exposure data. For example, if a line section is composed of an overhead line segment and an underground line segment, failure, and exposure data for each line segment may be recorded separately.