

AS 2253—1979

Australian Standard[®]

**METHODS FOR FIELD
MEASUREMENT OF THE
REDUCTION OF AIRBORNE
SOUND TRANSMISSION IN
BUILDINGS**

The following scientific, industrial and governmental organizations and departments were officially represented on the committee entrusted with the preparation of this standard:

Australian Acoustical Society
Confederation of Australian Industry
CSIRO, Division of Building Research
Environment Protection Authority, Victoria
Experimental Building Station
Institution of Engineers, Australia
Public Works Department, Western Australia
Royal Australian Institute of Architects
Royal Melbourne Institute of Technology
Universities

This standard, prepared by Committee AK/4, Architectural Acoustics, was approved on behalf of the Council of the Standards Association of Australia on 26 February 1979, and was published on 1 June 1979.

Review of Australian Standards. To keep abreast of progress in industry, Australian Standards are subject to periodic review and are kept up to date by the issue of amendments or new editions as necessary. It is important therefore that Standards users ensure that they are in possession of the latest edition, and any amendments thereto.

Full details of all Australian Standards and related publications will be found in the Standards Australia Catalogue of Publications; this information is supplemented each month by the magazine 'The Australian Standard', which subscribing members receive, and which gives details of new publications, new editions and amendments, and of withdrawn Standards.

Suggestions for improvements to Australian Standards, addressed to the head office of Standards Australia, are welcomed. Notification of any inaccuracy or ambiguity found in an Australian Standard should be made without delay in order that the matter may be investigated and appropriate action taken.

This standard was issued in draft form for public review as part of Doc 979.

AS 2253—1979

Australian Standard[®]

**METHODS FOR FIELD
MEASUREMENT OF THE
REDUCTION OF AIRBORNE
SOUND TRANSMISSION IN
BUILDINGS**

First published 1979

PUBLISHED BY STANDARDS AUSTRALIA
(STANDARDS ASSOCIATION OF AUSTRALIA)
1 THE CRESCENT, HOMEBUSH, NSW 2140

ISBN 0 7262 1655 0

PREFACE

This standard was prepared by the Association's Committee on Architectural Acoustics as one of a series dealing with the evaluation of the sound attenuating properties of building elements. It is intended to enable measurement of the performance of partitions and assemblies of building elements installed in buildings.

The measurement of the sound attenuation of building partitions, unlike the measurement of most of the physical properties of the construction or of the materials, is of necessity made indirectly by determining the sound pressure levels in the spaces on either side. As a result, the measurements can be affected to a significant extent by the nature of these spaces. Hence measurements suitable for general application are more difficult to make in the field, where a great variety of room shapes, sizes and surface conditions are encountered, than they are in the laboratory where the conditions are standardized.

The purpose of this standard is to categorize, as far as possible, the multiplicity of situations that exist in the field into five broad types, and to specify an appropriate measurement procedure for each. Even so, there are likely to be substantial differences between data obtained from similar structures tested in the laboratory and in buildings. In the laboratory, the measurements are restricted to conditions where there are random sound fields on both sides of the partition because of the adoption of appropriate dimensions for the test chambers and of suitable sound absorption coefficients for the surfaces. Also, the specimens for test are generally of an adequate size and area, and special constructions are incorporated to reduce flanking transmission, which, in any case, may be measured and evaluated once for use in all subsequent tests.

In the field, the effect of the environment must be assessed for each measurement that is attempted. The presence of flanking transmission or some other condition may even make a valid determination of sound transmission loss impracticable. In these circumstances, the other procedure of measurement of noise reduction given in this standard may be found adequate and in some cases may even provide more useful information.

The sound transmission loss is mainly required to determine whether the performance of a particular partition type is in accordance with expectations, and whether the particular one under consideration has been faithfully constructed and installed. This may not necessarily be the information that is really wanted in the field, where often it is only the noise reduction between rooms or spaces that is actually required.

The simpler procedure of measuring noise reduction, as well as avoiding the need to identify and eliminate flanking transmission, also avoids the necessity to measure sound absorption in the receiving room. The procedure warrants increased use in specifications and for checking the performance of buildings.

Even where construction weaknesses and flanking transmission are successfully eliminated and conformity with one of the field test situations described in this standard for measurement of transmission loss is achieved, there may still be, for the same construction, discrepancies between the transmission loss measured in the field and that measured in the laboratory. Furthermore, with the differences that exist between buildings, each field transmission loss applies only to a particular field condition and is not necessarily the unique value which is applicable to a certain building element, irrespective of where it is installed. Hence any attempt to adjust field results to conform to the results obtained from laboratory measurements or the measurements in other field situations may have little meaning.

Where a significant number of field transmission loss measurements have been made in accordance with the procedures prescribed in this standard, the range of field transmission losses to be expected from a partition type in different building situations will begin to appear. It may then become possible for a partition to be characterized by two ratings: one that expresses the sound attenuation that it can provide as established by laboratory measurement, and the other that indicates the likely range of its performance when installed in the field.

This standard may require reference to the following documents:

AS 1045	Method of Measurement of Absorption Coefficients in a Reverberation Room
AS 1259	Sound Level Meters
AS 1276	Methods for the Determination of Sound Transmission Class and Noise Isolation Class of Building Partitions
AS 1633	Glossary of Acoustic Terms
AS Z41	Octave, Half Octave and One-third Octave Band Pass Filters Intended for the Analysis of Sound and Vibrations
SAA MP44	Guide for the Use of Sound Measuring Equipment Part 1—Portable Sound Level Meters
ASTM E 90	Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions
ASTM E 336	Test Method for Measurement of Airborne Sound Insulation in Buildings

A related standard is AS 1191, Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions.

© Copyright — STANDARDS AUSTRALIA

Users of Standards are reminded that copyright subsists in all Standards Australia publications and software. Except where the Copyright Act allows and except where provided for below no publications or software produced by Standards Australia may be reproduced, stored in a retrieval system in any form or transmitted by any means without prior permission in writing from Standards Australia. Permission may be conditional on an appropriate royalty payment. Requests for permission and information on commercial software royalties should be directed to the head office of Standards Australia.

Standards Australia will permit up to 10 percent of the technical content pages of a Standard to be copied for use exclusively in-house by purchasers of the Standard without payment of a royalty or advice to Standards Australia.

Standards Australia will also permit the inclusion of its copyright material in computer software programs for no royalty payment provided such programs are used exclusively in-house by the creators of the programs.

Care should be taken to ensure that material used is from the current edition of the Standard and that it is updated whenever the Standard is amended or revised. The number and date of the Standard should therefore be clearly identified.

The use of material in print form or in computer software programs to be used commercially, with or without payment, or in commercial contracts is subject to the payment of a royalty. This policy may be varied by Standards Australia at any time.

CONTENTS

	<i>Page</i>
SECTION 1. SCOPE, APPLICATION AND DEFINITIONS	
1.1 Scope	5
1.2 Application	5
1.3 Definitions	6
SECTION 2. MEASUREMENT OF FIELD TRANSMISSION LOSS	
2.1 Scope of Section	8
2.2 General	8
2.3 Reverberant Source and Receiving Rooms	8
2.4 Either or Both Source and Receiving Spaces Highly Absorptive	10
2.5 Intermediate Configurations	11
2.6 Requirements of Measurements	11
2.7 Calculation of Field Transmission Loss	12
2.8 Report on Results	14
SECTION 3. MEASUREMENT OF NOISE REDUCTION	
3.1 Scope of Section	16
3.2 General	16
3.3 Requirements of Measurements	16
3.4 Calculation of Noise Reduction	17
3.5 Report on Results	17
APPENDIX A. Additional Information Relating to the Field Measurement of Airborne Sound Transmission	19

STANDARDS ASSOCIATION OF AUSTRALIA

Australian Standard

**METHODS FOR FIELD MEASUREMENT OF THE
REDUCTION OF AIRBORNE SOUND TRANSMISSION
IN BUILDINGS**

SECTION 1. SCOPE, APPLICATION AND DEFINITIONS

1.1 SCOPE. This standard sets out the methods for the field measurement of the reduction in the transmission of airborne sound between the spaces in a building separated by a partition (see Note).

The procedures are intended for the measurement of —

- (a) field transmission loss (*FTL*); and
- (b) noise reduction (NR_p).

NOTE: The term 'partition' includes in its meaning walls of all kinds, floor-ceiling assemblies, doors, and other space-dividing elements that may be permanent, openable or movable.

1.2 APPLICATION.

1.2 Field Transmission Loss (*FTL*). The requirements and procedures set out in this standard for the measurement of field transmission loss (*FTL*) are —

- (a) to establish whether a partition's performance complies with a specification for its field transmission loss;
- (b) to establish the field transmission loss of a particular partition for a subsequent specification; and
- (c) to relate a partition's field transmission loss to its laboratory transmission loss.

NOTE: In this regard, it must be recognized that, for a particular partition, there are likely to be differences between the transmission losses measured in the field and those measured in the laboratory that are caused by differences in the acoustic environment and not necessarily by differences in construction.

1.2.2 Noise Reduction (NR_p). The requirements and procedures set out in this standard for the measurement of the noise reduction (NR_p) between two rooms apply when the airborne sound transmission loss of a partition is not in question but when the sound attenuation between the rooms is required including such effects as may be caused by furnishings and flanking transmission.