

# IEEE Guide for Wind Power Plant Grounding System Design for Personnel Safety

IEEE Power and Energy Society

Developed by the  
Energy Development and Power Generation  
Committee

IEEE Std 2760™-2020



# **IEEE Guide for Wind Power Plant Grounding System Design for Personnel Safety**

**Energy Development and Power Generation Committee  
of the  
IEEE Power and Energy Society**

Approved 24 September 2020

**IEEE SA Standards Board**

**Abstract:** The collector system grounding for wind power plants (WPPs) is the primary concern of this guide. This guide is not intended for the WPP substation; however, since the substation is typically interconnected with the collector system, its design might affect or be affected by the collector system. With proper consideration, the methods described herein could be used in determining the impact of the collector system on substation safety and vice versa.

Quantitative analysis of the effects of lightning surges is beyond the scope of this document. Similarly, this guide does not cover offshore wind power plants, battery energy storage facilities, solar power plants, or substation grounding.

**Keywords:** collector system, grounding, IEEE 2760™, safety, wind power plant

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2021 by The Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 29 January 2021. Printed in the United States of America. IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code, NEC, and NFPA 70 are registered trademarks of the National Fire Protection Association.

PDF: ISBN 978-1-5044-7106-0      STD24433  
Print: ISBN 978-1-5044-7107-7      STDPD24433

*IEEE prohibits discrimination, harassment, and bullying.  
For more information, visit <https://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.  
No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

## **Important Notices and Disclaimers Concerning IEEE Standards Documents**

IEEE Standards documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page (<https://standards.ieee.org/ipr/disclaimers.html>), appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.”

### **Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents**

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board. IEEE develops its standards through an accredited consensus development process, which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed by volunteers with scientific, academic, and industry-based expertise in technical working groups. Volunteers are not necessarily members of IEEE or IEEE SA, and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE makes no warranties or representations concerning its standards, and expressly disclaims all warranties, express or implied, concerning this standard, including but not limited to the warranties of merchantability, fitness for a particular purpose and non-infringement. In addition, IEEE does not warrant or represent that the use of the material contained in its standards is free from patent infringement. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity, nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: THE NEED TO PROCURE SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

### **Translations**

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE is the approved IEEE standard.

## Official statements

A statement, written or oral, that is not processed in accordance with the IEEE SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that the presenter's views should be considered the personal views of that individual rather than the formal position of IEEE, IEEE SA, the Standards Committee, or the Working Group.

## Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE or IEEE SA. However, **IEEE does not provide interpretations, consulting information, or advice pertaining to IEEE Standards documents.**

Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its Societies and Standards Coordinating Committees are not able to provide an instant response to comments, or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in evaluating comments or in revisions to an IEEE standard is welcome to join the relevant IEEE working group. You can indicate interest in a working group using the Interests tab in the Manage Profile & Interests area of the [IEEE SA myProject system](#). An IEEE Account is needed to access the application.

Comments on standards should be submitted using the [Contact Us](#) form.

## Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not constitute compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

## Data privacy

Users of IEEE Standards documents should evaluate the standards for considerations of data privacy and data ownership in the context of assessing and using the standards in compliance with applicable laws and regulations.

## Copyrights

IEEE draft and approved standards are copyrighted by IEEE under US and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

## Photocopies

Subject to payment of the appropriate licensing fees, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400; <https://www.copyright.com/>. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every 10 years. When a document is more than 10 years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit [IEEE Xplore](#) or [contact IEEE](#). For more information about the IEEE SA or IEEE's standards development process, visit the IEEE SA Website.

## Errata

Errata, if any, for all IEEE standards can be accessed on the [IEEE SA Website](#). Search for standard number and year of approval to access the web page of the published standard. Errata links are located under the Additional Resources Details section. Errata are also available in [IEEE Xplore](#). Users are encouraged to periodically check for errata.

## Patents

IEEE Standards are developed in compliance with the [IEEE SA Patent Policy](#).

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE SA Website at <https://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

## **IMPORTANT NOTICE**

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. IEEE Standards development activities consider research and information presented to the standards development group in developing any safety recommendations. Other information about safety practices, changes in technology or technology implementation, or impact by peripheral systems also may be pertinent to safety considerations during implementation of the standard. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

## Participants

At the time this IEEE guide was completed, the Wind and Solar Plant Collector System Design Working Group had the following membership:

**Loren Powers, *Chair***  
**Sudipta Dutta, *Vice Chair***

Chris Brooks  
Tracker Goree  
Matt Hadsell  
Dustin Howard

Andy Leon  
Dave Mueller  
Gopal Padmanabhan  
Marius Popescu

Doug Price  
Abdou Sana  
Rob Schaerer  
Alkesh Shah

The following members of the individual balloting committee voted on this guide. Balloters may have voted for approval, disapproval, or abstention.

Robert Aiello  
Curtis Ashton  
James Babcock  
Michael Bayer  
W.J.(Bill) Bergman  
Bryan Beske  
Derek Brown  
Paul Cardinal  
Michael Dana Carlson  
Robert Christman  
Randy Clelland  
William Dietzman  
Thomas Dunmore II  
Sudipta Dutta  
Kevin Fellhoelter  
Rostyslaw Fostiak  
David Garrett  
Jalal Gohari  
Brady Hansen  
Jeffrey Helzer  
Lee Herron  
Werner Hoelzl

Robert Hoerauf  
Peter Kelly  
Boris Kogan  
Jim Kulchisky  
Chung-Yiu Lam  
Andrew Leon  
David Lewis  
Shuhui Li  
Jon Martin  
Dennis Neitzel  
Rajesh Nighot  
Joe Nims  
Michael Novev  
Gearold O. H. Eidhin  
Sivaraman P  
Bansi Patel  
Howard Penrose  
Branimir Petosic  
Christopher Petrola  
Prasad Pmsvsv  
Allan Powers  
Thomas Proios

Charles Rogers  
Christian Sanchez  
Bartien Sayogo  
Robert Schaerer  
Robert Seitz  
Gary Smullin  
Wayne Stec  
Andrew Steffen  
Brian Story  
David Tepen  
James Van De Ligt  
Gerald Vaughn  
John Vergis  
Karl Weber  
Kenneth White  
Richard Keil  
Percy Pool  
Malcolm Thaden  
Donald Wengerter  
Darren Woodhouse  
Terry Woodyard  
Nicholas Zagrodnik

When the IEEE-SA Standards Board approved this guide on 24 September 2020, it had the following membership:

**Gary Hoffman, *Chair***  
**Jon Walter Rosdahl, *Vice Chair***  
**John D. Kulick, *Past Chair***  
**Konstantinos Karachalios, *Secretary***

Ted Burse  
Doug Edwards  
J.Travis Griffith  
Grace Gu  
Guido R. Hiertz  
Joseph L. Koepfinger\*

David J. Law  
Howard Li  
Dong Liu  
Kevin Lu  
Paul Nikolich  
Damir Novosel  
Dorothy Stanley

Mehmet Ulema  
Lei Wang  
Sha Wei  
Philip B. Winston  
Daidi Zhong  
Jingyi Zhou

\*Member Emeritus

## Introduction

This introduction is not part of 2760-2020, Guide for Wind Power Plant Grounding System Design for Personnel Safety.

Wind Power Plants (WPPs) present unique grounding challenges when compared to other generation facilities. This is primarily due to their large interconnected nature—often over several square kilometers—and the fact that the plant is not fenced from the public. This guide addresses those aspects and provides guidance on the design and analysis of grounding systems for these large facilities.

The inaugural version of this document has been prepared by the Wind and Solar Plant Collector Design Working Group and the associated task force on grounding for personnel protection over the last several years.

This document assumes the user is designing using a grounded-wye secondary on the main power transformer. While this grounded-wye arrangement is by far the most common electrical collector system used in WPPs across the United States (US) and most countries in the Americas, many other countries commonly use an ungrounded delta connection. The guidance in this document may not apply to countries that are not using a wye-grounded collector system.

In the US, the most common main power transformer design used in WPPs is a three-winding transformer, as many utilities require a wye grounded high voltage (HV) primary and the WPP desires a wye-grounded medium voltage (MV) secondary. A third delta connected winding (to suppress three phase harmonics) is often added into one transformer case. Occasionally a utility will accept a delta connected HV winding; therefore, a two-winding transformer is used with a delta HV connection and wye-grounded MV connection. In some locations around the world, the three winding transformer is built as two separate transformers; a two-winding transformer with a wye-connected HV side and a delta-connected MV side, and then a separate grounding or ground reference transformer (often of a zig-zag design) is added to create the system ground, or effective ground, on the MV side. Regardless of whether a single transformer or two separate transformers are used, the result is that ground faults on these systems will flow through multiple ground paths back to the wye-ground. In systems that utilize a grounded-wye collection system, the guidance found in this document will apply.

## Contents

1. Overview.....	10
1.1 Scope.....	10
1.2 Purpose.....	10
1.3 Word usage.....	11
2. Normative references.....	11
3. Definitions.....	11
3.1 Definitions.....	11
3.2 Acronyms and abbreviations.....	12
4. Safety issues in WPPs.....	12
4.1 Unintentional ground.....	12
4.2 Intentional ground.....	13
5. Description of a WPP grounding system.....	13
5.1 General.....	13
5.2 Underground collection system grounding.....	14
5.3 Overhead collection system grounding.....	15
5.4 Redundancy of the ground conductor.....	16
5.5 Local WTG grounding.....	16
6. Design approach.....	16
6.1 General.....	16
6.2 Main grounding system design steps.....	17
6.3 Grounding design tools.....	17
6.4 Environment and geotechnical data.....	18
6.5 Soil electrical resistivity models.....	19
6.6 Safety design criteria.....	20
6.7 Ground fault current and split factor.....	20
6.8 Ground conductor.....	22
6.9 Ground electrode system impedance to remote earth calculations.....	24
6.10 Ground potentials calculations.....	24
6.11 Effects of interconnected substation ground grid on WPP.....	25
Annex A (informative) Bibliography.....	26

# IEEE Guide for Wind Power Plant Grounding System Design for Personnel Safety

## 1. Overview

### 1.1 Scope

This guide is primarily concerned with the collector system grounding for onshore wind power plants (WPPs). This guide is not intended for the WPP substation; however, since the substation is typically interconnected with the collector system, its design might affect or be affected by the collector system. With proper consideration, the methods described herein could be used in determining the impact of the collector system on substation safety and vice versa.

Quantitative analysis of the effects of overvoltage transients (switching and lightning) is beyond the scope of this document. Similarly, this guide does not cover offshore WPPs, battery energy storage facilities, solar power plants, or substation grounding.

### 1.2 Purpose

The intent of this guide is to provide guidance and information pertinent to the grounding practices in WPP collector system for personal safety.

The specific purpose of this guide is as follows:

- Identify differences between substation grounding (covered under IEEE Std 80™) and WPP collector system grounding.
- Establish, as a basis for design, safety limits of potential differences that can exist in a WPP collection system under fault conditions between points that can be contacted by the human body.
- Review WPP grounding practices with reference to safety criteria for the design, and provide a procedure for the design of practical grounding systems based on these criteria.
- Develop analytical methods as an aid in the understanding and solution of typical voltage gradient problems within a WPP.

This guide is primarily concerned with grounding practices within WPPs for 50 Hz or 60 Hz systems. DC systems are beyond the scope of this guide. A grounding system designed as described herein does, nonetheless, provide some degree of protection against steep wave front surges (such as lightning) entering the wind turbine generator (WTG) and passing to earth through its grounding system electrodes.