

IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers

Sponsor

**Switchgear Committee of the
IEEE Power Engineering Society**

Approved 26 June 1999

IEEE-SA Standards Board

Abstract: This standard covers the rating structure for all high-voltage circuit breakers, which include all voltage ratings above 1000 V ac and comprise both indoor and outdoor types having the preferred ratings as listed in ANSI C37.06-1997. Typical circuit breakers covered by these standards have maximum voltage ratings ranging from 4.76 kV through 800 kV, and continuous current ratings of 600 A, 1200 A, 2000 A, and 3000 A associated with the various maximum voltage ratings. The rating structure establishes the basis for all assigned ratings, including continuous current, dielectric withstand voltages, short-circuit current, transient recovery voltage, and capacitor switching, plus associated capabilities such as mechanical endurance, load current, and out-of-phase switching. This standard does not cover generator circuit breakers, which are covered in IEEE Std C37.013-1997.

Keywords: capacitance current switching, dielectric withstand, fast transient recovery voltage, indoor, initial, interrupting time, mechanical endurance, operating duty, outdoor, power frequency, ratings, related capabilities, short-circuit current, shortline fault, voltage distribution

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 1999 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 30 December 1999. Printed in the United States of America.

Print: ISBN 0-7381-1781-1 SH94774
PDF: ISBN 0-7381-1782-X SS94774

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

<p>Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.</p>

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (978) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

(This introduction is not part of IEEE Std C37.04-1999, IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers.)

In 1964, consolidated standards for circuit breakers rated on a symmetrical current basis were published to take the place of standards established on the total current basis of rating. This 1999 revision was undertaken to update the standard to reflect today's circuit breaker technology and application on modern power systems. The revision also continues harmonization with IEC 60056 Ed. 4.0b: 1987, a process that first began in 1951.

This document makes significant changes in the rating structure for circuit breakers, such as the change of the voltage range factor, K , and the standard duty cycle. With these changes, information needed to properly apply circuit breakers rated in accordance with the 1979 or 1964 editions of IEEE Std C37.04 are eliminated from this new edition. Accordingly, users must refer to the prior editions of the relevant standards (including IEEE Std C37.04-1999, ANSI C37.06, IEEE Std C37.09-1999, etc.) in order to properly select and apply circuit breakers rated in accordance with the older standards.

NOTE—These older standards are part of the IEEE archives. Contact the IEEE Standards Association for ordering information.

The changes in this standard are explained in the following clause-by-clause summary:

1. Scope—The scope was expanded to clarify the type of circuit breakers specifically covered by this standard.
2. References—A complete updated listing of references is supplied.
3. Definitions—No substantial changes.
4. Service conditions—The usual and unusual service conditions are given. Information given on how to deal with unusual service conditions has been moved to IEEE Std C37.010-1999.
5. Ratings—The rated voltage range factor, K , defined in earlier versions of IEEE Std C37.04 is commonly recognized as being equal to 1.0 for modern interrupting technologies; consequently, the rating structure has been simplified, because the use of a K factor of 1.0 has effectively eliminated K from the rating structure. The rated permissible tripping delay, Y , has been incorporated in the rated closing, latching, and short-time current carrying capability (5.8.2.3).
 - 5.1 Rated maximum voltage—No major changes.
 - 5.2 Rated power frequency—No major changes.
 - 5.3 Rated continuous current—Changes were made to Table 1 (Limits of temperature and temperature rise for various parts and materials of circuit breakers). This table has been brought into better harmony with IEC.
 - 5.4 Rated dielectric withstand capability—Changes clarify basic dielectric requirements.
 - 5.5 Rated standard operating duty (standard duty cycle)—Changed and expanded to include circuit breakers for rapid reclosing and to coordinate with IEC.
 - 5.6 Rated interrupting time—The definition was clarified and updated for modern circuit breaker performance.
 - 5.7 Contact parting time—This definition was modified to alert users of high-voltage circuit breakers that it may be necessary to add external delay to account for fault deionization times on power systems.
 - 5.8 Rated short-circuit current and related required capabilities
 - 5.8.1 Rated short-circuit current—No major changes.
 - 5.8.2 Related required capabilities—The required asymmetrical interrupting capability for three-phase faults (5.8.2.2) defines the percent dc component based on the standard time constant of 45 ms (corresponding to an X/R of 17 for 60 Hz or 14 for 50 Hz). This

replaces the “S-factor” concept used in earlier versions of IEEE Std C37.04.

The rated closing, latching, and short-time current carrying capability (5.8.2.3) incorporates the permissible tripping delay and short-time current into values that coordinate with IEC. The required reclosing capability is referenced to IEEE Std C37.010-1999.

- 5.9 Rated transient recovery voltage (TRV)—This subclause of the standard was expanded to provide a detailed explanation of how TRV values are calculated. The first pole-to-clear factor and transient amplitude factors have been harmonized with IEC in preparation for future harmonization of waveshapes for testing. The shortline fault surge impedance and amplitude constant were harmonized to a single value. The initial TRV was incorporated from IEEE Std C37.04i-1991.
- 5.10 Rated operating endurance capabilities—This subclause replaced “Required load current switching capability and life.”
- 5.11 Rated capacitance current switching—This subclause was not changed. Requirements for capacitance switching are currently under review by a joint IEEE/IEC working group.
- 5.12 Out-of-phase switching current capability—No major changes.
- 5.13 Shunt reactor current switching capability—References are made to IEEE Std C37.015-1993.
- 5.14 Rated line closing switching surge factor—No changes.
- 5.15 Rated control voltage—IEC definitions are incorporated.
- 5.16 Rated operating pressure for insulation and/or interruption (P_{re})—IEC definitions are incorporated.
- 5.17 Rated operating pressure for mechanical operation (P_{rm})—IEC definitions are incorporated.
6. Construction
 - 6.1 Outdoor apparatus bushings—References have been updated.
 - 6.2 Creepage distance—References ANSI C37.06-1997 requirements.
 - 6.3 Mechanical loading—This subclause has been updated to reflect individual mechanical loads per IEC.
 - 6.4 Pressurized components—Requirements for non-ceramic pressurized vessels have been added.
 - 6.5 Pressurized systems—No major changes.
 - 6.6 Gas and vacuum tightness—Requirements have been added that correlate to IEC.
 - 6.7 Functional components—Basic requirements for circuit breakers have been defined.
 - 6.8 Stored energy requirements for operating mechanisms—Basic requirements for stored energy are established based upon the time to replenish the stored energy after operation.
 - 6.9 Operating mechanism requirements—Establishes trip-free and anti-pump requirements.
 - 6.10 Electromagnetic compatibility (EMC)—Establishes withstand of secondary systems.
 - 6.11 Requirements for simultaneity of poles—Establishes mechanical requirements in correlation with IEC.
7. Nameplate markings—No major changes.

Participants

This standard was developed by the High-Voltage Circuit Breaker Subcommittee of the IEEE Switchgear Committee. At the time this standard was completed, the members of this working group were as follows:

Ruben D. Garzon, *Chair*

Anne Bosma
John H. Brunke
Randall L. Dotson
Denis Dufournet

Stephen R. Lambert
R. W. Long
Andy McCabe
Hugh C. Ross

Eric Ruoss
Devki Sharma
H. Melvin Smith
John Tannery

The following members of the balloting committee voted on this standard:

Roy W. Alexander
Steve Atkinson
W. J. Bill Bergman
Steven A. Boggs
Anne Bosma
Matthew Brown
John H. Brunke
Ted Burse
Eldridge R. Byron
Carlos L. Cabrera-Rueda
Raymond L. Capra
James F. Christensen
Stephen P. Conrad
Steven J. Delisi
Patrick J. DiLillo
Alexander Dixon
Randall L. Dotson
J. J. Dravis
Denis Dufournet
Peter W. Dwyer
Douglas J. Edwards
Gary R. Engmann
Jay Fischer
Charles G. Garner
Mietek T. Glinkowski
Dave Gohil
David F. Gray
Keith Gray

Ian J. Harvey
Harold L. Hess
Richard H. Hulett
Jerry M. Jerabek
Aftab H. Khan
Joseph L. Koepfinger
P. L. Kolarik
David G. Kumbera
Stephen R. Lambert
Thomas W. LaRose
W. E. Laubach
David Lemmerman
Albert Livshitz
R. W. Long
Jeffrey D. Lord
Deepak Mazumdar
L. V. McCall
Neil McCord
Nigel P. McQuin
Peter Meyer
Daleep C. Mohla
F. J. Muench
Raja Munayirji
Yasin I. Musa
Philip R. Nannery
Jeffrey H. Nelson
Paul J. Notarian
T. W. Olsen
Miklos J. Orosz

Gordon O. Perkins
Jack E. Reed
David N. Reynolds
Hugh C. Ross
Gerald Sakats
Hazairin Samaulah
Roger A. Sarkinen
Gary Schauffler
Larry H. Schmidt
E. W. Schmunk
Donald E. Seay
M. Dean Sigmon
H. Melvin Smith
R. Kirkland Smith
James E. Smith
Guy St. Jean
David Stone
Alan D. Storms
William M. Strang
David Swindler
Stan H. Telander
Frederick C. Teufel
Malcolm V. Thaden
Thomas J. Tobin
Michael Wactor
Charles L. Wagner
Larry E. Yonce
Janusz Zawadzki

When the IEEE-SA Standards Board approved this standard on 26 June 1999, it had the following membership:

Richard J. Holleman, *Chair*
Donald N. Heirman, *Vice Chair*
Judith Gorman, *Secretary*

Satish K. Aggarwal
Dennis Bodson
Mark D. Bowman
James T. Carlo
Gary R. Engmann
Harold E. Epstein
Jay Forster*
Ruben D. Garzon

James H. Gurney
Lowell G. Johnson
Robert J. Kennelly
E. G. "Al" Kiener
Joseph L. Koepfinger*
L. Bruce McClung
Daleep C. Mohla
Robert F. Munzner

Louis-François Pau
Ronald C. Petersen
Gerald H. Peterson
John B. Posey
Gary S. Robinson
Akio Tojo
Hans E. Weinrich
Donald W. Zipse

*Member Emeritus

Also included is the following nonvoting IEEE-SA Standards Board liaison:

Robert E. Hebner

Noelle D. Humenick
IEEE Standards Project Editor

Contents

1.	Scope.....	1
2.	References.....	1
3.	Definitions.....	3
4.	Service conditions.....	3
	4.1 Usual service conditions	3
	4.2 Unusual service conditions	3
5.	Ratings	3
	5.1 Rated maximum voltage	4
	5.2 Rated power frequency	4
	5.3 Rated continuous current	4
	5.4 Rated dielectric withstand capability	7
	5.5 Rated standard operating duty (standard duty cycle).....	8
	5.6 Rated interrupting time	9
	5.7 Contact parting time.....	9
	5.8 Rated short-circuit current and related required capabilities	9
	5.9 Rated transient recovery voltage (TRV).....	11
	5.10 Rated operating endurance capabilities	17
	5.11 Rated capacitance current switching.....	17
	5.12 Out-of-phase switching current capability.....	19
	5.13 Shunt reactor current switching capability	20
	5.14 Rated line closing switching surge factor	20
	5.15 Rated control voltage	20
	5.16 Rated operating pressure for insulation and/or interruption (Pre)	20
	5.17 Rated operating pressure for mechanical operation (Prm)	21
6.	Construction.....	21
	6.1 Outdoor apparatus bushings.....	21
	6.2 Creepage distance	21
	6.3 Mechanical loading.....	21
	6.4 Pressurized components.....	23
	6.5 Pressurized systems	23
	6.6 Gas and vacuum tightness.....	24
	6.7 Functional components	24
	6.8 Stored energy requirements for operating mechanisms.....	25
	6.9 Operating mechanism requirements	25
	6.10 Electromagnetic compatibility (EMC).....	26
	6.11 Requirements for simultaneity of poles	26
7.	Nameplate markings	27
	7.1 Circuit breaker	27
	7.2 External insulation	27
	7.3 Operating mechanism	28
	7.4 Current transformers and linear coupler transformers	28
	7.5 Accessories	28
	7.6 Instruction and warning signs	29

IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers

1. Scope

This standard establishes a symmetrical current rating structure and construction requirements for all indoor and outdoor types of ac high-voltage circuit breakers rated above 1000 V. It is only applicable to three-pole circuit breakers used in three-phase systems and single-pole circuit breakers used in single-phase systems. This standard does not cover circuit breakers used at frequencies other than 50 Hz or 60 Hz, or generator circuit breakers that are covered in IEEE Std C37.013-1997.

2. References

This standard shall be used in conjunction with the following publications. When a standard is superseded by an approved revision, the revision shall apply.

ANSI C37.06-1997, American National Standard for Switchgear—AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis—Preferred Ratings and Related Required Capabilities.¹

ANSI C37.06.1-1997, American National Standard Trial-Use Guide for High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis—Designated “Definite Purpose for Fast Transient Recovery Voltage Rise Times.”

ANSI C37.54-1996, American National Standard for Switchgear—Indoor Alternating-Current High-Voltage Circuit Breakers Applied as Removable Elements in Metal-Enclosed Switchgear Assemblies—Conformance Test.

ANSI C84.1-1989, American National Standard for Voltage Ratings for Electric Power Systems and Equipment (60 Hz).²

ASME 1998 Boiler and Pressure Vessel Code, Section VIII, Pressure Vessels.³

¹ANSI C37 standards are available from the Institute of Electrical and Electronics Engineers, 445 Hoes Lane, P.O. Box 1331, Piscataway, NJ 08855-1331, USA (<http://www.standards.ieee.org/>).

²ANSI publications are available from the Sales Department, American National Standards Institute, 11 West 42nd Street, 13th Floor, New York, NY 10036, USA (<http://www.ansi.org/>).

³ASME publications are available from the American Society of Mechanical Engineers, 3 Park Avenue, New York, NY 10016-5990, USA (<http://www.asme.org/>).